Table 1: EDM Monitored Sites in Good Health

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	(LOUGHBOROUGH (Sewage Treatment Works))LOUGHBOROUGH Sewage Treatment Works	T/57/45484/R	A2			323.9	55	99.99%		
Severn Trent Water	ILKESTON - 29 Cantelupe Road	No known permit reference	Single Discharge			29.6	4	99.04%		2020
Severn Trent Water	168 WARWICK ROAD (CSO)	S/13/26837/O	Single Discharge			49.5	32	99.98%		
Severn Trent Water	71a Station Road, Gunness (CSO)	No known permit reference	Single Discharge			173.9	16	100.00%		2020
Severn Trent Water	83 Bordesley Green Road, Birmingham	No known permit reference	Single Discharge			23.4	28	99.98%		2020
Severn Trent Water	Abberley PS	S/08/22038/R - S/08/22038/O	A1			138.0	32	97.71%		
Severn Trent Water	ABBEY HULTON - GREASLEY ROAD 2 (CSO)	T/01/35797/O	Single Discharge			16.0	30	99.98%		
Severn Trent Water	ABBEY LATHE - MALTBY (STW)	T/76/45916/R	A2			184.7	40	100.00%		2020
Severn Trent Water	ABBEY ROAD PUMPING STATION (EVESHAM - ABBEY ROAD (TPS))	S/17/23105/O	Single Discharge			137.5	22	98.29%		
Severn Trent Water	ABBOTS BROMLEY (STW)	T/06/35611/R	A2			999.7	51	100.00%		2020
Severn Trent Water	ACKLETON AND STABLEFORD Sewage Treatment Works (ACKLETON/STABLEFORD (Sewage Treatment Works))	S/05/55894/R	A2			1899.2	98	99.99%		
Severn Trent Water	ACRESFORD - BURTON ROAD (SPS)	T/23/02833/O	A1			0.0	0	99.08%		2020
Severn Trent Water	ADCOTE (SPS)	TSC3009	Single Discharge			433.8	34	100.00%		2020
Severn Trent Water	Adj Lane End Kirkby-in-Ashfield CSO	T/61/45981/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	AISBY (STW)	T/80/45928/R	A2			1.8	1	100.00%		2020
Severn Trent Water	ALBERT ROAD	No known permit reference	Single Discharge			17.5	17	99.99%		2020
Severn Trent Water	ALBERT VILLAGE - HIGHFIELDS PS (CSO)	T/23/03574/O-1	A1			0.0	0	100.00%		2020
Severn Trent Water	ALBRIGHTON - NEWPORT ROAD (SOF)	NPSWQD000857	Single Discharge			57.3	39	99.93%		2020
Severn Trent Water	ALBRIGHTON (STW)	S/05/55875/R	A2			278.2	36	100.00%		2020
Severn Trent Water	ALCESTER - FAIRWATER CRESCENT (TPS)	TSC3360	A1			58.6	8	100.00%		2020
Severn Trent Water	ALCESTER - SCHOOL ROAD (SPS)	S/15/09257/O	A1			0.0	0	91.30%		2020
Severn Trent Water	ALCESTER (STW)	S/15/26435/B	A2			665.2	55	100.00%		2020
Severn Trent Water	ALCESTER (STW)	S/15/26435/B	A3			0.0	0	100.00%		2020
Severn Trent Water	ALFRETON - BROOK AVENUE (CSO)	T/41/20315/O	Single Discharge			10.7	15	100.00%		2020
Severn Trent Water	ALFRETON - FIELD OFF EACHWELLS LANE (CSO)	TSC730	Single Discharge			2.9	4	100.00%		2020
Severn Trent Water	ALFRETON - HIGHFIELDS (SPS)	T/41/22362/O	A1			22.6	8	98.79%		2020
Severn Trent Water	ALFRETON - LYDFORD ROAD (CSO)	T/41/21121/O	Single Discharge			13.5	14	99.99%		
Severn Trent Water	ALFRETON - MEADOW LANE (SPS)	T/41/40224/O	A1			142.9	35	100.00%		2020
Severn Trent Water	ALFRETON - TRENT GROVE 11 (CSO)	T/41/45490/O	Single Discharge			60.3	40	91.95%		
Severn Trent Water	ALFRETON (STW)	T/41/45824/R	A3			95.2	23	100.00%		2020
Severn Trent Water	ALFRICK - CLAY GREEN (STW)	S/09/56139/R	A2			202.9	77	100.00%		2020
Severn Trent Water	ALKBOROUGH (STW)	T/81/45466/R	A2			171.9	80	100.00%		2020
Severn Trent Water	ALKBOROUGH (STW)	T/81/45466/R	A3			74.3	8	100.00%		2020
Severn Trent Water	ALLESLEY - BROOKSIDE AVENUE (CSO)	S/11/05067/O	Single Discharge			7.9	11	99.99%		
Severn Trent Water	ALLESTREE - DUFFIELD ROAD (SPS)	T/46/40237/O	A1			68.8	34	93.44%		
Severn Trent Water	ALLESTREE - MARKEATON LANE (CSO)	T/46/12418/O	Single Discharge			84.4	38	99.99%		
Severn Trent Water	ALREWAS (STW)	T/07/36151/R	A2			48.9	11	100.00%		2020
Severn Trent Water	ALTHORPE (STW)	T/83/45559/R	A2			2733.9	136	99.88%		2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	ALTON - SALTERSFORD LANE (CSO)	T/30/21596/O	Single Discharge			0.6	3	99.98%		
Severn Trent Water	ALTON (STW)	T/30/36203/R	A2			339.3	56	99.87%		2020
Severn Trent Water	ALTON- NEW ROAD (CSO)	T/30/20989/O	Single Discharge			5.5	9	100.00%		2020
Severn Trent Water	ALUM ROCK - ALUM ROCK RD/PELHAM RD (CSO)	DT/9806	Single Discharge			181.7	26	99.94%		2020
Severn Trent Water	ALVECHURCH - RADFORD ROAD (CSO)	S/15/21079/O	Single Discharge			60.6	39	94.93%		
Severn Trent Water	ALVECHURCH - THE ORCHARD (SPS)	S/15/25300/O	A1			4.4	2	100.00%		2020
Severn Trent Water	ALVECHURCH (STW)	S/15/25875/R	A2			241.6	31	100.00%		2020
Severn Trent Water	ALVELEY - DADDLEBROOK ROAD 46 (CSO)	S/02/21992/O	Single Discharge			1.0	2	99.99%		2020
Severn Trent Water	ALVELEY (STW)	S/02/56058/R	A2			148.8	27	100.00%		2020
Severn Trent Water	ALVINGTON - ST ANNES WELL (SPS)	S/20/21755/O	Single Discharge			493.0	43	100.00%		2020
Severn Trent Water	AMBERGATE - DERBY RD/NEWBRIDGE RD (CSO)	T/42/22293/O	Single Discharge			1.4	7	88.38%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	AMBERGATE - HAGWOOD (RIVERSDALE) (WRPS)	T/41/21542/O	Single Discharge			528.2	65	99.86%		2020
Severn Trent Water	AMBERGATE - RIPLEY ROAD (TPS)	T/41/40326/O	A1			30.4	13	100.00%		2020
Severn Trent Water	AMBERGATE (STW)	T/41/45524/R	A2			133.0	22	100.00%		2020
Severn Trent Water	AMBERGATE PS - STORM/EMERGENCY O/F (AMBERGATE - DERBY ROAD (SPS))	T/42/09111/O	A1			239.8	31	99.97%		
Severn Trent Water	AMISON STREET (LONGTON - AMISON STREET (CSO))	T/01/36226/O	Single Discharge			0.0	1	99.96%		
Severn Trent Water	ANCHOR ROAD (LONGTON - ANCHOR ROAD (CSO))	T/01/22783/O	Single Discharge			2.0	8	95.48%		
Severn Trent Water	ANDERSON ROAD (BEARWOOD - ANDERSON ROAD (CSO))	T/09/36150/O	Single Discharge			0.0	2	99.84%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	ANGLESEY ROAD STORM OVERFLOW (BURTON UPON TRENT - ANGLESEY RD 87 (CSO))	T/24/21575/O	Single Discharge			0.7	2	99.75%		
Severn Trent Water	ANKER BRIDGE PUMPING STATION (BRAMCOTE - ANKER BRIDGE (SPS))	T/19/36340/O	Single Discharge			922.2	44	99.64%		
Severn Trent Water	ANNESLEY - MOSELEY ROAD (CSO)	T/63/07350/O	Single Discharge			0.0	0	97.25%		
Severn Trent Water	ANNESLEY WOODHOUSE - FOREST ROAD A (CSO)	T/63/07054/O	Single Discharge			0.0	0	93.56%		2020
Severn Trent Water	ANSTON - RACKFORD ROAD (STW)	T/75/46078/R	A2			68.3	12	100.00%		2020
Severn Trent Water	Arden Road Saltley	No known permit reference	Single Discharge			5.6	12	100.00%		2020
Severn Trent Water	AREAS MILFORD & BELPER/SM & EM O/F (BELPER - BABBINGTON HOSPITAL (SPS))	T/42/03392/O-4	A1			124.6	14	99.89%		
Severn Trent Water	AREAS MILFORD & BELPER/SM & EM O/F (MILFORD - FOUNDARY LANE PS (CSO))	T/42/03392/O-6	A1			1014.1	45	94.33%		
Severn Trent Water	AREAS MILFORD & BELPER/SM & EM O/F (MILFORD - MAIN ROAD (DERBYSHIRE) (SPS))	T/42/03392/O-5	A1			72.1	7	99.82%		
Severn Trent Water	AREAS MILFORD & BELPER/SM & EM O/F (MILFORD - PLAY GROUND (SPS))	T/42/03392/O-1	A1			3.9	9	99.45%		
Severn Trent Water	AREAS MILFORD & BELPER/SM & EM O/F (MILFORD - SPORTS GROUND (SPS))	T/42/03392/O-2	A1			60.5	22	99.98%		
Severn Trent Water	AREAS OF CARLTON CSOS (MARSHALL RD) (CARLTON - FOXHILL RD CENTRAL (CSO))	T/64/08304/O-4	Single Discharge			8.2	7	99.17%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	AREAS OF CARLTON CSOS (MARSHALL RD) (CARLTON - FOXHILL RD WST/ERNEST RD (CSO))	T/64/08304/O-1	Single Discharge			1.5	5	99.02%		
Severn Trent Water	AREAS OF CARLTON CSOS (MARSHALL RD) (CARLTON - FOXHILL RD/FIRST AVE (CSO))	T/64/08304/O	Single Discharge			190.0	88	99.96%		
Severn Trent Water	AREAS of CARLTON CSOS (MARSHALL RD) (CARLTON - VALLEY ROAD (CSO))	T/64/46346/O	Single Discharge			1.6	5	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	ARMITAGE (STW)	T/05/36081/R	A3			24.5	13	100.00%		2020
Severn Trent Water	Armitage PS	TSC110	A1			7.0	6	91.37%		2020
Severn Trent Water	ARMITAGE ROAD PUMPING STATION (RUGELEY - ARMITAGE LANE (CSO))	T/05/03401/O-2	Single Discharge			1.5	6	99.64%		
Severn Trent Water	ARMITAGE ROAD PUMPING STATION (RUGELEY - ARMITAGE ROAD (SPS))	T/05/35793/O	A1			4.3	2	99.90%		
Severn Trent Water	ARMITAGE ROAD PUMPING STATION (RUGELEY - BRERETON PARK (CSO))	T/05/03401/O-9	Single Discharge			1.8	2	99.91%		
Severn Trent Water	ARMITAGE SEWAGE TREATMENT WORKS (ARMITAGE (Sewage Treatment Works))	T/05/36081/R	A2			128.5	38	99.79%		
Severn Trent Water	ARMTHORPE - COWHOUSE LANE (CSO)	T/83/03705/O	Single Discharge			0.2	1	96.97%		2020
Severn Trent Water	ARNOLD - NOTTINGHAM ROAD (CSO)	T/63/40290/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	ASDA,OXFORD SREET,NEWCASTLE (ETRURIA - QUEENSWAY (CSO))	T/01/21241/O	Single Discharge			9.2	29	99.91%		
Severn Trent Water	ASFORDBY FOUL STORM SEWAGE OVERFLOW (ASFORDBY - MAIN STREET (CSO))	T/55/12424/O	Single Discharge			11.5	5	99.99%		
Severn Trent Water	ASFORDBY PS (CSO)	T/55/45966/P	A1			1080.6	54	93.26%		2020
Severn Trent Water	ASFORDBY,KIRBY BELLARS,ROTHERBY PSS (KIRBY BELLARS - WASHDYKE LANE (TPS))	T/55/02241/O-2	Single Discharge			451.6	21	94.21%		
Severn Trent Water	ASHBOURNE - HENMORE BROOK (CSO)	DT/6404	Single Discharge			43.9	22	99.99%		
Severn Trent Water	ASHBOURNE - KING EDWARD ST (CSO)	WQD003289	Single Discharge			16.5	10	99.58%		
Severn Trent Water	ASHBOURNE (STW)	T/29/35728/R	A2			1408.1	103	99.58%		2020
Severn Trent Water	ASHBY - BATH GROUNDS (CSO)	T/23/21320/O	Single Discharge			0.0	0	99.99%		2020
Severn Trent Water	ASHBY - NOTTINGHAM ROAD (SPS)	T/23/08875/O	A1			0.0	0	100.00%		2020
Severn Trent Water	ASHBY FOLVILLE - FOLVILLE STREET (TPS)	T/55/03479/O-1	Single Discharge			13.4	2	100.00%		2020
Severn Trent Water	ASHBY FOLVILLE (STW)	T/55/45649/R	A2			308.8	30	99.99%		2020
Severn Trent Water	ASHBY MAGNA - STATION ROAD (SPS)	T/50/00802/O	A1			42.7	24	100.00%		2020
Severn Trent Water	ASHCHURCH - ASHCHURCH SCHOOL (SPS)	TSC3039	A1			6.7	1	100.00%		2020
Severn Trent Water	ASHFORD - BUXTON ROAD (CSO)	TSC269	Single Discharge			265.8	21	100.00%		2020
Severn Trent Water	ASHFORD - CHURCH STREET (CSO)	T/39/21265/O	Single Discharge			0.0	0	99.82%		
Severn Trent Water	ASHLEY WRW (O/FLOW ON WORKS)	T/02/21092/O	Single Discharge			426.6	82	100.00%		2020
Severn Trent Water	ASHOVER (STW)	T/41/45611/R	A3			198.0	26	100.00%		2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	ASHOVER Sewage Treatment Works (ASHOVER (Sewage Treatment Works))	T/41/45611/R	A2			985.9	101	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	ASHTON UNDER HILL (STW)	S/17/26154/R	A2			19.3	2	100.00%		2020
Severn Trent Water	ASHWELL (TPS)	T/54/40223/O	A1			153.8	13	100.00%		2020
Severn Trent Water	ASLOCKTON (STW)	T/67/45582/R	A2			264.6	30	99.98%		2020
Severn Trent Water	ASPLEY - AMERSHAM RISE (CSO)	T/63/22238/O	Single Discharge			0.0	0	99.09%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	ASPLEY - MELBOURNE RD/LEDBURY VALE (CSO)	T/63/22237/O	Single Discharge			1.6	4	99.31%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	ASTON - CHESTER STREET (CSO)	T/09/01056/O-2	Single Discharge			0.3	1	99.89%		2020
Severn Trent Water	ASTON - STATION RD/YEW TREE RD (CSO)	T/08/22244/O	Single Discharge			2.1	3	99.98%		
Severn Trent Water	Aston-On-Trent PS	T/49/02939/O	A1			241.4	14	100.00%		2020
Severn Trent Water	ASTWOOD BANK (STW)	S/19/26530/R	A2			1334.3	58	99.97%		2020
Severn Trent Water	ATHERSTONE - ROYAL MEADOW DRIVE (SSO)	NPSWQD003812	Single Discharge			102.3	47	99.90%		
Severn Trent Water	ATHERSTONE (STW)	T/19/35541/R	A3			18.6	16	100.00%		2020
Severn Trent Water	AUSTREY - WARTON LANE (SPS)	T/21/00159/R-2	Single Discharge			502.8	58	99.98%		
Severn Trent Water	AVERHAM - CHURCH LANE (SPS)	T/68/00222/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	AWSWORTH - GIN CLOSE WAY (CSO)	T/61/08109/O	Single Discharge			13.6	10	99.93%		
Severn Trent Water	BADGEWORTH - BADGEWORTH ROAD (SPS)	S/20/23190/O	A1			411.8	26	100.00%		2020
Severn Trent Water	BAGTHORPE (CSO)	T/61/03116/O-2	Single Discharge			232.3	25	99.98%		2020
Severn Trent Water	BAKEWELL - BASLOW ROAD (CSO)	T/38/02671/O	Single Discharge			47.4	18	99.98%		
Severn Trent Water	BAKEWELL SEWAGE TREATMENT WORKS (BAKEWELL - PICKORY CORNER (Sewage Treatment Works))	T/39/46184/R	A2			2690.8	143	99.99%		
Severn Trent Water	BALDERTON (STW)	T/67/45414/R	A2			375.5	28	100.00%		2020
Severn Trent Water	BALLINSON ROAD (BLURTON - BALLINSON ROAD (CSO))	T/01/30151/O	Single Discharge			2.3	7	99.93%		
Severn Trent Water	BALSALL COMMON (STW)	T/11/35953/R	A3			0.0	0	100.00%		2020
Severn Trent Water	BALSALL HEATH - BALSALL HEATH ROAD (CSO)	DT/9839	Single Discharge			0.0	0	99.95%		2020
Severn Trent Water	BALSALL HEATH - EDGBASTON ROAD (CSO)	DT/9845	Single Discharge			0.0	0	99.91%		2020
Severn Trent Water	BALSALL HEATH - MARY STREET (CSO)	DT/9841	Single Discharge			0.0	0	99.77%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	BAMFORD - ROSE GARDENS (TPS)	T/38/40245/O	A1			181.7	31	100.00%		2020
Severn Trent Water	BANNISTER STREET STORM OVERFLOW (CRADLEY HEATH - BANNISTER STREET (CSO))	S/06/21043/O	Single Discharge			873.2	55	99.99%		
Severn Trent Water	Barkers Lane/Meadow Ln Chilwell PS	T/62/40124/O	A1			113.7	24	99.95%		
Severn Trent Water	BARLESTONE - BROOKSIDE (CSO)	T/20/35410/O	Single Discharge			6.7	10	79.94%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BARLESTONE WWTW (BARLESTONE (Sewage Treatment Works))	T/20/35726/R	A2			313.1	59	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BARNHURST SEWAGE TREATMENT WORKS (BARNHURST (Sewage Treatment Works))	S/06/55227/R	A2			115.4	10	100.00%		
Severn Trent Water	BARNT GREEN - BITTELL RD/HEWELL RD (CSO)	S/07/04176/O	Single Discharge			14.8	21	99.74%		2020
Severn Trent Water	BARSBY - MAIN STREET (TPS)	T/55/03479/O-2	Single Discharge			31.2	11	100.00%		2020
Severn Trent Water	BARTON (Sewage Treatment Works)	T/24/35673/R	A2			7102.2	305	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BARTON UNDER NEEDWOOD - VILLAGE (CSO)	T/24/30265/O	Single Discharge			34.6	12	99.68%		
Severn Trent Water	Barwell – Farm Road PS	No known permit reference	A1			1.2	3	99.24%		2020
Severn Trent Water	BARWELL - THE COMMON (SPS)	T/50/03182/O	A1			41.3	32	99.97%		2020
Severn Trent Water	BASCHURCH - WALFORD HEATH (SPS)	TSC4037	A1			380.9	23	100.00%		2020
Severn Trent Water	BASCOTE (STW)	S/12/25831/R	A2			628.3	47	100.00%		2020
Severn Trent Water	BASLOW (STW)	T/38/45845/R	A2			0.0	0	99.84%		2020
Severn Trent Water	BASSETTS POLE (STW)	T/16/36166/R	A2			130.0	22	100.00%		2020
Severn Trent Water	BATH PLACE CSO (LEAMINGTON - BATH PLACE (CSO))	EPRWP3926XH	Single Discharge			26.5	20	100.00%		
Severn Trent Water	BATH ROAD (2) (LONGTON - BATHS ROAD (CSO))	T/01/22804/O	Single Discharge			2.8	9	99.89%		
Severn Trent Water	BATH ROAD (LONGTON - BATHS ROAD/MOULTON ROAD (CSO))	T/01/22805/O	Single Discharge			0.0	0	99.86%		
Severn Trent Water	BATHLEY - MUSKHAM LANE (SPS)	TSC3683	A1			0.0	0	100.00%		2020
Severn Trent Water	BATTLEFLAT - WEST LANE (SPS)	T/20/01553/O	A1			84.5	11	100.00%		2020
Severn Trent Water	BAWTRY - WHARF STREET (TPS)	T/78/07732/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	BAYSTON HILL - OAK TREE DRIVE (SPS)	TSC3450	A1			1.4	1	94.97%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	BAYSTON HILL - SHARPSTONES LANE (CSO)	S/02/21409/O	Single Discharge			48.3	24	99.99%		
Severn Trent Water	BAYSTON ROAD CSO (KINGS HEATH - BAYSTON RD PLAYING FIELDS (CSO))	T/12/36475/O	Single Discharge			7.7	24	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BEARLEY Sewage Treatment Works (BEARLEY (Sewage Treatment Works))	S/15/25830/R	A2			31.8	51	99.95%		
Severn Trent Water	BECKBURY SEWAGE TREATMENT WORKS (BECKBURY (Sewage Treatment Works))	S/05/55881/R	A2			25.7	30	99.64%		
Severn Trent Water	BEDDELEY GREEN FARM (BADDELEY GREEN - REGENCY DRIVE (CSO))	T/01/02126/O	Single Discharge			22.8	27	100.00%		
Severn Trent Water	BEDWORTH - JUNC. CHAPEL ST/RYE PIECE (SO)	T/19/01500/O-3	Single Discharge			0.6	5	97.31%		2020
Severn Trent Water	BEDWORTH MARSTON LANE WWTW (MARSTON LANE BEDWORTH (Sewage Treatment Works))	T/19/36017/R	A2			45.6	18	96.01%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	BEECHWOOD AVENUE PUMPING STATION (LEICESTER FOREST E - BEECHWOOD AVE (SPS))	T/52/40157/O	Single Discharge			5.8	1	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	Beeley PS	TSC3086	A1			1.6	3	99.87%		2020
Severn Trent Water	BEESTON - DOVECOTE LANE PS (CSO)	TSC646	A1			45.9	13	99.95%		2020
Severn Trent Water	BELBROUGHTON - QUEENS HILL (CSO)	S/06/21060/O	Single Discharge			548.6	24	99.98%		
Severn Trent Water	BELGRAVE - DYSART WAY (CSO)	TSC664	Single Discharge			7.7	18	86.38%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	Belle Vale Storm Tanks	PS/T/3092 & S/06/56331/O	Single Discharge			504.4	39	99.99%		
Severn Trent Water	BELPER - BARGATE ROAD (SST)	T/42/12283/O	Single Discharge			50.0	11	89.25%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BELPER - THE FLEET 30 (CSO)	T/42/20920/O	Single Discharge			0.7	3	85.59%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BELPER SEWAGE TREATMENT WORKS (BELPER (Sewage Treatment Works))	T/42/46187/R	A2			560.5	60	99.96%		
Severn Trent Water	BENHALL - WHITTINGTON ROAD (CSO)	S/20/26390/O	Single Discharge			32.1	10	100.00%		
Severn Trent Water	BENNETT STREET STORM OVERFLOW (LONG EATON - BENNET ST/ CANAL ST (CSO)	T/61/22211/O	Single Discharge			15.1	5	92.72%		
Severn Trent Water	BENTON GREEN - BENTON GREEN LANE (SPS)	T/11/12330/O	A1			0.0	0	100.00%		2020
Severn Trent Water	BERKSWELL - LAVENDER HALL LANE (CSO)	T/11/02640/O	Single Discharge			0.5	4	99.88%		2020
Severn Trent Water	BERKSWELL (STW)	T/11/35941/R	A2			636.5	31	99.95%		2020
Severn Trent Water	BESCOT - BESCOT ROAD (CSO)	T/08/36115/B	Single Discharge			33.6	9	99.99%		
Severn Trent Water	Bescot Crescent, Bescot - Needs abandoning - never operates but if there is blockage would pollute	No known permit reference	Single Discharge			22.8	4	99.89%		2020
Severn Trent Water	BESTWOOD - OLD MILL CLOSE (CSO)	T/63/07757/O	Single Discharge			6.8	10	99.97%		
Severn Trent Water	BIDFORD ON AVON Sewage Treatment Works (BIDFORD-ON-AVON (Sewage Treatment Works))	S/13/25360/R	A2			2249.0	162	100.00%		
Severn Trent Water	BILLESLEY - DENE HOLLOW (CSO)	T/12/36037/O	Single Discharge			9.8	21	90.50%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BILSTHORPE (STW)	T/70/45934/R	A2			108.2	16	99.88%		2020
Severn Trent Water	BILSTON - LADYMOOR ROAD (CSO)	T/08/07863/O	Single Discharge			41.1	3	99.57%		2020
Severn Trent Water	BILSTON - STOW HEATH LANE (CSO)	T/08/12270/O	Single Discharge			0.0	0	99.90%		
Severn Trent Water	BILSTON - VULCAN ROAD (CSO)	T/08/07832/O	Single Discharge			33.5	23	99.13%		
Severn Trent Water	BINGHAM - COGLEY LANE (SPS)	T/67/40317/O	A1			18.3	2	99.97%		
Severn Trent Water	BIRCHALL AVENUE BAL TANK - STORM of (ABBEYDALE - BIRCHALL AVENUE (CSO))	S/20/12173/O	Single Discharge			0.0	0	100.00%		
Severn Trent Water	Birches Lane PS	T/41/07222/R-2	Single Discharge			8.1	2	99.88%		2020
Severn Trent Water	BIRMINGHAM - CORPORATION STREET (CSO)	T/09/30263/O	Single Discharge			1.7	7	100.00%		
Severn Trent Water	BIRMINGHAM - LANCASTER ST/VESEY ST (CSO)	T/09/21166/O	Single Discharge			0.0	1	99.90%		
Severn Trent Water	BIRMINGHAM - LIONEL STREET (CSO)	T/09/30127/O	Single Discharge			4.0	13	100.00%		
Severn Trent Water	BIRMINGHAM - PERSHORE STREET (SO)	No known permit reference	Single Discharge			3.0	4	99.73%		2020
Severn Trent Water	BIRMINGHAM - STEELHOUSE LANE (CSO)	T/09/21162/O	Single Discharge			0.0	0	99.98%		
Severn Trent Water	BIRMINGHAM - WATER STREET (CSO)	T/09/02828/O	Single Discharge			0.0	0	99.98%		
Severn Trent Water	BIRMINGHAM- RAY HALL (SST)	WQD010064	Single Discharge			17.8	4	99.78%		
Severn Trent Water	BISHAMPTON (STW)	S/17/25865/R	A2			0.2	1	100.00%		2020
Severn Trent Water	Bishops Asbury Crescent CSO	No known permit reference	A1			3.7	5	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	BLABY - AUBURN ROAD (CSO)	2171V-6	Single Discharge			65.9	19	99.99%		
Severn Trent Water	BLABY - SYCAMORE STREET (CSO)	T/50/02171/O	Single Discharge			11.7	6	99.99%		
Severn Trent Water	BLACK HEATH - STATION ROAD TANKS (CSO)	T/08/36012/O	Single Discharge			24.8	6	99.99%		
Severn Trent Water	BLACKFORDBY VILLAGE (CSO)	T/23/09108/O	Single Discharge			440.5	64	95.75%		
Severn Trent Water	BLACKMINSTER (STW)	S/16/26290/R	A2			216.7	13	100.00%		2020
Severn Trent Water	BLACKWELL - GLOVES LANE (TPS)	T/41/09272/O	A1			12.8	5	99.52%		2020
Severn Trent Water	BLAKENEY (STW)	S/20/26262/R	A2			653.5	79	99.94%		2020
Severn Trent Water	BLIDWORTH - DALE LA/LYNDHURST AVE (CSO)	T/64/46424/OG	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	BLIDWORTH - DALE LA/PETROL STATION (CSO)	T/64/46423/OG	Single Discharge			385.5	19	99.98%		2020
Severn Trent Water	BLIDWORTH - DALE LANE/PARK AVENUE (CSO)	T/64/46425/OG	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	BLIDWORTH - DALE LN\BAULKER LN (SPS)	T/64/46422/OG	Single Discharge			10.4	7	99.40%		2020
Severn Trent Water	BLOCKLEY (STW)	S/14/25492/R	A2			3330.1	212	100.00%		2020
Severn Trent Water	BLOXWICH - GREEN LA/BEATRICE ST (CSO)	T/08/35259/O	Single Discharge			6.2	7	99.99%		
Severn Trent Water	BLOXWICH - LEAMORE LANE (CSO)	T/08/35943/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	BLOXWICH - SNEYD LANE (CSO)	TSC1775	Single Discharge			43.8	17	99.98%		
Severn Trent Water	BLYMHILL LAWN PUMPING STATION (BLYMHILL LAWNS - BROCKHURST LANE (SPS))	S/04/03096/O	A1			0.0	0	100.00%		
Severn Trent Water	BLYTH - BAWTRY ROAD (SPS)	T/77/40271/O	A1			4.0	3	99.46%		2020
Severn Trent Water	BLYTH NORNAY - BAWTRY ROAD (SPS)	T/76/08830/O	A1			0.0	0	100.00%		2020
Severn Trent Water	BLYTHE BRIDGE - STALLINGTON ROAD (CSO)	T/06/30058/O	Single Discharge			3.5	6	90.83%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BLYTON - HIGH ST PS (BLACK HORSE) (CSO)	T/79/02149/O	A1			10.2	4	99.98%		2020
Severn Trent Water	BOBBINGTON (STW)	S/05/56191/R	A2			737.8	43	99.99%		2020
Severn Trent Water	Bodmin Rise CSO	No known permit reference	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	BOMERE HEATH Sewage Treatment Works (BOMERE HEATH (Sewage Treatment Works))	S/02/55802/R	A2			1545.3	85	95.33%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BONSALL - CLATTERWAY/BLACK TOR RD (CSO)	DT/2187	Single Discharge			51.9	11	92.61%		2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	BONSALL - THE CROSS (CSO)	DT/2185	Single Discharge			0.0	0	95.03%		
Severn Trent Water	BONSALL - YEOMAN STREET (CSO)	DT/2186	Single Discharge			0.0	0	95.42%		
Severn Trent Water	BOOTHEN - BOOTHEN OLD RD 2 (CSO)	T/01/30276/O	Single Discharge			6.9	10	82.51%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BOOTHEN - BOOTHEN OLD ROAD 1 (CSO)	T/01/20465/O	Single Discharge			7.3	10	99.91%		
Severn Trent Water	BOOTHEN - SIDEWAY ONE (MICHELIN) (CSO)	T/01/21323/O	Single Discharge			2.4	3	99.98%		
Severn Trent Water	BORDESLEY - FAZELEY STREET (CSO)	DT/9818	Single Discharge			30.5	20	99.98%		2020
Severn Trent Water	BORDESLEY - LAWDEN ROAD (CSO)	TSC1078	Single Discharge			5.5	12	99.00%		2020
Severn Trent Water	BORDESLEY - MONTAGUE STREET (CSO)	DT/9828	Single Discharge			26.2	14	99.95%		
Severn Trent Water	BORDESLEY - MONTAGUE STREET 2 (CSO)	TSC1312	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	BORDESLEY GREEN - FORDROUGH LA 142 (CSO)	T/10/22687/O	Single Discharge			92.8	30	99.97%		
Severn Trent Water	BORDESLEY STREET CSO (BIRMINGHAM - BORDESLEY STREET (CSO))	T/09/36424/O	Single Discharge			2.2	6	99.95%		
Severn Trent Water	BORROWASH - BYPASS (CSO)	T/48/02741/O	Single Discharge			18.5	16	69.84%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BORROWASH - HAWTHORNE AVE (CSO)	T/48/22355/O	Single Discharge			3.5	2	87.80%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BOTTESFORD (STW)	T/65/45553/R	A2			292.4	74	99.93%		2020
Severn Trent Water	BOUGHTON (STW)	T/72/45594/R	A2			59.0	10	100.00%		2020
Severn Trent Water	BRADELEY - CHELL HEATH ROAD (CSO)	T/01/35689/O	Single Discharge			0.0	0	100.00%		
Severn Trent Water	BRADWELL - THE CRESCENT 23 (CSO)	T/38/21458/O	Single Discharge			1.3	6	100.00%		
Severn Trent Water	BRADWELL (STW)	T/38/46039/R	A2			1197.8	80	99.86%		2020
Severn Trent Water	BRAILSFORD STW STORM OVERFLOW (BRAILSFORD - STW (CSO))	T/34/21308/O	A2			34.8	23	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BRAITHWELL (STW)	T/83/45636/R	A2			30.5	14	99.98%		2020
Severn Trent Water	BRAMCOTE - DERBY ROAD (CSO)	T/63/45111/O	Single Discharge			1.0	5	99.92%		
Severn Trent Water	BRANCOTE (STW)	T/04/36032/R	A2			423.8	28	100.00%		2020
Severn Trent Water	BRANTON (STW)	T/83/45823/R	A2			12.8	6	99.99%		2020
Severn Trent Water	BRAUNSTON (STW)	S/12/26147/R	A2			500.2	66	100.00%		2020
Severn Trent Water	BRAUNSTONE - KINGSWAY 10 (CSO)	T/52/21090/O	Single Discharge			0.0	0	100.00%		
Severn Trent Water	BREASTON - MARLBOROUGH ROAD (CSO)	T/49/02839/O	A1			3.4	3	99.77%		
Severn Trent Water	BREASTON - SOUTH OF CHURCH (CSO)	T/61/03514/O-1	Single Discharge			2.2	2	99.99%		
Severn Trent Water	BREASTON - WILSTHORPE ROAD (SPS)	T/61/40169/O	A1			104.6	12	94.15%		
Severn Trent Water	BREDON - MORETONS LANE (CSO)	S/17/23232/O	Single Discharge			14.2	5	98.56%		
Severn Trent Water	BREEDON CROSS - CHARLOTTE ROAD (CSO)	T/09/21290/O	Single Discharge			0.3	1	93.56%		
Severn Trent Water	BREWOOD - FOUR ASHES ROAD (SPS)	T/03/12149/O & T/03/00310/O	Single Discharge			73.8	59	100.00%		
Severn Trent Water	BRICK KILN LANE STORM OVERFLOW (GORNAL WOOD - BRICK KILN LANE (CSO))	S/06/21303/O	Single Discharge			96.0	45	99.94%		
Severn Trent Water	BRIDGE PIECE DETENTION TANK (NORTHFIELD - BRIDGE PIECE (SST))	T/09/36303/O	Single Discharge			0.0	0	100.00%		
Severn Trent Water	BRIDGE ST/FIELD LN JUNCTION (BELPER - BRIDGE STREET/FIELD LANE (CSO))	T/42/21278/O	Single Discharge			10.6	27	99.87%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BRIDGE STREET PUMPING STATION SSO (GAINSBOROUGH - BRIDGE STREET (SPS))	T/69/12379/O	Single Discharge			922.2	169	97.26%		
Severn Trent Water	BRIDGNORTH - UNDERHILL STREET (CSO)	S/02/55571/O	Single Discharge			170.9	20	94.74%		
Severn Trent Water	BRIDGNORTH - UNDERHILL STREET (TPS)	S/02/55569/O	A1			248.3	44	99.89%		
Severn Trent Water	BRIDGNORTH - WELLMEADOW (CSO)	S/02/55570/O	Single Discharge			269.6	37	99.87%		
Severn Trent Water	BRIDGNORTH (THE SLADS) Sewage Treatment Works (BRIDGNORTH-SLADS (Sewage Treatment Works))	S/02/56079/R	A2			919.2	77	99.94%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BRIMSCOMBE - CARAVAN SITE (CSO)	S/22/20973/O	Single Discharge			0.3	1	99.99%		
Severn Trent Water	BRINKLOW - COVENTRY ROAD (CSO)	NPSWQD000303	Single Discharge			8.6	13	99.97%		
Severn Trent Water	BRINSLEY- HALL LANE (MEADOW LODGE) (CSO)	T/61/46090/O	Single Discharge			21.2	6	100.00%		2020
Severn Trent Water	BRISTOL ROAD SOUTH SSO (LONGBRIDGE - BRISTOL ROAD SOUTH (CSO))	T/09/36046/O	Single Discharge			34.9	8	98.44%		
Severn Trent Water	BROADHOLME PUMPING STATION (BELPER - BROADHOLM (SPS))	T/42/01142/O-1	A1			29.5	6	99.59%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BROADOAK (STW)	S/20/25648/R	A2			327.0	61	100.00%		2020
Severn Trent Water	BROADWAS - BROAD GREEN (SPS)	S/09/55735/O	A1			57.8	6	99.47%		2020
Severn Trent Water	BROADWAY (STW)	S/16/26056/R	A2			250.6	28	99.52%		2020
Severn Trent Water	BROADWAY ROAD STORM OVERFLOW (WINCHCOMBE - BROADWAY ROAD (CSO))	S/18/20337/O	Single Discharge			0.0	0	100.00%		
Severn Trent Water	BROADWELL - BROADWELL HOUSE (SPS)	S/12/07849/O	A1			72.8	9	100.00%		2020
Severn Trent Water	BROCKHAMPTON (STW)	S/17/26552/R	A2			934.6	50	99.99%		2020
Severn Trent Water	BROCKSFORD STREET (LONGTON - BROCKSFORD ST (CSO))	T/01/35711/O	Single Discharge			0.0	0	99.70%		
Severn Trent Water	BROMFORD - BROMFORD RD/BROMFORD LA (CSO)	T/10/09369/O	Single Discharge			72.0	7	100.00%		2020
Severn Trent Water	BROMSGROVE (STW)	S/07/56027/R	Single Discharge			39.4	12	100.00%		2020
Severn Trent Water	Brook End Repton Ps	T/36/12289/O	Single Discharge			736.2	53	99.86%		2020
Severn Trent Water	BROOK LANE COMBINED STORM OVERFLOW (BILLESLEY - BROOK LANE 515 (CSO))	T/12/36038/O	Single Discharge			0.0	0	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BROOK ROAD CSO (STOURBRIDGE - BROOK ROAD (CSO))	S/06/55435/O	Single Discharge			0.1	1	100.00%		
Severn Trent Water	Brooklands - Swindon (Sps)	S/06/50053/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	BROOKS LANE - STORM/EMERGENCY O/F (WHITWICK - ROBINSON ROAD (CSO))	T/57/08799/O-1	Single Discharge			3.1	3	99.92%		
Severn Trent Water	BROSELEY - DARK LANE (CSO)	S/02/21268/O	Single Discharge			209.2	114	99.98%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	BROUGHTON ASTLEY (STW)	T/50/45321/R	A2			312.0	30	99.88%		2020
Severn Trent Water	BROWN LEES AREA (BIDDULPH - BROWN LEES ROAD (CSO))	T/01/07201/O	Single Discharge			24.8	8	99.91%		
Severn Trent Water	BROWNHILLS - LICHFIELD ROAD (CSO)	T/08/22000/O	Single Discharge			2.9	4	99.99%		2020
Severn Trent Water	BROWNHILLS - LINDON ROAD (CSO)	T/08/30021/O	Single Discharge			3.8	5	93.89%		
Severn Trent Water	BROWNHILLS - SILVER CT GDNS 39 (CSO)	TSC22	Single Discharge			8.0	13	99.99%		
Severn Trent Water	BROWNHILLS - SILVER STREET PS (CSO)	T/08/00463/O	A1			0.0	0	100.00%		2020
Severn Trent Water	BUBBENHALL (STW)	S/10/26091/R	A2			40.4	4	99.88%		2020
Severn Trent Water	BUCKLAND END - CHIPPERFIELD RD 136 (CSO)	T/10/36336/O	Single Discharge			533.6	97	100.00%		
Severn Trent Water	BUCKNALL - DIVIDY RD/JOINERS SQ (CSO)	T/01/35986/O	Single Discharge			57.5	73	99.81%		
Severn Trent Water	BUCKNELL (TPS)	S/09/50094/O	A1			290.0	17	99.86%		2020
Severn Trent Water	BUILDWAS - PARK VIEW (STW)	NPSWQD007895	A2			0.1	1	99.87%		2020
Severn Trent Water	BULKINGTON STW (BULKINGTON - BEDWORTH ROAD (CSO))	T/19/01498/O-2	Single Discharge			0.0	0	100.00%		
Severn Trent Water	BULWELL - MAIN ST/RAVENSWORTH RD (CSO)	T/63/40037/O	Single Discharge			0.0	0	99.88%		2020
Severn Trent Water	BULWELL - MAIN STREET/CAREY ROAD (CSO)	T/63/40225/O	Single Discharge			1.0	4	100.00%		2020
Severn Trent Water	BULWELL - ST ANDREWS CLOSE 33 (CSO)	T/63/22902/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	BURBAGE - BANKY MEADOW (CSO)	T/50/12279/O	Single Discharge			1.8	2	99.80%		
Severn Trent Water	BURBAGE - BULLFURLONG LANE (CSO)	T/50/45424/O	Single Discharge			4.3	14	99.45%		
Severn Trent Water	BURBAGE - LYCHGATE LANE (SPS)	T/50/09330/O	A1			2.4	3	100.00%		2020
Severn Trent Water	BURBAGE - LYCHGATE LANE 2 CSO	No known permit reference	Single Discharge			0.5	2	95.54%		2020
Severn Trent Water	BURBAGE - SAPCOTE ROAD (CSO)	T/50/40061/O	Single Discharge			55.5	26	97.14%		2020
Severn Trent Water	BURFORD VILLAGE Sewer & SPS (Burford - Swan Hotel PS)	S/09/05176/O	A1			30.9	4	100.00%		
Severn Trent Water	BURNHILL GREEN SEWAGE TREAT WORKS (BURNHILL GREEN (Sewage Treatment Works))	S/05/55671/O	A2			13.1	2	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BURNTWOOD (STW)	T/17/35855/R	A2			194.5	30	100.00%		2020
Severn Trent Water	BURTON - SEYMOUR ROAD (SPS)	EPRTP3822XY	A1			3.5	3	99.47%		2020
Severn Trent Water	BURTON END BRIDGE STORM OVERFLOW (MELTON - BURTON ROAD/ANKLE HILL (CSO))	T/55/12384/O	Single Discharge			4.8	2	100.00%		
Severn Trent Water	BURTON JOYCE PS EMERGENCY OVERFLOW (BURTON JOYCE - TRENT LANE (TPS))	T/64/01299/O	A1			1107.0	93	100.00%		
Severn Trent Water	BURTON LAZARS (STW)	T/54/45615/R	A2			156.8	56	100.00%		2020
Severn Trent Water	BURTON ON THE WOLDS STW - EMER O/F (Burton-on-the-Wolds STW PS)	T/57/03391/O	A1			244.2	54	99.98%		
Severn Trent Water	BURTON ON THE WOLDS WWTW (BURTON ON THE WOLDS (Sewage Treatment Works))	T/57/45802/R	A2			59.8	19	98.88%		
Severn Trent Water	BURTON ON TRENT_COTON PARK SEWAGE TREATMENT WORKS	T/24/35915/R	A1&A2			72.3	67	92.49%		
Severn Trent Water	BURTON STATHER (STW)	T/84/45914/R	A2			64.0	17	100.00%		2020
Severn Trent Water	BURTON STATHER (STW)	T/84/45914/R	A3			0.7	2	100.00%		2020
Severn Trent Water	BURTON UPON TRENT - FERRY ST 1 (CSO)	T/24/21254/O	Single Discharge			201.9	31	99.80%		
Severn Trent Water	BURTON UPON TRENT - FERRY STREET (CSO)	T/24/35718/O	Single Discharge			0.9	5	95.83%		
Severn Trent Water	BURTON UPON TRENT - MAYFIELD ROAD (CSO)	T/24/30266/O	Single Discharge			61.9	37	99.79%		
Severn Trent Water	BURTON UPON TRENT - WHEATLEY LANE (CSO)	T/24/30267/O	Single Discharge			240.5	82	96.73%		
Severn Trent Water	BUSSAGE - TOADSMOOR ROAD (CSO)	S/22/25173/O	Single Discharge			0.0	0	92.34%		
Severn Trent Water	Butterwick Rd Messingham PS	T/81/46220/O	A1			48.8	19	99.65%		
Severn Trent Water	BUXTON - PAVILION GARDENS (CSO)	T/39/12333/O	Single Discharge			0.0	0	99.15%		2020
Severn Trent Water	BUXTON - THE SQUARE (SO)	No known permit reference	Single Discharge			0.5	1	100.00%		2020
Severn Trent Water	BUXTON (STW)	T/39/45680/R	A3			33.3	15	100.00%		2020
Severn Trent Water	CAKEMORE ROAD TANK Sewer SSO (BLACKHEATH - CAKEMORE ROAD (CSO))	T/08/36011/O	Single Discharge			0.2	1	100.00%		
Severn Trent Water	CALCOTT PUMPING STATION (SPS) (BICTON - CALCOTT LANE (SPS))	S/02/55421/O	A1			170.0	20	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	CALLOW END - LOWER FERRY LANE (CSO)	A300	Single Discharge			767.7	50	99.99%		
Severn Trent Water	CALTHORPE FIELDS (EDGBASTON - FREDERICK RD 2 (CSO))	T/09/35020/O	Single Discharge			0.7	3	99.99%		
Severn Trent Water	CALTHORPE FIELDS STORM OVERFLOW (EDGBASTON - GEORGE ROAD (CSO))	T/09/35288/O	Single Discharge			0.6	3	99.99%		
Severn Trent Water	CALTHORPE RD/ST JAMES RD JCN SSO (EDGBASTON - CALTHORPE RD (CSO))	T/09/35019/O	Single Discharge			0.7	3	99.98%		
Severn Trent Water	Calthorpe Road/Harborne Road, Edgbaston	No known permit reference	Single Discharge			0.5	2	100.00%		2020
Severn Trent Water	CALVER - SHEFFIELD ROAD (CSO)	671-3	Single Discharge			58.0	14	99.93%		
Severn Trent Water	CALVERTON Sewage Treatment Works (CALVERTON (Sewage Treatment Works))	T/64/45588/R	A2			830.4	63	99.98%		
Severn Trent Water	CAM - DRAYCOTT (CSO)	S/20/06015/O	Single Discharge			538.4	80	99.99%		2020
Severn Trent Water	Camp Hill, Brierley Hill	No known permit reference	Single Discharge			0.0	0	99.87%		2020
Severn Trent Water	Campbell Road	No known permit reference	Single Discharge			1.3	3	99.85%		2020
Severn Trent Water	CANLEY (CANLEY - OLD MILL LANE (CSO))	S/11/04668/R	Single Discharge			14.4	8	100.00%		
Severn Trent Water	CANNOCK - DEVON ROAD/SURREY CLOSE (CSO)	T/03/21298/O	Single Discharge			1.0	3	99.60%		
Severn Trent Water	CANNOCK - WELLINGTON DRIVE (SPS)	T/03/30249/O	A1			0.0	0	99.79%		
Severn Trent Water	CANNOCK ROAD SEWAGE PUMPING STATION (HEATH HAYES - CANNOCK ROAD (SPS))	T/03/35891/O	A1			34.3	12	97.25%		
Severn Trent Water	CANNOCK SEWAGE TREATEMENT WORKS (CANNOCK (Sewage Treatment Works))	T/03/36222/R	A2			112.0	19	99.89%		
Severn Trent Water	CARADOC VIEW PUMPING STATION (HANWOOD - CARADOC VIEW (SPS))	S/02/55420/O	A1			145.4	24	99.93%		
Severn Trent Water	CARLTON IN LINDRICK - WATER LANE (SPS)	T/76/01281/O	A1			6.4	4	100.00%		2020
Severn Trent Water	CARLTON-ON-TRENT - MAIN STREET (TPS)	TSC3286	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	CAROL GREEN - HODGETTS LANE (SPS)	T/11/35957/O	A1			38.5	4	100.00%		2020
Severn Trent Water	CASTLE DONINGTON - STATION ROAD (CSO)	T/36/22695/O	Single Discharge			11.0	13	99.88%		2020
Severn Trent Water	CASTLE DONNINGTON (STW)	T/36/45984/S	A1			24.1	6	99.99%		2020
Severn Trent Water	CASTLE GRESLEY_BURTON RD (BONAS) SPS	T/24/21773/O	A1			0.9	2	93.47%		
Severn Trent Water	CASTLE ORCHARD PUMPING STATION (DUFFIELD - CASTLE ORCHARD PS (CSO))	T/42/40222/O	A1			0.4	2	99.86%		
Severn Trent Water	CASTLE VALE - FARNBOROUGH RD 2 (SPS)	T/10/22951/O	Single Discharge			0.4	1	100.00%		2020
Severn Trent Water	CASTLE VALE - KINGSBURY ROAD (CSO)	3178/1	Single Discharge			0.0	0	99.99%		
Severn Trent Water	CASTLETON - OLD SEWAGE WORKS (CSO)	T/38/07611/O	Single Discharge			22.8	6	100.00%		2020
Severn Trent Water	CATTHORPE (SPS)	S/10/25578/O	A1			19.7	4	100.00%		2020
Severn Trent Water	CAUDLEWELL PUMPING STATION (SHIPSTON-ON-STOUR - CAUDLE WELL (TPS))	S/14/23238/O	A1			59.0	9	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	CHADDESDEN PARK RD/MAYFIELD RD SSO (CHADDESDEN - CHADDESDEN PARK ROAD (CSO))	C486	Single Discharge			11.4	2	100.00%		
Severn Trent Water	CHADDESLEY CORBETT (WTW)	S/07/55368/T	A2			6.4	5	100.00%		2020
Severn Trent Water	CHADWELL - MANOR FARM (TPS)	T/54/12319/O	Single Discharge			15.9	2	100.00%		2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	CHAPEL ASH/LOVATT STREET JCN SSO (WOLVERHAMPTON - CHAPEL ASH 2 (CSO))	S/06/50126/O	Single Discharge			1.1	3	99.72%		
Severn Trent Water	CHAPLIN ROAD NO.1 CSO (DRESDEN - BELGRAVE RD/CHAPLIN RD (CSO))	T/01/22807/O	Single Discharge			2.2	9	91.34%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	CHAPLIN ROAD NO.2 CSO (DRESDEN - CHAPLIN RD (CSO))	T/01/35787/O	Single Discharge			0.0	1	99.91%		
Severn Trent Water	CHARLTON KINGS - DOWDSWELL STORM (CSO)	S/20/23189/O	Single Discharge			318.1	75	99.98%		
Severn Trent Water	CHASETOWN - TRIANGLE (TPS)	T/17/12355/O	A1			52.4	17	100.00%		2020
Severn Trent Water	CHEADLE - BEDBROOK FARM (SPS)	TSC3084	A1			2.4	2	99.94%		2020
Severn Trent Water	CHEADLE - TEAN ROAD (CSO)	T/32/30318/O	Single Discharge			22.9	14	99.95%		
Severn Trent Water	CHEAPSIDE COMBINED SEWAGE OVERFLOW (DIGBETH - CHEAPSIDE (CSO))	T/09/36117/O	Single Discharge			0.0	0	99.91%		
Severn Trent Water	CHECKLEY (STW)	T/32/36105/R	A2			8.2	13	100.00%		2020
Severn Trent Water	CHEDDLETON (STW)	T/30/35983/R	A2			163.8	13	100.00%		2020
Severn Trent Water	CHEDDLETON HEATH - SPICERSTONE (CSO)	T/30/22306/O	Single Discharge			21.2	30	99.98%		
Severn Trent Water	CHELTENHAM - ARLE SWO (CSO)	S/20/25068/O	Single Discharge			63.5	22	100.00%		2020
Severn Trent Water	CHELTENHAM - MARSH GARDENS (SPS)	TSC3637	A1			0.0	0	100.00%		2020
Severn Trent Water	CHERINGTON (STW)	S/14/26294/R	A2			1232.6	80	100.00%		2020
Severn Trent Water	CHERRY ORCHARD PUMPING STATION (PERSHORE - CHERRY ORCHARD (SPS))	S/17/25685/O	A1			1465.2	74	99.98%		
Severn Trent Water	Chestall Farm PS	TSC3227	Single Discharge			9.7	11	99.86%		2020
Severn Trent Water	CHESTER ROAD STORM OVERFLOW (CRADLEY HEATH - CRADLEY ROAD 2 (CSO))	S/06/21066/O	Single Discharge			144.9	50	99.89%		
Severn Trent Water	CHESWARDINE (STW)	S/04/55997/R	A2			27.4	14	100.00%		2020
Severn Trent Water	CHILCOTE RBC (STW)	T/23/36154/R	A2			153.1	33	94.34%		2020
Severn Trent Water	CHIPPING CAMPDEN (STW)	S/14/25988/R	A2			407.0	49	99.98%		2020
Severn Trent Water	CHURCH HILL COMBINED STORM OVERFLOW (NORTHFIELD - CHURCH HILL (CSO))	T/09/36172/O	Single Discharge			0.1	1	91.59%		
Severn Trent Water	CHURCH LANE PS /STM & EMERGENCY of (OSGATHORPE - CHURCH LANE (SPS))	T/57/07182/O	A1			89.5	10	98.42%		
Severn Trent Water	CHURCH LAWFORD (STW)	S/10/25784/R	A2			22.8	17	100.00%		2020
Severn Trent Water	CHURCH ST/GREGORY ST STORM OVERLFOW (OLD LENTON - CHURCH STREET (CSO))	T/64/21886/O	Single Discharge			5.0	4	99.80%		
Severn Trent Water	Church Street	No known permit reference	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	Church street	No known permit reference	Single Discharge			0.0	0	96.88%		2020
Severn Trent Water	CHURCH STREET PUMPING STATION (TENBURY - CHURCH STREET (SPS))	S/09/55022/O	A1			582.9	33	99.99%		
Severn Trent Water	CHURCH STRETTON (STW)	S/09/55956/R	A1			2030.1	86	99.95%		2020
Severn Trent Water	CHURCH WALK, BIRCOTES	T/83/45133/O	A1			59.6	12	99.93%		2020
Severn Trent Water	CHURCH WARSOP - EASTLANDS LANE (CSO)	T/71/40115/O	Single Discharge			34.8	8	96.71%		
Severn Trent Water	CHURCH WARSOP (STW)	T/71/45571/R	A2			199.0	33	100.00%		2020
Severn Trent Water	Church Westbury-on-Severn CSO	TSC502	Single Discharge			378.2	52	98.30%		
Severn Trent Water	CHURCHAM (STW)	S/20/25769/R	A2			11.8	5	100.00%		2020
Severn Trent Water	CHURCHOVER (STW)	S/10/25817/R	A2			0.4	3	99.94%		2020
Severn Trent Water	CINDERFORD - CRUMPMEADOW (STW)	S/20/25975/R	A2			309.0	29	100.00%		2020
Severn Trent Water	CINDERFORD - GREENWAY ROAD (CSO)	S/20/26201/O	Single Discharge			8.2	9	99.98%		
Severn Trent Water	CLARENCE ST/LOVATT ST JUNCTION SSO (WOLVERHAMPTON - CHAPEL ASH 1 (CSO))	S/06/50095/O	Single Discharge			1.0	3	99.86%		
Severn Trent Water	CLAVERDON - CHURCH ROAD (SPS)	TSC3240	A1			1.9	4	100.00%		2020
Severn Trent Water	CLAVERLEY (STW)	S/05/55897/R	A2			562.7	46	99.94%		2020
Severn Trent Water	CLAY CROSS - BACON SPRINGS (CSO)	T/41/21895/O	Single Discharge			141.5	40	100.00%		2020
Severn Trent Water	CLAY CROSS (STW)	T/41/45710/R	A2			534.6	68	100.00%		2020
Severn Trent Water	CLAYTON - LILLESHALL ROAD (CSO)	T/01/35713/O	Single Discharge			14.4	6	99.99%		
Severn Trent Water	CLAYTON RD SPS STOKE ON TRENT (CLAYTON - CLAYTON ROAD (SPS))	T/01/21896/O	A1			1.4	1	99.01%		
Severn Trent Water	CLEEVE PRIOR - QUARRY LANE (SPS)	S/16/26188/O	A1			263.6	15	100.00%		2020
Severn Trent Water	CLEOBURY MORTIMER (STW)	S/09/55898/R	A2			372.1	33	99.99%		2020
Severn Trent Water	CLIFTON - VILLAGE (SPS)	T/29/01413/O-2	A1			40.4	12	100.00%		2020
Severn Trent Water	CLIFTON - WATERY LANE/GREEN LANE (SO)	No known permit reference	Single Discharge			118.8	10	100.00%		2020
Severn Trent Water	CLOWNE (STW)	T/73/45819/R	A3			0.9	5	100.00%		2020
Severn Trent Water	CLOWNE WASTEWATER TREATMENT WORKS (CLOWNE (Sewage Treatment Works))	T/73/45819/R	A2			2.0	15	99.97%		
Severn Trent Water	CLUN (Sewage Treatment Works)	S/09/55822/O	A2			1341.5	60	99.72%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	COALEY (STW)	S/20/26180/R	A2			445.9	41	99.94%		2020
Severn Trent Water	COALPOOL - WHATELEY ROAD (CSO)	DT/8403	Single Discharge			1.8	1	99.95%		
Severn Trent Water	COALPORT (STW)	S/02/56070/R	A3			32.1	10	100.00%		2020
Severn Trent Water	COALVILLE - CENTRAL ROAD (CSO)	T/20/12374/O-3	Single Discharge			19.5	18	94.04%		
Severn Trent Water	COALVILLE - FOREST ROAD (CSO)	T/20/12374/O	Single Discharge			7.6	10	99.99%		
Severn Trent Water	COALVILLE - HERMITAGE ROAD (CSO)	T/57/09234/O-2	Single Discharge			2.4	2	99.98%		
Severn Trent Water	COALVILLE - LONDON ROAD (CSO)	T/20/12234/O	Single Discharge			104.4	44	100.00%		2020
Severn Trent Water	COALVILLE - MEADOW LANE (CSO)	T/57/09031/O	Single Discharge			2.0	2	100.00%		2020
Severn Trent Water	COALVILLE - THORNBOROUGH ROAD (CSO)	T/57/09234/O-1	Single Discharge			0.8	1	100.00%		2020
Severn Trent Water	COCKS MOORS WOODS GOLF COURSE SSO (KINGS HEATH - COCKS MOORS LEIS CEN (CSO))	T/12/26865/O	Single Discharge			35.9	15	99.80%		
Severn Trent Water	CODNOR - GLASSHOUSE HILL 81 (CSO)	T/61/46414/O	Single Discharge			0.0	0	94.91%		2020
Severn Trent Water	CODNOR - HOLBORN VIEW 24 (CSO)	T/61/03673/O-2	Single Discharge			0.5	1	100.00%		2020
Severn Trent Water	CODNOR - JESSOP STREET 2 (CSO)	T/61/21512/O	Single Discharge			0.0	0	99.99%		2020
Severn Trent Water	CODNOR - NOTTINGHAM ROAD (CSO)	T/61/21524/O	Single Discharge			0.0	0	99.98%		2020
Severn Trent Water	CODNOR - NOTTINGHAM ROAD (IN FIELD) (CSO)	T/61/45717/O	Single Discharge			0.7	1	99.88%		2020
Severn Trent Water	CODSALL SEWAGE TREATMENT WORKS (CODSALL (Sewage Treatment Works))	T/03/35861/R	A2			469.4	54	99.97%		
Severn Trent Water	COLDBATH VALLEY (WAKE GREEN - YARDLEY WOOD ROAD (CSO))	T/12/02757/O	Single Discharge			674.5	53	99.92%		
Severn Trent Water	COLE AVENUE STORM OVERFLOW (TUFFLEY - COLE AV/PODSMEAD RD (CSO))	S/20/23082/O	Single Discharge			0.0	0	99.96%		
Severn Trent Water	COLERIDGE DRIVE SPS (PERTON - COLERIDGE DRIVE (SPS))	T/03/35150/O	A1			8.3	2	99.95%		
Severn Trent Water	COLESHILL - COLE END (SPS)	T/12/02492/O	A1			195.1	21	100.00%		
Severn Trent Water	COLESHILL - OLD MILL ROAD 54 (CSO)	T/12/36069/O	Single Discharge			54.6	13	99.98%		2020
Severn Trent Water	COLESHILL WASTEWATER TREATMENT WRKS (COLESHILL (Sewage Treatment Works))	T/12/36068/R	A2			3034.8	157	99.99%		
Severn Trent Water	COLLINGHAM (STW)	T/69/45554/R	A2			17.6	7	100.00%		2020
Severn Trent Water	Colwall Cso	S/09/20392/O	Single Discharge			398.5	39	98.94%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	Colwick Road/Trent Lane	No known permit reference	Single Discharge			28.3	21	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	Common Rd Evesham PS Cso	S/17/21571/O	A1			0.0	0	92.06%		
Severn Trent Water	COMPTON PARK SSO (COMPTON - PARK (CSO))	S/06/55300/O	Single Discharge			318.1	47	100.00%		
Severn Trent Water	CONDOVER (STW)	S/02/55972/R	A2			3.1	1	100.00%		2020
Severn Trent Water	CONDUIT STREET (LEICESTER - CONDUIT STREET (CSO))	T/53/21315/O	Single Discharge			0.0	0	100.00%		
Severn Trent Water	COOKLEY - CAUNSALL ROAD (SPS)	S/06/12199/O	A1			7.1	13	99.94%		2020
Severn Trent Water	CO-OPERATIVE ST/PROVIDENT ST SSO (NORMANTON - CO-OP ST/PROVIDENT ST (CSO))	T/48/21199/O	Single Discharge			11.9	32	100.00%		
Severn Trent Water	CO-OPERATIVE ST/SOCIETY PLACE (NORMANTON - CO-OP ST/SOCIETY PLACE (CSO))	T/48/21198/O	Single Discharge			1.3	5	99.96%		
Severn Trent Water	COSBY - NARBOROUGH ROAD (CSO)	DT/8044	Single Discharge			0.0	0	99.99%		2020
Severn Trent Water	Cosby Rd Littlethorpe PS	T/50/01009/O	Single Discharge			14.4	3	99.98%		
Severn Trent Water	COSELEY - ANCHOR LANE (CSO)	T/08/08453/O	Single Discharge			38.6	10	99.95%		2020
Severn Trent Water	COSELEY - DOCK MEADOW DRIVE (CSO)	T/08/07832/O-2	Single Discharge			18.7	11	97.97%		2020
Severn Trent Water	COSSALL - ILKESTON JNC (SPS)	T/61/00483/O	A1			47.0	11	99.94%		2020
Severn Trent Water	COTGRAVE - MAIN ROAD (SPS)	T/64/03028/O	A1			3.2	3	99.88%		2020
Severn Trent Water	COTGRAVE (STW)	T/64/45774/R	A2			4.2	4	100.00%		2020
Severn Trent Water	COTON IN THE ELMS - CHURCH ROAD (SPS)	T/23/02473/O	A1			159.8	23	100.00%		2020
Severn Trent Water	Cottage Rake CSO	No known permit reference	Single Discharge			29.1	17	99.93%		2020
Severn Trent Water	COUNTESTHORPE - GWENDOLINE DR PS (CSO)	T/51/02170/O	A1			0.0	0	100.00%		2020
Severn Trent Water	COUNTESTHORPE - ROSEBANK ROAD 90 (CSO)	T/51/02170/O	Single Discharge			1.5	3	99.98%		
Severn Trent Water	COUNTESTHORPE - WESTFIELD AVENUE (CSO)	T/51/40060/O	Single Discharge			58.8	9	99.98%		
Severn Trent Water	COVEN HEATH (STW)	T/03/35959/O	A2			128.6	20	99.99%		2020
Severn Trent Water	COVENTRY - FINHAM (STW)	S/11/26637/R	A2			213.2	21	99.88%		2020
Severn Trent Water	COVENTRY - MEADOW STREET (CSO)	S/11/25660/O	Single Discharge			0.1	3	100.00%		2020
Severn Trent Water	Coxmoor Rd Sutton in Ashfield PS	T/70/45949/R	A1			22.4	4	100.00%		
Severn Trent Water	CRADLEY HEATH - CRADLEY FORGE (CSO)	S/06/04942/R	Single Discharge			72.0	42	99.88%		
Severn Trent Water	CRADLEY ROAD CSO (CRADLEY HEATH - CRADLEY ROAD 1 (CSO))	TSC583	Single Discharge			0.0	0	100.00%		
Severn Trent Water	CRANKLEY POINT (STW)	T/68/45770/R	Single Discharge			51.6	9	100.00%		2020
Severn Trent Water	CRAVEN ARMS - STOKESAY (CSO)	S/09/56277/O	Single Discharge			10.5	9	99.98%		2020
Severn Trent Water	CRESSAGE (SPS)	TSC3278	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	CRESWELL - CHEBSEY DR (MANOR FARM) (SPS)	TSC3279	Single Discharge			0.9	3	99.88%		2020
Severn Trent Water	CRESWELL - CRESWELL GROVE (SPS)	TSC3280	A1			94.1	13	99.99%		2020
Severn Trent Water	CRESWELL SEWAGE PUMPING STATION (CRESWELL CRAGS (SPS))	T/73/45213/O	A1			139.4	34	90.98%		
Severn Trent Water	CRESWELL WASTEWATER TREATMENT WORKS (CRESWELL (Sewage Treatment Works))	T/73/45605/R	A2			680.2	88	99.89%		
Severn Trent Water	Croft ECC Quarry Yard CSO	T/50/03632/O-4	Single Discharge			153.7	19	100.00%		2020
Severn Trent Water	Cromer Road	No known permit reference	Single Discharge			0.3	4	90.33%		2020
Severn Trent Water	Cromer Road/Gresham Avenue	No known permit reference	Single Discharge			0.0	0	97.16%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	CROMFORD - MARKET PLACE (CSO)	T/40/21424/O	Single Discharge			53.7	37	99.99%		2020
Severn Trent Water	CROMFORD MEADOWS - RAILWAY BRIDGE (CSO)	DT/2183	Single Discharge			1.6	3	93.30%		
Severn Trent Water	CROPWELL BISHOP (STW)	T/66/45846/R	A2			133.8	22	99.98%		2020
Severn Trent Water	CROSS HEATH - BRYMBO ROAD (CSO)	T/01/22729/O	Single Discharge			8.9	16	99.99%		
Severn Trent Water	CROSS HEATH - LAXLEY ROAD (CSO)	T/01/36473/O	Single Discharge			7.3	16	90.69%		
Severn Trent Water	CROSS HOUSES Sewage Treatment Works (BROMPTON-CROSS HOUSES (Sewage Treatment Works))	S/02/55905/R	A2			2.7	3	100.00%		
Severn Trent Water	CROSSLEY PS - STORM/EMERGENCY of (Crossley PS)	T/61/20321/O	A1			23.8	15	92.16%		
Severn Trent Water	CROWDECOTE SEWAGE TREATMENT WORKS (CROWDECOTE (Sewage Treatment Works))	T/25/35877/R	A2			0.0	1	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	CROWLE - SCUNTHORPE (STW)	T/84/46212/R	A2			0.0	0	100.00%		2020
Severn Trent Water	CROWLE Sewage Treatment Works (CROWLE - WORCESTER (Sewage Treatment Works))	S/19/25637/R	A2			2624.2	137	100.00%		
Severn Trent Water	CROXTON KERRIAL (STW)	T/65/45650/R	A2			182.9	50	100.00%		2020
Severn Trent Water	CSO AT JUNCTION of SILVERDALE ROAD (ERDINGTON - WOODCOTE ROAD (SO))	T/10/36441/O	Single Discharge			0.1	2	99.61%		
Severn Trent Water	CSO AT MARKET STREET, BAKEWELL (BAKEWELL - MARKET STREET (CSO))	T/39/45883/O	Single Discharge			13.7	7	94.13%		
Severn Trent Water	CSO AT STEADFOLDS LANE (THURCROFT - STEADFOLDS LANE (CSO))	T/76/45854/O	Single Discharge			17.4	11	95.04%		
Severn Trent Water	CSO_WOLDS RESERVOIR (CSO)	T/40/03087/O	Single Discharge			0.0	0	99.88%		2020
Severn Trent Water	CUBLEY (STW)	T/33/35576/R	A2			0.0	0	100.00%		2020
Severn Trent Water	DALE ABBEY (SPS)	T/61/45975/O	A1			10.7	7	99.88%		2020
Severn Trent Water	DALE ROAD/BYRON STREET JCN SSO (NORMANTON - LOWER DALE RD/BYRON ST (CSO))	T/48/21195/O	Single Discharge			0.0	0	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DARLASTON - BENTLEY MILL WAY (CSO)	T/08/30020/O	Single Discharge			60.2	20	99.97%		
Severn Trent Water	DARLASTON - BENTLEY ROAD SOUTH (CSO)	T/08/30115/O	Single Discharge			9.3	4	99.54%		2020
Severn Trent Water	DARLASTON - DARLASTON ROAD (CSO)	T/08/12398/O	Single Discharge			13.6	6	100.00%		2020
Severn Trent Water	DARLASTON - STOWHEATH EAST TANK (CSO)	T/08/22745/O	Single Discharge			12.7	7	97.27%		
Severn Trent Water	DARLASTON - WOLVERHAMPTON STREET (CSO)	T/08/30116/O	Single Discharge			1.7	2	100.00%		2020
Severn Trent Water	DARLEY ABBEY - OLD LANE (CSO)	T/46/07193/O-2	Single Discharge			11.5	25	83.51%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DARLEY ABBEY - OLD LANE 9 (CSO)	T/46/07193/O-1	Single Discharge			2.1	7	83.88%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DARLEY ABBEY/ALLESTREE SW-STM/EMG (ALLESTREE - SITE of ALLESTREE WRW (CSO))	T/46/03716/O-2	Single Discharge			98.6	50	99.95%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	DARLEY BRIDGE - MAIN ROAD/WENSLEES (CSO)	817-5	Single Discharge			789.2	94	90.26%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DARLEY DALE - CHURCH ROAD (CSO)	817/3	Single Discharge			8.8	16	82.84%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DARLEY DALE - DALE RD NTH (CSO)	817-11	Single Discharge			0.6	4	93.52%		
Severn Trent Water	DARLEY DALE - FOUR LANE ENDS (SPS)	817-12	A1			101.0	11	100.00%		
Severn Trent Water	DARLEY DALE - STATION ROAD (CSO)	817/10	Single Discharge			0.3	4	83.37%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DARLEY DALE DALE ROAD NORTH CSO AT SK2712763198	T/40/45723/O	Single Discharge			66.3	18	98.95%		
Severn Trent Water	Darley Dale No11 Sso	817-13	Single Discharge			732.6	101	97.05%		
Severn Trent Water	DARTMOUTH AVENUE,NEWCASTLE-U-L (WESTLANDS - DARTMOUTH AVENUE (CSO))	T/01/21213/O	Single Discharge			30.5	32	99.16%		
Severn Trent Water	Defford Rd Pershore PS	S/17/25722/O	A1			19.6	7	99.99%		
Severn Trent Water	DEFFORD SEWAGE TREATMENT WKS (NEW) (DEFFORD VILLAGE (Sewage Treatment Works))	S/19/25866/R	A2			270.5	47	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DELPH ROAD STORM OVERFLOW (BRIERLEY HILL - DELPH ROAD (CSO))	S/06/22382/O	Single Discharge			1.9	10	99.87%		
Severn Trent Water	DENBY - FLAMSTEAD LANE 8 (CSO)	T/45/02232/O	Single Discharge			196.4	36	99.89%		
Severn Trent Water	Deppers Bridge Harbury PS	S/12/25043/O	Single Discharge			6.7	3	100.00%		2020
Severn Trent Water	DERBY - ABBEY ST/MACKLIN ST (CSO)	T/47/22338/O	Single Discharge			0.3	4	99.90%		
Severn Trent Water	DERBY - ABBEY ST/NEWLAND ST (CSO)	T/47/22580/O	Single Discharge			11.4	9	98.91%		
Severn Trent Water	DERBY - BROADWAY 76 (CSO)	T/46/21203/O	Single Discharge			49.6	44	100.00%		
Severn Trent Water	DERBY - FRIAR GATE/VICTORIA STREET (CSO)	T/48/45157/O	Single Discharge			5.7	3	99.86%		
Severn Trent Water	DERBY - GREAT NORTHERN ROAD (CSO)	T/47/21118/O	Single Discharge			4.2	5	100.00%		
Severn Trent Water	DERBY - GREEN LANE/MACKLIN STREET (CSO)	T/47/20994/O	Single Discharge			4.6	25	86.92%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DERBY - MORLEDGE/THORNTREE LANE (CSO)	WQD003066	Single Discharge			13.1	10	100.00%		
Severn Trent Water	DERBY - ST PETERS ST/EAST STREET (CSO)	T/47/21209/O	Single Discharge			0.0	0	99.95%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DERBY - UTTOXETER NEW RD 1 (CSO)	T/47/22336/O	Single Discharge			0.6	2	99.95%		
Severn Trent Water	DERBY - UTTOXETER OLD RD (CSO)	T/47/22335/O	Single Discharge			1.9	3	99.83%		
Severn Trent Water	Derby Rd Lower Kilburn PS	T/45/40274/O	Single Discharge			819.3	43	99.82%		2020
Severn Trent Water	DERBY ROAD (CSO)	No known permit reference	Single Discharge			0.6	6	99.98%		2020
Severn Trent Water	DERBY ROAD (MILFORD - DERBY ROAD (CSO))	T/42/21098/O	Single Discharge			135.6	93	99.99%		
Severn Trent Water	DERRINGTON (STW)	T/02/36155/R	A2			6.5	4	99.06%		2020
Severn Trent Water	DESFORD ROAD - STORM OVERFLOW (ENDERBY - MILL HILL (SPS))	T/50/02176/O	A1			49.6	4	100.00%		
Severn Trent Water	DIGBETH HIGH STREET CSO (DIGBETH - DIGBETH/UPPER MILL LANE (CSO))	T/09/36065/O	Single Discharge			36.5	54	99.95%		
Severn Trent Water	DIMMINGSDALE Sewage Treatment Works (DIMMINGSDALE (Sewage Treatment Works))	S/06/55681/O	A2			2.7	3	99.94%		
Severn Trent Water	DINGLE ROAD STORM OVERFLOW (STOURBRIDGE - DINGLE ROAD (CSO))	S/06/22135/O	Single Discharge			113.3	33	98.04%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DINNINGTON (STW)	T/75/46295/R	A1			533.1	37	99.42%		2020
Severn Trent Water	DINNINGTON (STW)	T/75/46295/R	A3			210.8	17	100.00%		2020
Severn Trent Water	DONISTHORPE (STW)	T/23/08420/R	A2			345.3	40	99.81%		2020
Severn Trent Water	Donisthorpe Rd Moira PS	T/23/01426/O	A1			0.0	0	100.00%		2020
Severn Trent Water	DONNINGTON - SCHOOL ROAD (CSO)	S/04/20914/O	Single Discharge			10.9	20	99.98%		
Severn Trent Water	DORRIDGE - GRANGE ROAD/MANOR RD (CSO)	T/11/00523/O	Single Discharge			1.2	3	99.93%		
Severn Trent Water	DORRIDGE - NORTON GREEN LANE (WRPS)	T/11/35890/O	A1			181.4	21	100.00%		2020
Severn Trent Water	DORRINGTON (STW)	S/02/55348/R	A2			208.9	78	100.00%		2020
Severn Trent Water	DORSINGTON Sewage Treatment Works (DORSINGTON (Sewage Treatment Works))	S/13/26040/R	A2			243.3	53	100.00%		
Severn Trent Water	DOSELEY - HOLYWELL LANE (SPS)	S/02/55806/O	Single Discharge			155.8	25	99.24%		2020
Severn Trent Water	DOSTHILL - HIGH STREET (CSO)	T/16/35997/O	Single Discharge			0.1	3	98.39%		
Severn Trent Water	DOSTHILL - TAMWORTH ROAD (SPS)	T/16/36398/O	A1			54.2	16	99.94%		
Severn Trent Water	DOVERIDGE PUMPING STATION (DOVERIDGE (SPS))	EPREP3320GQ	Single Discharge			460.3	23	97.90%		
Severn Trent Water	DOWNTON COURT	No known permit reference	Single Discharge			0.0	0	99.93%		2020
Severn Trent Water	DRAKELOW - SLADD LANE (WORCS) (SPS)	S/06/12681/O	A1			0.0	0	100.00%		2020
Severn Trent Water	DRAYCOTT - SAWLEY ROAD (SPS)	T/48/12102/O	Single Discharge			26.6	9	100.00%		2020
Severn Trent Water	DRAYTON BASSETT - SALTS LANE (SPS)	T/16/12882/O	Single Discharge			21.5	5	100.00%		2020
Severn Trent Water	DRENEWYDD - OSWESTRY (STW)	S/03/56061/R	A2			60.4	4	100.00%		2020
Severn Trent Water	DRESDEN - CARLISLE ST/RUSSELL ST (CSO)	T/01/36459/O	Single Discharge			12.5	38	94.35%		
Severn Trent Water	Dudding Road	No known permit reference	Single Discharge			0.0	0	96.73%		2020
Severn Trent Water	DUDLEY - ST JAMES ROAD (CSO)	T/08/35766/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	DUFFIELD - TOWN STREET (CSO)	T/44/07229/O	Single Discharge			168.6	49	87.04%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DUNCHURCH (STW)	S/12/26162/R	A2			428.3	30	100.00%		2020
Severn Trent Water	DUNKIRK - LENTON LANE/FINCH CLOSE (SPS)	T/63/08812/O	Single Discharge			24.6	25	92.89%		2020
Severn Trent Water	DUNSTALL HILL - COXWELL AVENUE (CSO)	S/06/56045/O	Single Discharge			2.5	4	99.98%		
Severn Trent Water	DUNSTON A449 TERMINAL PUMPING STN (DUNSTON - A449 (TPS))	T/03/02843/O	A1			1782.6	76	100.00%		
Severn Trent Water	DURHAM AVE/SUFFOLK AVE JCN SSO (CHADDESDEN - DURHAM AVE (CSO))	T/48/22377/O	Single Discharge			6.4	16	99.97%		
Severn Trent Water	Durham Street/Wiltshire Road	No known permit reference	Single Discharge			1.1	2	99.82%		2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	DURSLEY - LISTERS CAR PARK (CSO)	S/20/26173/O	Single Discharge			19.2	12	99.98%		
Severn Trent Water	DYMOCK (STW)	S/21/26719/R	A2			32.0	7	100.00%		2020
Severn Trent Water	EARL SHILTON (STW)	T/50/45319/R	A2			23.9	6	100.00%		2020
Severn Trent Water	EARL SHILTON (STW)	T/50/45319/R	A3			3.3	5	100.00%		2020
Severn Trent Water	EASENHALL - RUGBY ROAD (SPS)	S/10/12219/O	A1			0.0	0	100.00%		2020
Severn Trent Water	EAST BRIDGFORD - SPRINGDALE LANE (SPS)	T/67/40161/O	A1			92.0	17	99.98%		2020
Severn Trent Water	EAST BUTTERWICK - CHAPEL LANE (TPS)	T/82/12009/R-2	A1			0.0	0	99.94%		2020
Severn Trent Water	EAST LEAKE - GOTHAM ROAD (TPS)	T/58/45986/O	Single Discharge			347.9	34	99.98%		
Severn Trent Water	EAST LEAKE - GOTHAM ROAD (TPS)	No known permit reference	Single Discharge			29.0	12	100.00%		2020
Severn Trent Water	EAST LEAKE (STW)	T/58/45986/R	A2			715.2	58	99.88%		2020
Severn Trent Water	EAST MARKHAM (STW)	T/69/45785/R	A2			0.0	0	100.00%		2020
Severn Trent Water	EASTERN GREEN - UNICORN LANE (CSO)	S/11/05068/O	Single Discharge			0.0	1	100.00%		2020
Severn Trent Water	EASTERN MAIN RELIEF Sewer - Storm (Eastern Main Relief Sewer Sso)	T/53/00442/O	A1			144.7	42	95.89%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	EASTON AVENUE/NETHERSTOWE LANE (LICHFIELD - EASTERN AVENUE 1 (CSO))	T/07/36393/O	Single Discharge			0.0	0	97.71%		
Severn Trent Water	EASTWOOD - CHURCH STREET 118 (CSO)	T/61/45051/O	Single Discharge			4.9	4	100.00%		2020
Severn Trent Water	EASTWOOD - MANSFIELD ROAD (CSO)	T/61/02559/O-2	Single Discharge			7.7	10	100.00%		2020
Severn Trent Water	EATON - DISTRICT (SPS)	T/65/40325/O	A1			723.2	36	99.93%		2020
Severn Trent Water	ECCLESHALL AND STURBRIDGE (STW)	T/02/35657/R	A2			1249.3	65	100.00%		2020
Severn Trent Water	ECKINGTON PUMPING STATION (ECKINGTON - MILL LANE (SPS))	S/17/26702/O	Single Discharge			107.5	13	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	EDALE (STW)	T/38/45929/R	A2			746.0	84	99.75%		2020
Severn Trent Water	EDGBASTON - FREDERICK ROAD (CSO)	T/09/35289/O	Single Discharge			2.1	6	99.99%		
Severn Trent Water	EDGMOND (STW)	S/04/56016/R	A2			460.1	32	99.99%		2020
Severn Trent Water	EDINGLEY - STATION ROAD (SPS)	TSC3920	A1			74.6	11	99.91%		2020
Severn Trent Water	EDWINSTOWE - BOY LANE (SSO)	T/70/03120/O-2	Single Discharge			5.1	2	99.99%		
Severn Trent Water	EDWINSTOWE - FOURTH AVENUE (CSO)	T/70/07146/O	Single Discharge			36.1	30	99.98%		
Severn Trent Water	EDWINSTOWE (STW)	T/70/45573/R	A2			75.6	13	99.99%		2020
Severn Trent Water	EJECTOR STATION AT APEDALE (Apedale Rd N-U-Lyme Ps)	T/01/01887/O	A1			0.0	0	99.83%		
Severn Trent Water	ELFORD WASTEWATER TREATMENT WORKS (ELFORD (Sewage Treatment Works))	T/22/35591/R	A2			576.4	94	100.00%		
Severn Trent Water	ELLERDINE (STW)	S/04/55874/O	A2			0.1	1	100.00%		2020
Severn Trent Water	ELLESMERE - OSWESTRY RD/BEECH DR (CSO)	S/03/50085/O	Single Discharge			82.4	47	99.98%		
Severn Trent Water	ELLWOOD - HOLLY LANE (SPS)	S/20/26859/O	A1			0.0	0	100.00%		2020
Severn Trent Water	ELMESTHORPE - BOSTOCK CLOSE PS (CSO)	T/50/03632/O-1	A1			239.9	45	99.99%		
Severn Trent Water	ELMHURST SEWAGE TREATMENT WORKS (ELMHURST (Sewage Treatment Works))	T/07/35741/R	A2			4665.9	255	92.84%		
Severn Trent Water	ELSTON (STW)	T/67/45596/R	A2			112.6	46	99.92%		2020
Severn Trent Water	ELTON (STW)	T/65/45931/R	A2			0.0	0	100.00%		2020
Severn Trent Water	ENDERBY - BLABY ROAD (CSO)	DT/8037	Single Discharge			5.7	4	99.99%		
Severn Trent Water	ENDON (STW)	T/30/35824/R	A2			1393.4	86	99.98%		2020
Severn Trent Water	ENVILLE SEWAGE PUMPING STATION (Enville St Lowndes Rd PS)	S/06/09103/O	Single Discharge			513.2	22	100.00%		
Severn Trent Water	EPWORTH (STW)	T/83/45777/R	A2			17.8	6	100.00%		2020
Severn Trent Water	ERDINGTON - CLARENCE ROAD 54 (CSO)	T/08/30222/O	Single Discharge			0.1	2	99.95%		
Severn Trent Water	Erewash Sq Ilkeston Cso	T/61/45158/O	Single Discharge			0.0	0	99.98%		
Severn Trent Water	ETRURIA - ETRURIA ROAD 457 (CSO)	T/01/22640/O	Single Discharge			0.0	0	97.11%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	ETRURIA VALE 2 (CSO)	T/01/02020/B	Single Discharge			2.8	10	99.96%		
Severn Trent Water	ETTINGTON WORKS (STW)	S/13/25835/R	A2			45.7	27	100.00%		2020
Severn Trent Water	ETWALL (STW)	T/36/46320/R	Single Discharge			54.8	14	99.92%		2020
Severn Trent Water	EVESHAM - AVON ST/BLIND LANE (CSO)	S/17/21586/O	Single Discharge			107.2	61	99.98%		
Severn Trent Water	EVESHAM - BATTLETON SYPHON 15 (CSO)	S/17/23078/O	A1			139.2	30	87.65%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	EVESHAM - LOWER LEYS 10 (CSO)	S/17/26187/O	Single Discharge			13.0	4	99.98%		
Severn Trent Water	EVESHAM - PERSHORE RD (CSO)	S/18/20357/O	Single Discharge			129.4	31	99.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	EVESHAM - WATERSIDE (CSO)	S/17/23194/O	Single Discharge			11.4	7	99.50%		
Severn Trent Water	EVESHAM/HAMPTON PARKS Sewage Treatment Works (EVESHAM (Sewage Treatment Works))	S/17/26427/R	A2			404.2	56	99.98%		
Severn Trent Water	EVINGTON - GWENDOLEN ROAD (CSO)	T/53/21447/O	Single Discharge			0.0	0	100.00%		
Severn Trent Water	FALLOWFIELD ROAD STORM OVERFLOW (HALESOWEN - FALLOWFIELD ROAD (CSO))	S/06/21187/O	Single Discharge			7.1	3	98.49%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	Farm Lane South Littleton PS	S/16/26059/O	Single Discharge			327.7	20	98.53%		2020
Severn Trent Water	FARM STREET STORM OVERFLOW (HOCKLEY - HUNTERS VALE (CSO))	T/09/22111/O	Single Discharge			42.3	37	99.40%		
Severn Trent Water	FARNDON - CHAPEL LANE (TPS)	TSC3221	A1			0.0	0	92.59%		2020
Severn Trent Water	FARNDON (STW)	T/67/45555/R	A2			18.0	7	100.00%		2020
Severn Trent Water	FARNSFIELD (STW)	T/64/45766/R	A3			19.8	10	100.00%		2020
Severn Trent Water	FEATHERSTONE - BROOKHOUSE LANE (CSO)	T/03/02756/O & T/03/08968/O	Single Discharge			570.0	43	93.12%		
Severn Trent Water	FENNY COMPTON (STW)	S/12/25307/R	A2A			1539.9	141	100.00%		2020
Severn Trent Water	FENNY COMPTON (STW)	S/12/25307/R	A2B			82.8	9	100.00%		2020
Severn Trent Water	FENNY DRAYTON (SPS)	T/19/12086/O	A1			105.7	39	100.00%		2020
Severn Trent Water	FENTON - SMITHPOOL ROAD (CSO)	T/01/35899/O	Single Discharge			1.8	9	99.90%		
Severn Trent Water	FENTON - WILLIAM STREET (CSO)	T/01/35844/O	Single Discharge			79.5	9	99.98%		
Severn Trent Water	FERNHILL HEATH - KENNELS LANE (TPS)	S/07/12223/O	A1			24.1	12	100.00%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	FIELD ADJ TO CHURCH STREET (BROSELEY - CHURCH ST (FIELD 7365) (SO))	S/02/55701/O	Single Discharge			10.8	7	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	FILLONGLEY - TAMWORTH ROAD (SPS)	T/15/35298/O	A1			115.1	32	99.86%		2020
Severn Trent Water	FINCHFIELD - CASTLECROFT LANE (SPS)	S/06/55921/O	Single Discharge			49.0	7	99.99%		
Severn Trent Water	FINCHFIELD - LINDEN LEA (SPS)	TSC3572	A1			2.5	3	99.70%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	FINDERN - COMMON PIECE LANE (CSO)	T/36/21115/O	Single Discharge			15.0	11	99.99%		
Severn Trent Water	FINDERN (STW)	T/36/45583/R	A2			26.1	4	96.85%		2020
Severn Trent Water	FINDERN (STW)	T/36/45583/R	A3			1.5	3	100.00%		2020
Severn Trent Water	FINDON CLOSE SEWAGE PUMPING STATION (BULKINGTON - FINDON CLOSE (SPS))	T/19/35397/O	A1			623.0	65	100.00%		
Severn Trent Water	FINNINGLEY (STW)	T/82/45638/R	A2			15.3	68	99.83%		2020
Severn Trent Water	FIVE WAYS - SPRING STREET (CSO)	DT/9835	Single Discharge			0.0	0	97.48%		2020
Severn Trent Water	FLECKNEY (STW)	T/51/45576/R	A2			331.8	47	99.39%		2020
Severn Trent Water	FLINTHAM - MAIN STREET (SPS)	T/67/22142/O	A1			0.0	0	100.00%		2020
Severn Trent Water	FLINTHAM (STW)	T/67/45832/R	A2			102.5	15	100.00%		2020
Severn Trent Water	FLYFORD FLAVELL STW (STW)	S/17/26537/R	A2			427.3	35	99.91%		2020
Severn Trent Water	FOREST TOWN - MAIN AVENUE (CSO)	T/70/40313/O	Single Discharge			13.0	23	99.85%		2020
Severn Trent Water	FOREST TOWN - NEWLANDS FARM (CSO)	T/70/46400/O	Single Discharge			112.5	20	99.81%		2020
Severn Trent Water	FORTON (STW)	S/04/55545/R	A2			0.0	0	100.00%		2020
Severn Trent Water	FOX'S LN/CROWN ST - STORM O/F (DUNSTALL HILL - FOXS LA/CROWN ST (CSO))	S/06/08871/O	Single Discharge			0.8	1	100.00%		
Severn Trent Water	FOXTON ROAD/WARD END PARK ROAD CSO (WASHWOOD HEATH - FOXTON ROAD (CSO))	T/10/12295/O	Single Discharge			17.4	30	99.96%		
Severn Trent Water	FRAMPTON (STW)	S/20/26558/R	A2			2276.4	146	100.00%		2020
Severn Trent Water	FRANKTON - MANOR FARM (SPS)	S/12/09044/O	A1			14.2	2	99.88%		2020
Severn Trent Water	FRANKTON (STW)	S/12/25970/R	A2			1418.9	78	100.00%		2020
Severn Trent Water	FRANKWELL - WHITE HORSE PASSAGE (CSO)	S/02/55709/O	Single Discharge			0.0	1	99.99%		
Severn Trent Water	FREEBY (STW)	T/54/45286/R	A2			495.4	166	100.00%		2020
Severn Trent Water	FRIARY AVENUE/BIRMINGHAM ROAD CSO (LICHFIELD - BIRMINGHAM ROAD (CSO))	T/22/35822/O	Single Discharge			93.9	12	91.57%		
Severn Trent Water	FRITCHLEY (STW)	T/41/45541/R	A2			569.4	58	99.99%		2020
Severn Trent Water	FRITCHLEY (STW)	T/41/45541/R	A3			44.1	14	100.00%		2020
Severn Trent Water	FROGHALL (STW)	T/30/35538/R	A2			1271.7	75	100.00%		2020
Severn Trent Water	FROGHALL (STW)	T/30/35538/R	A3			75.0	21	100.00%		2020
Severn Trent Water	FROLESWORTH (STW)	T/50/45550/R	A2			47.0	11	99.99%		2020
Severn Trent Water	FURLONG ROAD COMBINED STORM O'FLOW (TUNSTALL - GREENWAY (CSO))	T/01/35830/O	Single Discharge			20.1	14	99.81%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	FURNACE END Sewage Treatment Works (FURNACE END (Sewage Treatment Works))	T/15/35597/R	A2			0.0	0	99.41%		
Severn Trent Water	GADDESBY - NETHER END (TPS)	T/55/45578/O	Single Discharge			215.5	39	98.58%		2020
Severn Trent Water	GAINSBOROUGH Sewage Treatment Works (GAINSBOROUGH - LEA ROAD (Sewage Treatment Works))	T/69/45776/R	A2			1.0	1	100.00%		
Severn Trent Water	GARNER STREET ETRURIA (ETRURIA - GARNER STREET (CSO))	T/01/21052/O	Single Discharge			279.6	47	99.94%		
Severn Trent Water	GAULBY (STW)	T/51/45532/R	A2			781.3	104	100.00%		2020
Severn Trent Water	GAWNE LANE STORM OVERFLOW (CRADLEY HEATH - GAWNE LANE (CSO))	S/06/21065/O	Single Discharge			105.9	28	99.94%		
Severn Trent Water	GERRARD CLOSE,LOZELLS (LOZELLS - GERRARD CLOSE (CSO))	T/09/21293/O	Single Discharge			0.1	1	99.61%		
Severn Trent Water	GILBERTS END (SPS)	S/08/25189/O	Single Discharge			366.4	33	100.00%		2020
Severn Trent Water	GLASTONBURY RD COMBINED STORM of LOW (YARDLEY WOOD - 38 GLASTONBURY RD (CSO))	T/12/36476/O	Single Discharge			8.8	23	99.60%		
Severn Trent Water	GLENFIELD - LEICESTER ROAD (CSO)	T/56/02605/O-2	Single Discharge			0.5	1	90.91%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	GLENFIELD - STATION ROAD (CSO)	T/56/02605/O-8	Single Discharge			0.0	0	90.65%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	GLOUCESTER NETHERIDGE Sewage Treatment Works (NETHERIDGE (Sewage Treatment Works))	S/20/26440/R	A2			676.8	94	99.93%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	GOADBY MARWOOD - KEMPS LANE (TPS)	T/54/07710/O-5	A1			38.0	4	92.05%		2020
Severn Trent Water	GOBOWEN - FERNHILL LANE (SPS)	S/03/55151/O	Single Discharge			0.0	0	99.99%		2020
Severn Trent Water	GOLDEN HILLOCK ROAD STORM OVERFLOW (SMALL HEATH - GOLDEN HILLOCK ROAD (CSO))	T/12/36422/O	Single Discharge			8.2	11	99.39%		
Severn Trent Water	GOMS MILL (DRESDEN - KIMBERLEY STREET (CSO))	T/01/30035/O	Single Discharge			36.6	38	100.00%		
Severn Trent Water	GOSCOTE - HILDICKS CRESCENT (CSO)	T/08/36219/O	Single Discharge			0.0	0	99.99%		
Severn Trent Water	GOSCOTE (STW)	T/08/36220/R	A2			64.0	8	100.00%		2020
Severn Trent Water	GOTHAM WASTEWATER TREATMENT WORKS (GOTHAM (Sewage Treatment Works))	T/62/46338/R	A2			104.4	7	99.88%		
Severn Trent Water	GRACEDIEU - LOUGHBOROUGH ROAD (SPS)	T/57/03613/O	A1			125.2	22	98.60%		2020
Severn Trent Water	GREASLEY ROAD CSO (ABBEY HULTON - GREASLEY ROAD 3 (CSO))	T/01/35799/O	Single Discharge			2.8	10	99.98%		
Severn Trent Water	GREAT BARR - HAMSTEAD RD/WALCOT DR (CSO)	T/08/12277/O	Single Discharge			0.4	1	99.99%		
Severn Trent Water	GREAT BOLAS (STW)	S/04/55714/O	A2			706.2	86	99.36%		2020
Severn Trent Water	GREAT BRIDGE - FARLEY STREET (CSO)	T/08/21454/O	Single Discharge			3.8	6	93.58%		
Severn Trent Water	GREAT BRIDGE - GREAT BRIDGE ST (CSO)	T/08/30062/O	Single Discharge			3.4	3	99.99%		
Severn Trent Water	Great Bridgeford PS	T/02/30245/O	A1			0.0	0	99.05%		2020
Severn Trent Water	GREAT CHELL - CUMBERBATCH AVENUE (CSO)	T/01/35798/O	Single Discharge			47.2	42	99.93%		
Severn Trent Water	GREAT GLEN (STW)	T/51/45910/R	A2			438.1	60	99.97%		2020
Severn Trent Water	GREAT WYRLEY - STATION RD (CSO)	T/03/21311/O	Single Discharge			71.9	57	99.89%		
Severn Trent Water	Green Hill Road	No known permit reference	Single Discharge			11.4	7	100.00%		2020
Severn Trent Water	GREEN STREET COMBINED STORM O'FLOW (BIRMINGHAM - GREEN STREET (CSO))	T/09/36504/O	Single Discharge			0.0	0	100.00%		
Severn Trent Water	GREENGATE LANE ESTATE - EMEG O/F (BIRSTALL -QUEENSGATE DRIVE (SPS))	T/56/00953/O	A1			5.3	2	99.93%		
Severn Trent Water	GRENDON WASTEWATER TREATMENT WORKS	T/21/36278/R	A1			203.8	29	99.94%		
Severn Trent Water	GRIFFYDAM - REMPSTONE ROAD (CSO)	T/20/03553/O-1	Single Discharge			14.4	6	99.91%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	GRINDLEFORD SEWAGE P S (Grindleford PS)	T/38/40242/O	A1			404.6	44	99.92%		
Severn Trent Water	GROSVENOR RD SSO (HANDSWORTH - WELLINGTON ROAD 223 (CSO))	T/08/30193/O	Single Discharge			361.7	51	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	GROVE (STW)	T/74/45346/R	A2			13.0	7	100.00%		2020
Severn Trent Water	GT WASHBOURNE (STW)	S/17/26193/R	A2			356.2	42	99.98%		2020
Severn Trent Water	GUNNESS - DONCASTER ROAD (SPS)	T/81/40049/O	A1			7.7	6	99.88%		2020
Severn Trent Water	GUNNESS (STW)	T/84/45990/R	A2			0.0	0	100.00%		2020
Severn Trent Water	HALESOWEN - DUDLEY ROAD (CSO)	S/06/21185/O	Single Discharge			7.3	2	82.93%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HALESOWEN ROAD STORM OVERFLOW (OLD HILL - HALESOWEN ROAD (CSO))	S/06/21042/O	Single Discharge			0.6	2	99.87%		
Severn Trent Water	Hall Lane Willington PS	T/36/45168/O, T/36/12288/O & WQ/7/444V2-2	A1			8.4	3	99.91%		
Severn Trent Water	Halloughton Rd Southwell CSO	T/64/45273/O	Single Discharge			31.9	27	99.97%		
Severn Trent Water	HALLOW (STW)	S/09/55973/R	A2			362.7	31	100.00%		2020
Severn Trent Water	HAMMERCLIFFE ROAD STORM OVERFLOW (HUMBERSTONE - HAMMERCLIFFE ROAD (CSO))	T/53/21449/O	Single Discharge			11.1	8	100.00%		
Severn Trent Water	HAMPTON IN ARDEN - MERIDEN ROAD (SPS)	T/11/02501/O	A1			225.8	37	100.00%		2020
Severn Trent Water	Hampton on the Hill - Henley Road (SPS)	No known permit reference	A1			19.6	3	99.99%		2020
Severn Trent Water	HAMSTEAD PUMPING STATION (GREAT BARR - HAMSTEAD ROAD (SPS))	T/08/02585/O	A1			2.6	2	99.98%		
Severn Trent Water	HANBURY - HANBURY HILL (CSO)	T/33/21255/O	Single Discharge			0.0	0	99.72%		
Severn Trent Water	HANBURY (WORCESTERSHIRE) (STW)	S/19/25309/R	A2			1384.3	76	97.79%		2020
Severn Trent Water	HANBURY SEWAGE TREATMENT WORKS (HANBURY (STAFFORDSHIRE) (Sewage Treatment Works))	T/33/35725/R	A2			12.6	11	100.00%		
Severn Trent Water	Handsacre PS	TSC3400	Single Discharge			0.8	2	100.00%		2020
Severn Trent Water	HANDSWORTH - GROSVENOR RD (CSO)	T/08/30257/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	HANDSWORTH - GROVE LA/ALBERT RD (CSO)	T/08/35643/O	Single Discharge			0.0	0	99.99%		
Severn Trent Water	HANDSWORTH - NINEVEH RD 1 (CSO)	T/08/35896/O	Single Discharge			52.4	4	99.93%		2020
Severn Trent Water	HANDSWORTH - NINEVEH RD 2 (CSO)	T/08/35895/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	HANDSWORTH - PIERS ROAD (CSO)	T/09/21294/O	Single Discharge			6.9	9	100.00%		2020
Severn Trent Water	HANDSWORTH WOOD - PLAYING FIELDS (CSO)	T/08/36342/O	Single Discharge			14.7	10	99.76%		
Severn Trent Water	Hanging Bridge No1 PS	T/29/01413/O-1	A1			91.1	7	100.00%		2020
Severn Trent Water	HANLEY - AUSTIN ST/JOINERS SQ PS (CSO)	T/01/35973/O	A1			7.9	8	99.90%		
Severn Trent Water	HANLEY - BOUGHEY ROAD (CSO)	T/01/21318/O	Single Discharge			600.8	37	95.60%		
Severn Trent Water	HANLEY - LEEK RD/ IVY HOUSE RD (CSO)	T/01/35968/O	Single Discharge			1.9	28	99.84%		
Severn Trent Water	HANLEY - LEEK RD/BOTTESLOW ST (CSO)	T/01/35967/O	Single Discharge			10.7	40	99.86%		
Severn Trent Water	HANLEY - STUART ROAD (CSO)	T/01/35974/O	Single Discharge			0.1	2	99.95%		
Severn Trent Water	HANWOOD - WEIR ROAD (SPS)	S/02/56288/O	Single Discharge			149.8	16	99.99%		
Severn Trent Water	HARBORNE - FREDAS GROVE (CSO)	T/08/36421/O	Single Discharge			0.0	0	99.78%		
Severn Trent Water	HARBORNE - TENNAL LANE (CSO)	T/09/36321/O & CSO/T/1941	Single Discharge			0.0	0	100.00%		
Severn Trent Water	HARBOROUGH MAGNA (STW)	S/10/26277/R	A2			379.7	99	100.00%		2020
Severn Trent Water	HARBY - LANGAR LANE (SPS)	T/66/07371/O-3	A1			20.0	5	100.00%		2020
Severn Trent Water	HARBY (STW)	T/66/45609/R	A1			267.2	42	100.00%		2020
Severn Trent Water	HARDEN - HARDEN ROAD/COALPOOL LANE (CSO)	T/08/22302/O	Single Discharge			1.5	10	99.88%		
Severn Trent Water	HARTINGTON WWTW (HARTINGTON (Sewage Treatment Works))	T/25/36210/R	A2			1368.7	71	99.84%		
Severn Trent Water	HARTS ROAD/HIGHFIELD ROAD JCN SSO (WASHWOOD HEATH - HARTS ROAD (CSO))	T/10/36467/O	Single Discharge			11.1	39	99.29%		
Severn Trent Water	HARTSHILL - HILTON ROAD (CSO)	T/01/36238/O	Single Discharge			31.2	41	99.99%		
Severn Trent Water	HARTSHILL - RISELEY ROAD (CSO)	T/01/35715/O	Single Discharge			35.1	55	99.53%		
Severn Trent Water	HARTSHORNE - BUGLEY HOLE (CSO)	T/36/40347/O	Single Discharge			0.0	0	99.88%		2020
Severn Trent Water	HARVINGTON (STW)	S/17/26284/R	A2			110.2	11	100.00%		2020
Severn Trent Water	HARWILL CRESCENT - STORM of & SWS (ASPLEY - NUTHALL ROAD/BAR LANE (CSO))	T/63/12349/O	Single Discharge			0.0	0	99.85%		
Severn Trent Water	HARWORTH (STW)	T/83/45790/R	A2			35.6	9	99.94%		2020
Severn Trent Water	HARWORTH (STW)	T/83/45790/R	A3			0.0	0	100.00%		2020
Severn Trent Water	Hassam Parade and Milehouse Lane	No known permit reference	Single Discharge			2949.0	163	91.65%		2020
Severn Trent Water	HATHERN - WIDE STREET (CSO)	T/57/07603/O	Single Discharge			44.4	45	78.18%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HATHERSAGE - MILL LANE (CSO)	T/38/40068/O	Single Discharge			1.2	4	100.00%		2020
Severn Trent Water	HATHERSAGE Sewage Treatment Works (HATHERSAGE (Sewage Treatment Works))	T/38/46316/R	A2			2475.2	136	99.91%		
Severn Trent Water	HAUGHTON (STW)	T/02/35592/R	A2			415.6	23	100.00%		2020
Severn Trent Water	HAWBUSH ROAD STORM OVERFLOW (BRIERLEY HILL - HAWBUSH ROAD (CSO))	S/06/21751/O	Single Discharge			340.5	37	99.99%		
Severn Trent Water	HAWKSWORTH (STW)	T/67/45666/R	A2			0.6	1	100.00%		2020
Severn Trent Water	HAWLEY RD; HINCKLEY	T/19/00793/O	Single Discharge			0.5	3	99.97%		
Severn Trent Water	HAXEY - GRAIZELOUND (STW)	T/82/45052/R	A2			197.3	36	99.99%		2020
Severn Trent Water	HAYDEN (STW)	S/20/26207/R	A2			426.0	42	96.07%		2020
Severn Trent Water	HAYES LANE STORM SEWAGE OVERFLOW (LYE - HAYES LANE (CSO))	S/06/55808/O	Single Discharge			0.0	0	90.97%		
Severn Trent Water	HAZELWOOD - NETHER LANE (SPS)	T/43/02012/O	A1			105.6	13	99.81%		2020
Severn Trent Water	HEAGE - BROOK STREET 3 (CSO)	T/41/21456/O	Single Discharge			1189.9	55	99.96%		2020
Severn Trent Water	HEAGE - SOTSHOLE (SPS)	TSC3901	A1			55.8	27	100.00%		2020
Severn Trent Water	HEAGE (STW)	T/41/45771/R	A2			329.8	25	100.00%		2020
Severn Trent Water	HEAGE (STW)	T/41/45771/R	A3			329.5	31	100.00%		2020
Severn Trent Water	HEANOR - BERLE AVENUE (CSO)	T/61/21531/O	Single Discharge			257.0	94	96.70%		2020
Severn Trent Water	HEANOR - BURNS STREET (CSO)	T/61/46407/O	Single Discharge			0.0	0	99.33%		2020
Severn Trent Water	HEANOR - GREENACRE AVENUE (CSO)	T/61/45741/O	Single Discharge			47.5	27	99.99%		
Severn Trent Water	HEANOR - HEANOR ROAD (CSO)	T/61/21519/O	Single Discharge			2.3	6	100.00%		2020
Severn Trent Water	HEANOR - LOSCOE ROAD/ALLANDALE ROAD (CSO)	T/61/21513/O	Single Discharge			0.0	0	99.57%		2020
Severn Trent Water	HEANOR - PEACH STREET (CSO)	T/61/20990/O	Single Discharge			2.4	3	99.87%		2020
Severn Trent Water	HEANOR - THORPES ROAD 58 (CSO)	T/61/21600/O	Single Discharge			15.3	9	100.00%		2020
Severn Trent Water	HEANOR - THORPES ROAD 83 (CSO)	T/61/21510/O	Single Discharge			331.3	16	99.74%		
Severn Trent Water	HEANOR-MILNHAY (STW)	T/61/45098/R	A3			1156.0	66	100.00%		2020
Severn Trent Water	HEANOR-MILNHAY (STW)	T/61/45098/R	A4			30.1	10	100.00%		2020
Severn Trent Water	Heather - Mill Lane WRPS	No known permit reference	A1			1.3	2	91.88%		2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	HEATHER (TPS)	T/20/30312/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	HEDGING LANE CSO (HOCKLEY - HEDGING LANE (CSO))	T/16/36096/O	Single Discharge			0.6	2	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HELLABY - BAWTRY ROAD (CSO)	T/83/40034/O	Single Discharge			34.4	30	99.98%		
Severn Trent Water	HEMINGTON - MAIN STREET (SPS)	T/59/40159/O	A1			0.0	0	98.41%		2020
Severn Trent Water	HEMPSTED - SUDMEADOW ROAD (SPS)	TSC3962	A1			95.7	6	100.00%		2020
Severn Trent Water	HENDESFORD ROAD 195 (SO) - HEATH HAYES	No known permit reference	Single Discharge			0.3	1	99.88%		2020
Severn Trent Water	HIGH ERCALL - CHURCH ROAD (CSO)	NPSWQD006196	Single Discharge			51.9	11	99.98%		2020
Severn Trent Water	HIGH ERCALL (STW)	S/04/55903/R	A2			0.9	3	100.00%		2020
Severn Trent Water	HIGH ROAD SEWAGE PUMPING STATION (BEESTON - MIDDLE STREET (CSO))	T/61/03670/O-4	Single Discharge			13.1	35	99.94%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HIGH ST/WHATTON RD-STORM & SWS (KEGWORTH - HIGH STREET (CSO))	T/57/08994/O	Single Discharge			0.0	0	98.87%		
Severn Trent Water	HIGH STREET(OPPOSITE BULL ST) (HARBORNE - HIGH STREET/VIVIAN ROAD (CSO))	T/09/36323/O	Single Discharge			0.3	2	99.99%		
Severn Trent Water	High Street/ Station Road CSO	No known permit reference	Single Discharge			1.3	2	99.95%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	HIGHAM ON THE HILL (SPS)	T/20/30310/O	A1			18.3	11	99.88%		2020
Severn Trent Water	HIGHER HEATH-PREES (STW)	S/04/56056/R	A2			13.9	6	100.00%		2020
Severn Trent Water	HIGHFIELDS - MAYFIELD ROAD (CSO)	T/53/21444/O	Single Discharge			0.0	0	99.99%		
Severn Trent Water	HIGHGATE - SHERLOCK STREET (CSO)	DT/9834	Single Discharge			28.7	2	99.67%		2020
Severn Trent Water	HIGHLEY - MAIN ROAD (CSO)	S/02/21492/O	Single Discharge			5.6	9	93.87%		
Severn Trent Water	HIGHLEY - NETHERTON LANE (SST)	S/02/55700/O	Single Discharge			41.4	8	99.94%		
Severn Trent Water	HIGHLEY WASTEWATER TREATMENT WORKS (HIGHLEY (Sewage Treatment Works))	S/02/56099/R	A2			1150.9	69	100.00%		
Severn Trent Water	HILCOTE - NEW LANE (SPS)	T/41/20329/O	A1			36.8	14	100.00%		2020
Severn Trent Water	HILL - A426 (SPS)	TSC3481	A1			100.7	7	99.61%		2020
Severn Trent Water	HILLMORTON - BRINDLEY ROAD (CSO)	TSC317	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	HILLMORTON - THE KENT (CSO)	S/10/12157/O	Single Discharge			137.1	12	99.92%		2020
Severn Trent Water	HILTON - MILL LANE (SO)	T/34/03432/O-1	Single Discharge			0.0	0	99.91%		
Severn Trent Water	HILTON PARK SEWAGE PUMPING STATION (HILTON PARK (SPS))	T/03/36276/O	A1			3.1	2	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HIMLEY Sewage Treatment Works (HIMLEY (Sewage Treatment Works))	S/06/55931/R	A2			1278.6	95	94.58%		
Severn Trent Water	HINCKLEY - HARROWBROOK ROAD (CSO)	T/19/35414/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	Hinckley Rd Aston Flamville PS	TSC3485	A1			56.7	22	99.88%		2020
Severn Trent Water	HINCKLEY WASTEWATER TREATMENT WORKS (HINCKLEY - BROOKFIELD ROAD (CSO))	T/19/36495/R	Single Discharge			144.7	50	100.00%		
Severn Trent Water	HIXON - PASTUREFIELDS (TPS)	TSC3747	A1			15.5	8	99.94%		2020
Severn Trent Water	HIXON SEWAGE TREATMENT WORKS (HIXON (Sewage Treatment Works))	T/01/36221/R	A2			754.0	78	99.91%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HOGNASTON (STW)	T/29/35579/R	A2			6.0	15	99.99%		2020
Severn Trent Water	HOLBROOK - TOWN STREET (CSO)	T/45/40156/O	Single Discharge			1.6	4	100.00%		2020
Severn Trent Water	HOLBROOK - WATERING LANE (CSO)	T/45/40156/O	Single Discharge			0.0	0	99.98%		2020
Severn Trent Water	HOLBURY CRESCENT PUMPING STATION (WHITMINSTER - SCHOOL LANE (SPS))	S/20/25538/O	Single Discharge			446.6	72	99.99%		
Severn Trent Water	HOLLINGTON ROAD (STRAMSHALL - ASBOURNE ROAD (CSO))	T/31/08235/O	Single Discharge			7.3	14	99.83%		
Severn Trent Water	HOLLOWAY - LEA ROAD (CSO)	T/40/00737/O	Single Discharge			2.0	7	100.00%		2020
Severn Trent Water	HOLLOWAY SCHOOL ROAD (TETTENHALL - SCHOOL RD/THE CRES (CSO))	T/03/12429/O-4	Single Discharge			0.0	0	98.38%		
Severn Trent Water	HOLWELL - MAIN STREET (SPS)	T/55/02608/O-1	A1			2.9	10	100.00%		2020
Severn Trent Water	HOLY CROSS - HOSSIL LANE (SPS)	S/06/07665/O	A1			0.5	2	100.00%		2020
Severn Trent Water	Homesford PS	T/40/45096/O	A1			12.5	12	99.88%		2020
Severn Trent Water	HONNINGTON - LILLESHALL (SPS)	S/04/55811/O	A1			14.8	3	99.98%		2020
Severn Trent Water	HONNINGTON ON A518 (CSO)	S/04/20894/O	Single Discharge			560.9	71	99.78%		
Severn Trent Water	Hoobrook PS	S/06/55076/O	A2			0.0	0	97.89%		2020
Severn Trent Water	HOOKAGATE PUMPING STATION (HOOK A GATE (SPS))	S/02/55419/O	A1			470.7	39	99.98%		
Severn Trent Water	HOPWAS - CANALSIDE SCHOOL LANE (CSO)	T/22/35105/O	Single Discharge			3.4	13	99.99%		
Severn Trent Water	HOPYARD LANE/STRAIGHTS RD JCN SSO (GORNAL WOOD - STRAITS ROAD (CSO))	S/06/21304/O	Single Discharge			0.0	0	100.00%		
Severn Trent Water	HORNINGLOW - HORNINGLOW ROAD 49 (CSO)	T/24/35226/O	Single Discharge			52.6	32	99.99%		
Severn Trent Water	HORNINGLOW - ROLLESTON ROAD 151 (CSO)	T/24/21576/O	Single Discharge			61.2	38	99.91%		
Severn Trent Water	HORNINGLOW - WYGGESTON STREET 316 (CSO)	T/33/07069/O-2	Single Discharge			248.0	42	94.19%		
Severn Trent Water	HORSLEY WOODHOUSE - CHESTNUT CLOSE (CSO)	T/45/03036/O	Single Discharge			0.0	0	99.99%		2020
Severn Trent Water	Hortonwood Trench Sso	S/04/55294/O	Single Discharge			2337.7	112	100.00%		2020
Severn Trent Water	HOWARD ROAD & KNIGHTON/STM & SWS (KNIGHTON FIELDS - HOWARD ROAD (CSO))	T/52/12423/O-2	Single Discharge			0.2	1	99.83%		
Severn Trent Water	HUCKNALL - BATHS LANE (CSO)	T/63/08784/O	Single Discharge			10.4	13	100.00%		2020
Severn Trent Water	HUCKNALL - NABBS LANE (CSO)	T/63/03780/O	Single Discharge			0.0	0	99.67%		2020
Severn Trent Water	HUCKNALL - SHELTON AVENUE (CSO)	T/63/45888/O	Single Discharge			230.1	61	99.09%		2020
Severn Trent Water	HUCKNALL - STOREY GARDENS (CSO)	T/63/08794/O	Single Discharge			75.0	44	99.99%		
Severn Trent Water	HUCKNALL - WATNALL ROAD (CSO)	T/63/03781/O	Single Discharge			0.8	3	99.99%		
Severn Trent Water	Hucknall Lane / Aston Drive (Unlisted)	No known permit reference	Single Discharge			226.5	55	97.60%		2020
Severn Trent Water	Hucknall Lane / Grindon Crescent (Unlisted)	No known permit reference	Single Discharge			14.7	8	100.00%		2020
Severn Trent Water	Hucknall Lane / Longford Crescent (Unlisted)	No known permit reference	Single Discharge			0.0	0	93.72%		2020
Severn Trent Water	HUGGLESCOTE - STATION RD(CEMETERY) (CSO)	T/20/22541/O	Single Discharge			0.0	0	95.46%		2020
Severn Trent Water	HULLAND WARD (STW)	T/43/45461/R	A2			126.5	29	99.88%		2020
Severn Trent Water	HUMBERSTONE - HUMBERSTONE DRIVE (CSO)	T/53/02503/O	Single Discharge			0.0	0	99.99%		
Severn Trent Water	Hunters Lane (Avon Mill) Rugby PS	248	Single Discharge			88.1	9	100.00%		2020
Severn Trent Water	HUNTLEY - ORCHARD WAY (CSO)	S/21/09311/O	Single Discharge			225.6	54	99.17%		
Severn Trent Water	HURLEY SEWAGE TREATMENT WORKS (HURLEY (Sewage Treatment Works))	T/16/35777/R	A2			1330.9	82	99.77%		
Severn Trent Water	HUTHWAITE - BLACKWELL ROAD (CSO)	T/41/07297/O-1	Single Discharge			0.0	0	99.99%		2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	HUTHWAITE (STW)	T/41/45831/R	Single Discharge			509.7	37	100.00%		2020
Severn Trent Water	HUTHWAITE (STW)	T/41/45831/R	A3			37.1	14	100.00%		2020
Severn Trent Water	IBSTOCK - BELCHERS BAR (SPS)	T/20/02945/O	A1			0.0	0	100.00%		2020
Severn Trent Water	IBSTOCK - STATION ROAD (SPS)	T/20/30176/O	A1			38.1	5	100.00%		2020
Severn Trent Water	IBSTOCK (STW)	T/20/36246/R	A2			229.8	25	90.65%		2020
Severn Trent Water	IBSTOCK (STW)	T/20/36246/R	A3			222.6	38	100.00%		2020
Severn Trent Water	ILKESTON - BENNERLEY FIELDS (CSO)	T/61/02840/O	Single Discharge			158.2	69	89.59%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	ILKESTON - LITTLE HALLAM HILL (CSO)	T/61/40371/O	Single Discharge			5.0	6	95.15%		2020
Severn Trent Water	ILKESTON - MANOR VIEW (CSO)	T/61/45127/O	Single Discharge			2.5	3	99.99%		2020
Severn Trent Water	ILKESTON - NELSON STREET (CSO)	T/61/01787/O-3	Single Discharge			0.0	0	99.96%		
Severn Trent Water	ILKESTON (HALLAM FIELDS) WWTW (ILKESTON - HALLAM FIELDS (Sewage Treatment Works))	T/61/45626/R	A2			2400.3	131	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	ILKESTON RD/ROTHSAY AVENUE (RADFORD - ILKESTON RD/BALFOUR RD (CSO))	T/63/09183/O	Single Discharge			1.2	6	99.95%		
Severn Trent Water	ILKESTON RD/ROTHSAY AVENUE (RADFORD - ILKESTON RD/ROTHESAY AVE (CSO))	T/63/09183/O-2	Single Discharge			7.3	23	99.83%		
Severn Trent Water	ILMINGTON (STW)	S/14/25976/R	A2			967.9	74	99.94%		2020
Severn Trent Water	IPSTONES - BROOKFIELDS ROAD (CSO)	T/30/01383/O	Single Discharge			3.8	13	99.95%		
Severn Trent Water	IPSTONES (SPS)	T/30/20183/O	A1			1409.1	88	99.98%		2020
Severn Trent Water	IRONBRIDGE - NEW ROAD #1	No known permit reference	Single Discharge			0.0	0	99.99%		2020
Severn Trent Water	IRONBRIDGE - NEW ROAD #2	No known permit reference	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	IRONBRIDGE - SEVERNSIDE (SPS)	TSC3863	A1			0.0	0	100.00%		2020
Severn Trent Water	IRONBRIDGE (SHAFT) SPS AND LADYWOOD (IRONBRIDGE SHAFT (TPS))	S/02/56046/O	Single Discharge			649.7	56	99.99%		
Severn Trent Water	Islington Row Middleway CSO	No known permit reference	Single Discharge			0.0	0	99.84%		2020
Severn Trent Water	ITCHEN BANK (STW)	S/12/26557/R	A2			487.2	51	100.00%		2020
Severn Trent Water	JACKFIELD - COALFORD (TPS)	S/02/08939/O	Single Discharge			34.8	3	99.86%		2020
Severn Trent Water	JACKSDALE - MAIN ROAD (CSO)	T/61/02559/O-1	Single Discharge			99.7	32	99.99%		
Severn Trent Water	JEFFCOCK RD/RAYLEIGH RD JCN SSO (BRADMORE - JEFFCOCK RD/RAYLEIGH RD (CSO))	S/06/50096/O	Single Discharge			0.0	0	97.10%		
Severn Trent Water	Jn of Mansfield Rd / Egerton Rd	No known permit reference	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	Joiners Square CSO	T/01/36023/O	Single Discharge			0.0	0	99.78%		
Severn Trent Water	JUNCTION OF OXHILL ROAD AND AVENUE ROAD	No known permit reference	Single Discharge			0.0	0	92.02%		2020
Severn Trent Water	KEGWORTH - LONG LANE (CSO)	T/59/40062/O	Single Discharge			26.3	10	100.00%		2020
Severn Trent Water	KEGWORTH (STW)	T/59/45410/R	A2			180.5	26	100.00%		2020
Severn Trent Water	KELHAM - BLACKSMITH LANE (SPS)	TSC3118	A1			0.0	0	99.94%		2020
Severn Trent Water	KELHAM - KELHAM BRIDGE (CSO)	T/20/30308/O	Single Discharge			65.6	30	99.88%		2020
Severn Trent Water	KELHAM BRIDGE (SPS)	T/20/35540/O	Single Discharge			262.3	36	100.00%		2020
Severn Trent Water	KELSTEDGE Sewage Treatment Works (KELSTEDGE (Sewage Treatment Works))	T/41/45651/R	A2			249.1	76	99.76%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	KEMERTON - LOWER MILL FARM (CSO)	S/17/25504/O	Single Discharge			25.6	8	99.98%		
Severn Trent Water	KEMERTON (SPS)	S/17/26559/O	Single Discharge			259.5	26	99.98%		2020
Severn Trent Water	KEMPLEY - FISHPOOL (SPS)	TSC3379	A1			28.0	5	100.00%		2020
Severn Trent Water	KEMPSEY Sewage Treatment Works (KEMPSEY WORKS (Sewage Treatment Works))	S/08/26590/R	A2			0.0	0	99.98%		
Severn Trent Water	KENDRICK STREET (LONGTON - KENDRICK STREET (CSO))	T/01/22784/O	Single Discharge			1.4	8	93.12%		
Severn Trent Water	KENILWORTH - DALEHOUSE LANE (TPS)	S/11/07065/O	A1			103.0	18	100.00%		2020
Severn Trent Water	KENILWORTH - THE CLOSE/MILL END (CSO)	S/11/26415/O	Single Discharge			0.5	1	99.95%		2020
Severn Trent Water	Kestrel Close Whittington PS	T/22/35362/O	Single Discharge			20.1	4	99.76%		
Severn Trent Water	KEYWORTH - PLATT LANE (SPS)	T/64/40319/O	A1			33.4	14	100.00%		2020
Severn Trent Water	KIDDERMINSTER - BEWDLEY ROAD (CSO)	S/06/12206/O-2	Single Discharge			0.4	2	100.00%		2020
Severn Trent Water	KIDDERMINSTER - COMBERTON ROAD (CSO)	S/06/12242/O	Single Discharge			66.4	38	99.95%		
Severn Trent Water	KIDDERMINSTER - COVENTRY ST ISLAND (SST)	S/06/12241/O-2	Single Discharge			0.0	0	99.89%		
Severn Trent Water	KIDDERMINSTER - PARK BUTTS RINGWAY (CSO)	S/06/12239/O	Single Discharge			26.3	33	99.98%		
Severn Trent Water	KIDDERMINSTER - STOURPORT ROAD (CSO)	S/06/12238/O	Single Discharge			5.4	13	99.83%		2020
Severn Trent Water	KIDDERMINSTER - SUTTON ROAD (CSO)	S/06/12206/O-1	Single Discharge			0.1	1	99.76%		2020
Severn Trent Water	KIDDERMINSTER OLDINGTON (STW)	S/06/56074/R	A2			1295.2	68	100.00%		2020
Severn Trent Water	KILBURN - DERBY RD/BYWELL LN (CSO)	T/45/21097/O	Single Discharge			0.0	0	99.88%		2020
Severn Trent Water	KILBURN - DERBY ROAD 211 (CSO)	T/45/03036/O	Single Discharge			14.0	12	92.13%		2020
Severn Trent Water	KILBURN - RAWSON GREEN 4 (CSO)	T/45/03036/O	Single Discharge			164.0	31	99.74%		2020
Severn Trent Water	KILBURN - RYKNIELD ROAD (CSO)	T/45/03036/O	Single Discharge			0.0	0	99.90%		
Severn Trent Water	KILBURN (STW)	T/45/45334/R	A2			259.9	42	99.99%		2020
Severn Trent Water	KILBY (SPS)	T/51/40041/O	Single Discharge			16.5	4	100.00%		2020
Severn Trent Water	KILSBY (STW)	S/12/26563/R	A2			173.9	22	99.69%		2020
Severn Trent Water	KIMBLE GROVE COMBINED STORM O'FLOW (TYBURN - KIMBLE GROVE (CSO))	T/10/36054/O	Single Discharge			8.0	6	99.96%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	KINETON - BANBURY ROAD/MILL LANE (CSO)	S/13/20324/O	Single Discharge			52.4	8	99.98%		
Severn Trent Water	KINETON - SOUTHAM STREET (CSO)	S/13/20323/O	Single Discharge			0.0	0	94.13%		
Severn Trent Water	KINETON (STW)	S/13/25745/R	A2			731.6	172	100.00%		2020
Severn Trent Water	KING STREET (BELPER - KING STREET/STRUTT STREET (CSO))	T/42/20919/O	Single Discharge			0.9	3	99.91%		
Severn Trent Water	KING STREET SSO (NEWCASTLE - KING STREET (CSO))	T/01/35196/O	Single Discharge			3.3	13	99.76%		
Severn Trent Water	KINGS COUGHTON - BIRMINGHAM RD PS (CSO)	S/15/08983/O	A1			56.6	9	99.95%		
Severn Trent Water	KINGS NEWTON - MAIN STREET (CSO)	T/36/21330/O	Single Discharge			8.1	12	99.88%		2020
Severn Trent Water	KINGS NORTON - ILLSTON ROAD (SPS)	T/51/03218/O-1	A1			11.6	3	99.94%		2020
Severn Trent Water	KINGS NORTON - REAR 24 EBURY RD (CSO)	T/09/36083/O	Single Discharge			50.6	34	100.00%		2020
Severn Trent Water	KINGSBURY PUMPING STATION (KINGSBURY (SPS))	T/16/07864/O	A1			0.0	0	100.00%		
Severn Trent Water	KINGSLEY HOLT - SHAWE PARK ROAD (SPS)	T/32/20187/O	Single Discharge			116.6	35	100.00%		2020
Severn Trent Water	KINGSWAY PUMPING STATION (Kingsway PS)	S/06/55687/O	Single Discharge			0.0	0	99.91%		
Severn Trent Water	KINGSWINFORD - CROSS STREET (CSO)	S/06/21299/O	Single Discharge			0.0	0	100.00%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	KINVER Sewage Treatment Works (KINVER (Sewage Treatment Works))	S/06/55384/R	A2			88.7	8	99.95%		
Severn Trent Water	KIRBY MUXLOE - GOLF COURSE (CSO)	T/56/02605/O-4	Single Discharge			0.5	5	89.17%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	KIRK ROAD STORM OVERFLOW (MAPPERLEY - KIRK ROAD (CSO))	T/64/46345/O	Single Discharge			29.0	36	99.69%		
Severn Trent Water	KIRKBY IN ASHFIELD - MILL LANE (CSO)	T/61/08696/O-1	Single Discharge			7.5	3	92.09%		2020
Severn Trent Water	KIRKBY IN ASHFIELD - REGENT STREET (CSO)	T/61/45563/O	Single Discharge			38.1	23	99.99%		
Severn Trent Water	KIRKBY IN ASHFIELD (STW)	T/61/45171/R	A3			0.0	0	100.00%		2020
Severn Trent Water	KIRKBY MALLORY (STW)	T/50/46001/R	A2			29.9	13	99.99%		2020
Severn Trent Water	KIRTON-IN-LINDSEY (STW)	T/80/45794/R	A2			9.4	4	100.00%		2020
Severn Trent Water	KITTS GREEN - GRESSEL LANE (CSO)	T/12/21309/O	Single Discharge			2.3	9	99.99%		
Severn Trent Water	KITTS GREEN - KITTS GREEN ROAD (CSO)	T/12/21238/O	Single Discharge			185.9	68	99.98%		
Severn Trent Water	KITTS GREEN - MIDDLE LEAFORD (CSO)	T/12/07937/O	Single Discharge			0.0	0	99.99%		
Severn Trent Water	KIVETON PARK - HARD LANE (SPS)	T/75/46091/O	A1			0.0	0	95.69%		2020
Severn Trent Water	KIVETON PARK - WALES ROAD (CSO)	T/75/40098/O	Single Discharge			0.1	1	100.00%		2020
Severn Trent Water	KNEETON (STW)	T/67/45313/R	A2			3.5	7	99.88%		2020
Severn Trent Water	KNIVETON (STW)	T/29/35675/R	A2			25.0	24	99.99%		2020
Severn Trent Water	Knockin PS	S/01/55002/O	A1			64.1	50	100.00%		2020
Severn Trent Water	KNOWLE - HILLMORTON ROAD (CSO)	T/11/21467/O	Single Discharge			9.0	4	99.95%		
Severn Trent Water	KNYPERSLEY STORM SEWAGE OVERFLOW (KNYPERSLEY - TUNSTALL ROAD (CSO))	T/01/35494/O	Single Discharge			20.5	15	99.85%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	LADYGATE - STORM/EMERGENCY O/F (DISEWORTH - LADYGATE (SPS))	T/57/08273/O	A1			23.5	6	99.86%		
Severn Trent Water	LADYWOOD - GOODMAN STREET (CSO)	T/09/21230/O	Single Discharge			0.0	0	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	LADYWOOD CSO (IRONBRIDGE - LADYWOOD (CSO))	S/02/26850/O	Single Discharge			24.4	26	99.43%		
Severn Trent Water	LANEHAM - MAIN STREET (SPS)	T/69/46318/O	A1			67.2	14	100.00%		2020
Severn Trent Water	LANGAR (STW)	T/66/46151/R	A2			149.2	35	99.98%		2020
Severn Trent Water	LANGHAM (STW)	T/54/45998/R	A2			106.7	22	100.00%		2020
Severn Trent Water	LANGLEY MILL - CROMFORD RD (CSO)	T/61/21599/O	Single Discharge			2.9	2	91.25%		2020
Severn Trent Water	LANGLEY MILL - CROMFORD ROAD 96 (CSO)	T/61/12266/O	Single Discharge			207.5	65	99.99%		
Severn Trent Water	LANGLEY MILL - LEA LANE 78B (CSO)	T/61/02160/O	Single Discharge			138.6	77	99.99%		
Severn Trent Water	LANGLEY MILL - ROSEWOOD CRES 13 (CSO)	T/61/21526/O	Single Discharge			1.3	2	91.35%		2020
Severn Trent Water	LANGLEY MILL - STATION ROAD 208 (CSO)	T/61/12267/O	Single Discharge			32.5	33	93.12%		2020
Severn Trent Water	LAVERTON (STW)	S/18/25216/R	A2			929.8	83	99.98%		2020
Severn Trent Water	Lawley Middleway CSO	No known permit reference	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	LAXTON (STW)	T/69/45349/R	A2			91.2	20	100.00%		2020
Severn Trent Water	LEACH HEATH LANE CSO (RUBERY - LEACH HEATH LANE (CSO))	T/09/36064/O	Single Discharge			18.3	25	99.98%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	LEAMINGTON - ADELAIDE RD (CSO)	S/12/20261/O	Single Discharge			20.1	10	100.00%		
Severn Trent Water	LEAMINGTON - PARADE/REGENT GROVE (CSO)	S/12/20259/O	Single Discharge			0.0	0	99.89%		
Severn Trent Water	LEASOW DRIVE COMBINED SEWAGE O'FLOW (SELLY OAK - LEASOW DRIVE (CSO))	T/09/36344/O	Single Discharge			0.0	0	100.00%		
Severn Trent Water	LEDBURY - LOWER RD TRADING EST (CSO)	S/21/23083/O	Single Discharge			33.6	6	99.99%		2020
Severn Trent Water	LEDBURY (STW)	S/21/26211/R	A2			220.5	48	100.00%		2020
Severn Trent Water	LEEK - MACCLESFIELD ROAD (CSO)	T/30/03561/O-2	Single Discharge			75.3	40	99.99%		
Severn Trent Water	LEEK - NORTH STREET (CSO)	T/30/30328/O	Single Discharge			15.1	41	99.91%		
Severn Trent Water	LEEK - VICARAGE ROAD 2 (CSO)	T/30/30223/O	Single Discharge			52.0	51	97.37%		
Severn Trent Water	LEEK (STW)	T/30/36067/R	A2			78.3	13	99.17%		2020
Severn Trent Water	LEICESTER - BEATRICE RD/HAWTHORNE ST (CSO)	TSC898	Single Discharge			1.2	11	100.00%		
Severn Trent Water	LEICESTER - BEATRICE RD/SYLVAN ST (CSO)	T/53/21281/O	Single Discharge			1.2	12	91.08%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	LEICESTER - RAW DYKES ROAD (CSO)	T/52/46106/O	Single Discharge			26.5	12	97.49%		
Severn Trent Water	Leicester Bridge O/L G SSO	T/55/03724/O-8	Single Discharge			20.4	12	98.57%		2020
Severn Trent Water	LEICESTER FOREST W - DESFORD X-RD (CSO)	T/56/02605/O-12	A1			1372.1	83	99.52%		2020
Severn Trent Water	LENCHWICK PUMPING STATION (SPS) (LENCHWICK - MAIN ROAD (SPS))	S/17/26190/O	A1			24.2	3	96.33%		
Severn Trent Water	LENTON - LENTON BLVD/SHERWIN RD (CSO)	T/63/22909/O	Single Discharge			21.8	11	86.80%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	LEONARD STANLEY - STANLEY DOWNTON (CSO)	S/22/20978/O	Single Discharge			100.4	32	99.99%		
Severn Trent Water	LETWELL (STW)	T/76/45987/R	A2			202.7	9	100.00%		2020
Severn Trent Water	LEWIS CLOSE PUMPING STATION (Lewis Close Drakes Broughton PS)	S/19/26045/O	A1			109.4	13	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	LICHFIELD - NETHERSTOWE (CSO)	T/07/01441/O & TSC1345	Single Discharge			0.0	0	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	LICHFIELD - ST JOHN STREET (CSO)	No known permit reference	Single Discharge			0.0	0	99.99%		2020
Severn Trent Water	LICHFIELD - THE FRIARY (CSO)	No known permit reference	Single Discharge			0.2	1	99.85%		2020
Severn Trent Water	LICHFIELD (STW)	T/07/36033/R	A3			3.9	1	100.00%		2020
Severn Trent Water	LICHFIELD SEWAGE TREATMENT WORKS (LICHFIELD (Sewage Treatment Works))	T/07/36033/R	A2			13.0	16	100.00%		
Severn Trent Water	LIFFORD - ALLENSCROFT ROAD (CSO)	T/09/36383/O	Single Discharge			28.7	24	90.19%		2020
Severn Trent Water	LIGHTHORNE HEATH Sewage Treatment Works (LIGHTHORNE HEATH (Sewage Treatment Works))	S/13/25884/R	A2			59.3	38	99.91%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	LIGHTHORNE SEWAGE PUMPING STATION (LIGHTHORNE - MORTON MORRELL LANE (SPS))	S/13/23222/O	Single Discharge			25.3	13	100.00%		
Severn Trent Water	LILBOURNE (STW)	S/10/26161/R	A2			425.2	65	99.75%		2020
Severn Trent Water	LINGFIELD DRIVE (GREAT WYRLEY - LINGFIELD DRIVE (CSO))	T/03/30261/O	Single Discharge			36.6	25	95.36%		
Severn Trent Water	LINTON SOUTH (LINTON - COLLIERY LANE (SPS))	T/24/07093/O	A1			24.4	20	100.00%		
Severn Trent Water	Lion Fields Avenue / Birmingham Road CSO	No known permit reference	Single Discharge			13.6	2	99.98%		2020
Severn Trent Water	LITTLE ASTON (STW)	T/17/35743/R	A2			198.4	33	100.00%		2020
Severn Trent Water	LITTLE BLOXWICH - LIVINGSTONE ROAD (CSO)	T/08/35059/O	Single Discharge			756.3	58	99.92%		
Severn Trent Water	LITTLE EATON SPS - STM/EMERGENCY of (LITTLE EATON (SPS))	T/45/12100/O	Single Discharge			0.0	0	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	Little Glen Rd Glen Parva PS	T/52/03045/O-3	A1			121.5	10	99.91%		
Severn Trent Water	LITTLE KINETON - BRIDGE STREET (CSO)	S/13/20327/O	Single Discharge			4.2	1	99.99%		
Severn Trent Water	LITTLE MARCLE RD LEDBURY (TPS)	S/21/26218/O	Single Discharge			73.2	18	99.96%		2020
Severn Trent Water	LITTLE STRETTON (STW)	T/51/46383/R	A2			285.2	48	100.00%		2020
Severn Trent Water	LITTLEDEAN (STW)	S/20/26168/R	A2			15.7	3	100.00%		2020
Severn Trent Water	LITTLETHORPE - STATION ROAD (CSO)	DT/8040	Single Discharge			91.7	13	99.99%		
Severn Trent Water	Littleworth PS	S/17/25586/O	A2			166.7	16	100.00%		2020
Severn Trent Water	LITTON - BUXTON ROAD/LITTON DALE (CSO)	T/39/46153/O	Single Discharge			6.8	7	99.61%		
Severn Trent Water	Lodge Road	No known permit reference	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	LOGGERHEADS - PRICE CLOSE (CSO)	S/04/20963/O	Single Discharge			0.0	0	99.35%		
Severn Trent Water	LOGGERHEADS VILLAGE (STW)	S/04/55884/R	A2			105.5	19	99.88%		2020
Severn Trent Water	Long Acre CSO A	No known permit reference	Single Discharge			0.0	0	99.61%		2020
Severn Trent Water	LONG CLAWSON - HOSE LANE (SPS)	T/66/07371/O-1	Single Discharge			91.2	17	100.00%		2020
Severn Trent Water	Long Lane CSO	No known permit reference	Single Discharge			3.6	8	99.89%		2020
Severn Trent Water	LONG LAWFORD (SPS) ex STW	S/10/26066/R	Single Discharge			3093.8	155	99.81%		2020
Severn Trent Water	LONG MARSTON Sewage Treatment Works (LONG MARSTON (Sewage Treatment Works))	S/13/26592/R	A2			49.3	4	100.00%		
Severn Trent Water	LONG WHATTON Sewage Treatment Works (LONG WHATTON (Sewage Treatment Works))	T/57/08423/R	A2			982.4	204	100.00%		
Severn Trent Water	LONGBOAT LANE (SPS)	TSC3591	A1			0.1	1	98.09%		2020
Severn Trent Water	LONGBRIDGE - TURVES GREEN (CSO)	DT/9871	Single Discharge			8.0	14	99.60%		2020
Severn Trent Water	Longden Coleham Shrewsbury PS	NPSWQD005469	Single Discharge			729.9	62	99.99%		
Severn Trent Water	LONGHOPE (STW)	S/20/08537/R	A2			457.9	39	100.00%		2020
Severn Trent Water	LONGTON - CAROLINE ST (CSO)	T/01/07540/O	Single Discharge			1.8	9	99.80%		
Severn Trent Water	LONGTON - SUTHERLAND RD (CSO)	T/01/36478/O	Single Discharge			6.7	17	99.99%		
Severn Trent Water	LOOMER ROAD SPS (Loomer Rd Chesterton PS)	T/01/30243/O	A1			0.0	0	96.43%		
Severn Trent Water	LOSCOE - HIGH ST/SPRINGFIELD AVE (CSO)	T/61/21520/O	Single Discharge			0.0	0	99.95%		2020
Severn Trent Water	Love Lane Rugeley PS	T/05/35792/O	Single Discharge			0.8	1	99.88%		2020
Severn Trent Water	LOW BURNHAM - BECK LANE (SPS)	TSC3082	A1			0.0	0	100.00%		2020
Severn Trent Water	LOWER BINTON - EVESHAM ROAD 177 (CSO)	S/13/09239/O	Single Discharge			149.7	18	81.09%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	LOWER BRADLEY - GREAT BRIDGE ROAD (CSO)	T/08/36416/O	Single Discharge			3.9	2	99.99%		
Severn Trent Water	LOWER GORNAL (STW)	EPRWB3835AM	A3			0.0	0	100.00%		2020
Severn Trent Water	LOWER GORNAL Sewage Treatment Works (LOWER GORNAL (Sewage Treatment Works))	EPRWB3835AM	A2			75.8	35	99.91%		
Severn Trent Water	LOWER HARTSHAY - BRIDLE LANE (SPS)	TSC3602	A1			679.9	31	99.76%		2020
Severn Trent Water	LOWER HIGH STREET STORM OVERFLOW (STOURBRIDGE - LOWER HIGH STREET (CSO))	S/06/21181/O	Single Discharge			34.4	9	100.00%		
Severn Trent Water	LOWER LODE LANE PUMPING STATION (TEWKESBURY - LOWER LODE (SPS))	S/17/26249/O	Single Discharge			1303.7	99	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	LOWER MOOR Sewage Treatment Works (LOWER MOOR (Sewage Treatment Works))	S/17/25770/R	A2			2299.1	136	100.00%		
Severn Trent Water	LOWER OXFORD ROAD SSO (ETRURIA - ETRURIA ROAD (CSO))	T/01/22738/O	Single Discharge			50.2	38	100.00%		
Severn Trent Water	LOWER PENKRIDGE PUMPING STATION (ACTON TRUSSELL - LWR PENKRIDGE RD (SPS))	T/03/12334/O	A1			4.7	3	100.00%		
Severn Trent Water	LOWER TYSOE - STW (CSO)	S/14/09255/O	A2			566.1	66	96.50%		2020
Severn Trent Water	LUDFORD SPS - EMERG O/F & STORM O/F (LUDLOW - LUDFORD BRIDGE (SPS))	S/09/12194/O	A1			13.3	5	99.43%		
Severn Trent Water	LUDLOW - OLD STREET (CSO)	282/3/2	Single Discharge			64.4	14	99.99%		
Severn Trent Water	LUDLOW - THE LINNEY (CSO)	282/3	Single Discharge			82.7	12	99.92%		
Severn Trent Water	LUDLOW SEWAGE TREATMENT WORKS (LUDLOW (Sewage Treatment Works))	S/09/55809/R	A2			1559.7	98	100.00%		
Severn Trent Water	LUTTERWORTH (STW)	S/10/26704/R	A2			490.7	50	99.87%		2020
Severn Trent Water	Lutterworth Rd Brinklow PS	S/11/23198/O	A1			0.0	0	100.00%		2020
Severn Trent Water	Lychgate Lane/Woodstock Cl Burbage CSO	T/50/08892/O	Single Discharge			6.8	20	99.83%		2020
Severn Trent Water	LYDNEY - CHURCH ROAD (CSO)	S/20/26052/O-2	Single Discharge			110.9	41	99.87%		
Severn Trent Water	LYDNEY - EAST MARSH (SPS)	S/20/26052/O-1	A1			255.6	18	100.00%		2020
Severn Trent Water	LYDNEY - TUTNALLS ST/HAMS RD (CSO)	S/20/05156/O	Single Discharge			45.2	17	99.97%		
Severn Trent Water	LYDNEY (STW)	S/20/26643/R	A2			1233.2	102	100.00%		2020
Severn Trent Water	LYME VALLEY (HOMEBASE) CSO (NEWCASTLE - CLAYTON ROAD (CSO))	T/01/36239/O	Single Discharge			39.8	36	99.97%		
Severn Trent Water	LYME VALLEY-OPP REMPLOY WORKS-CRIT (CSO)	T/01/36237/O	Single Discharge			67.5	20	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MACDONALD STREET CSO 1 (DIGBETH - MACDONALD STREET O/L 1 (CSO))	EPRKP3223KZ	Single Discharge			57.8	46	100.00%		
Severn Trent Water	MACDONALD STREET CSO 2 (DIGBETH - MACDONALD STREET O/L 2 (CSO))	EPRKP3223XS	Single Discharge			1.8	3	99.91%		
Severn Trent Water	MADELEY - PARK AVENUE (CSO)	S/02/55675/O	Single Discharge			3.9	18	99.99%		
Severn Trent Water	MADRESFIELD - HALL GREEN (TPS)	S/08/26255/O	A1			911.2	79	99.99%		2020
Severn Trent Water	MADRESFIELD WATERLOO CLOS (STW)	S/08/25823/R	A2			609.5	64	99.96%		2020
Severn Trent Water	Main Rd Nether Langwith CSO	T/73/20354/O	Single Discharge			114.7	55	99.99%		
Severn Trent Water	MAIN ROAD STORM OVERFLOW (GEDLING - MAIN ROAD (CSO))	T/64/21205/O	Single Discharge			13.2	12	99.55%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	Main St / Linby St, Bulwell	No known permit reference	Single Discharge			0.0	0	99.46%		2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	MALTBY - BLYTH ROAD/MEADOW LANE 1 (CSO)	T/83/40035/O	Single Discharge			0.5	1	99.99%		
Severn Trent Water	MALTBY - BLYTH ROAD/MEADOW LANE 2 (CSO)	T/76/40099/O	Single Discharge			1.1	2	99.86%		
Severn Trent Water	MALTBY - LOW COMMON (TPS)	T/83/07438/O	A1			2.0	6	99.99%		2020
Severn Trent Water	MALVERN - BLACKMORE PARK (CSO)	S/08/22500/O	Single Discharge			17.8	3	100.00%		2020
Severn Trent Water	MALVERN - CHANCE LANE (CSO)	S/08/20890/O	Single Discharge			0.6	1	99.97%		2020
Severn Trent Water	MALVERN - COCKSHOT RD (CSO)	S/08/26248/O	Single Discharge			29.5	14	99.88%		2020
Severn Trent Water	MALVERN - PICKERSLEIGH RD (CSO)	S/08/05545/O	Single Discharge			6.3	1	100.00%		2020
Severn Trent Water	MALVERN (STW)	S/08/26522/R	A2			407.2	27	100.00%		2020
Severn Trent Water	MALVERN (STW)	S/08/26522/R	A3			78.6	10	100.00%		2020
Severn Trent Water	MALVERN WELLS - SHUTTLEFAST FARM (CSO)	S/08/04615/O	Single Discharge			35.1	4	99.99%		
Severn Trent Water	MANOR HOUSE FARM (MAPLETON (TPS))	T/29/07985/O	A1			202.0	21	100.00%		
Severn Trent Water	MANSF WOODHOUSE - LEEMING LN (CSO)	T/71/07550/O	Single Discharge			36.8	22	99.98%		2020
Severn Trent Water	MANSF. WOODHOUSE - CHURCH ST (CSO)	T/71/09179/O-2	Single Discharge			0.0	0	99.97%		2020
Severn Trent Water	MANSF. WOODHOUSE - OLD MILL LN (CSO)	No known permit reference	Single Discharge			10.4	19	99.98%		2020
Severn Trent Water	MANSF. WOODHOUSE - PARK HALL RD 86 (CSO)	T/71/40173/O	Single Discharge			426.8	22	97.97%		
Severn Trent Water	MANSF. WOODHOUSE - WARSOP RD (CSO)	T/71/46331/O	Single Discharge			0.0	0	99.89%		
Severn Trent Water	MANSFIELD - BATH LANE (STW)	T/70/46165/R	A2			43.6	63	99.95%		2020
Severn Trent Water	MANSFIELD - OXCLOSE LANE (SPS)	T/71/08882/O	A1			164.3	24	98.36%		
Severn Trent Water	MANSFIELD - RANDOL CLOSE 10 (CSO)	T/70/03474/O	Single Discharge			11.5	11	99.99%		2020
Severn Trent Water	MANSFIELD - SHEEPBRIDGE LANE 1 (CSO)	T/70/07519/O & T/70/03244/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	MANSFIELD - SHEEPBRIDGE LANE 2 (CSO)	T/70/07519/O & T/70/03244/O	Single Discharge			0.8	3	99.99%		2020
Severn Trent Water	MANSFIELD WOODHOUSE - ALBERT SQ (CSO)	T/71/09179/O-1	Single Discharge			32.4	20	93.54%		
Severn Trent Water	MANSFIELD WOODHOUSE - SWAN LANE (CSO)	T/71/20185/O	Single Discharge			0.4	2	99.93%		2020
Severn Trent Water	MANSFIELD WOODHOUSE - WARSOP RD (CSO)	T/71/46325/O	Single Discharge			2.1	11	99.95%		2020
Severn Trent Water	MANSFIELD WOODHOUSE - WELLS CL 12 (CSO)	T/71/07945/O	Single Discharge			19.7	11	99.99%		2020
Severn Trent Water	MARCHINGTON - SILVER LANE (SPS)	TSC3889	A1			0.0	0	100.00%		2020
Severn Trent Water	Marchington CSO	T/33/30319/O	Single Discharge			10.0	3	100.00%		2020
Severn Trent Water	MARCHINGTON Sewage Treatment Works (MARCHINGTON (Sewage Treatment Works))	T/33/36156/R	A2			1283.9	79	99.97%		
Severn Trent Water	MAREHAY (STW)	T/45/45471/R	A2			684.2	59	100.00%		2020
Severn Trent Water	MAREHAY (STW)	T/45/45471/R	A3			3.5	8	100.00%		2020
Severn Trent Water	MARKET BOSWORTH Sewage Treatment Works (MARKET BOSWORTH (Sewage Treatment Works))	T/20/35543/R	A2			1327.9	89	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MARKET DRAYTON - FLASH LANE (SPS)	TSC752	A1			0.0	0	100.00%		2020
Severn Trent Water	MARKET DRAYTON (STW)	S/04/56026/R	A2			24.0	24	100.00%		2020
Severn Trent Water	MARKET OVERTON (STW)	T/54/45475/R	A2			15.1	9	99.64%		2020
Severn Trent Water	MARKET PLACE - GREAT BRIDGE (CSO)	T/08/21234/O	Single Discharge			3.9	7	99.97%		
Severn Trent Water	MARKET STREET (LICHFIELD - MARKET STREET 39 (CSO))	T/07/22060/O	Single Discharge			1.1	2	99.55%		
Severn Trent Water	MARKET WARSOP - THE HAWTHORNS (CSO)	T/71/08687/O-3	Single Discharge			0.4	1	99.99%		2020
Severn Trent Water	MARKFIELD ROAD PUMPING STATION (GROBY - BRS A50 (SPS))	T/56/40158/O	Single Discharge			177.3	31	99.95%		
Severn Trent Water	MARLPOOL - BUXTON AVENUE PS (CSO)	T/61/40154/O	A1			7.7	6	100.00%		2020
Severn Trent Water	MARSONS GARAGE,NEWCASTLE-U-L (NEWCASTLE - THE HIGHERLAND (SOUTH) (CSO))	T/01/21606/O	Single Discharge			211.4	22	97.57%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MARSTON GREEN - HOLLY LANE (CSO)	T/12/03702/O-4	Single Discharge			0.0	0	100.00%		
Severn Trent Water	MARSTON GRN - COLESHILL RD 1 (SO)	T/12/03702/O-2 & TSC534	Single Discharge			0.0	0	99.80%		2020
Severn Trent Water	MARSTON GRN - COLESHILL RD 2 (SO)	T/12/03702/O-3	Single Discharge			0.0	0	99.98%		
Severn Trent Water	MARSTON LANE BEDWORTH (STW)	T/19/36017/R	A3			0.0	0	100.00%		2020
Severn Trent Water	MARSTON MONTGOMERY (STW)	T/33/35557/R	A2			229.5	128	97.46%		2020
Severn Trent Water	MATLCK BTH-DALE RD (CABLE CR BRDG) (CSO)	DT/2180	Single Discharge			13.0	14	99.86%		2020
Severn Trent Water	MATLOCK - DALE ROAD (SPS)	TSC3301	A1			30.6	74	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	MATLOCK - IMPERIAL RD CSO	T/40/01693/O-1	Single Discharge			74.0	34	58.84%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MATLOCK - KNOWLESTON PLACE - SPS/SSO	T/40/07898/O	A1			11.6	15	99.99%		
Severn Trent Water	MATLOCK - LEA BRIDGE (SPS)	TSC3559	A1			0.0	0	99.72%		2020
Severn Trent Water	MATLOCK - STONEY WAY CSO	T/40/12380/O	Single Discharge			87.9	30	99.99%		
Severn Trent Water	MATLOCK BATH - STATION YARD (SPS)	TSC3639	A1			0.0	0	99.94%		2020
Severn Trent Water	MATLOCK GREEN_MORNINGTON RISE CSO	DT/2174	Single Discharge			4.1	4	99.97%		
Severn Trent Water	MATLOCK LEA (STW)	T/40/08170/R	A2			1446.2	77	100.00%		2020
Severn Trent Water	MATLOCK_BAKEWELL RD / DIMPLE ROAD CSO	DT/2168	Single Discharge			2.6	20	83.72%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MATLOCK_MATLOCK GREEN/LIME TREE RD CSO	DT/2173	Single Discharge			0.0	0	99.95%		
Severn Trent Water	MATLOCK_WEBSTERS TERRACE_OS PARK HSE_ALFRETON RD CSO	TSC2088	Single Discharge			0.0	0	99.99%		
Severn Trent Water	MATTERSEY - CHURCH HOUSE (SPS)	T/74/40055/O	A1			0.0	0	100.00%		2020
Severn Trent Water	MAYFIELD (STW)	T/29/35581/R	A3			0.0	0	100.00%		2020
Severn Trent Water	MAYFIELD Sewage Treatment Works (MAYFIELD (Sewage Treatment Works))	T/29/35581/R	A2			265.9	50	99.92%		
Severn Trent Water	MEADOW ROAD SPS (DERBY - MEADOW ROAD (SPS))	T/48/45234/O	A1			766.1	34	100.00%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	MEADOWS - TURNEY STREET & ARKWRIGHT STREET CSO	T/64/22903/O	Single Discharge			95.0	18	82.01%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MEAFORD SPS (MEAFORD - A34 (SPS))	T/01/30303/O	A1			0.0	0	99.82%		
Severn Trent Water	MEASHAM - CHAPEL STREET (CSO)	T/23/08998/O	Single Discharge			0.0	0	94.55%		2020
Severn Trent Water	MEASHAM (SPS)	T/23/36411/O	A1			3.0	2	100.00%		2020
Severn Trent Water	MEDEN VALE - WELBECK (SPS)	T/71/02650/O-6 & TSC1343	A1			2.7	8	100.00%		2020
Severn Trent Water	Melbourne Rd	No known permit reference	Single Discharge			0.0	0	97.82%		2020
Severn Trent Water	MELLOR STREET/HANDLEY STREET/ (PACKMOOR - BULL LA/MELLOR ST 97 (CSO))	T/01/36257/O	Single Discharge			0.5	1	99.84%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MELTON - NOTTINGHAM RD/WELBY LN (CSO)	T/55/02986/O-1	Single Discharge			4.5	5	82.78%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MELTON MOWBRAY - SCALFORD ROAD (CSO)	T/55/02986/O	Single Discharge			29.6	16	82.81%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MELTON MOWBRAY AREAS/STM-EMG-SWS (Leicester Bridge O/L F SSO)	T/55/03724/O-7	Single Discharge			0.0	0	99.17%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MELTON MOWBRAY AREAS/STM-EMG-SWS (MELTON - ASFORDBY ROAD 137 (CSO))	T/55/03724/O	Single Discharge			170.4	73	100.00%		
Severn Trent Water	MELTON MOWBRAY PS - STORM/EMERG of (HOBY - BROOKSBY ROAD (SPS))	T/55/02608/O-4	A1			65.5	17	99.91%		
Severn Trent Water	MELTON MOWBRAY Sewage Treatment Works (MELTON (Sewage Treatment Works))	T/55/45835/R	A2			308.4	44	100.00%		
Severn Trent Water	MERCHANT AVENUE - STM O/F - SWS (SPONDON - DERBY RD/MERCHANT AVE (CSO))	T/48/20194/O	Single Discharge			94.5	11	99.69%		
Severn Trent Water	MERRFIELDS FARM - STORM OVERFLOW (MARCLIFF - MERRYFIELDS FARM (SPS))	S/13/07698/O	Single Discharge			384.9	26	99.91%		
Severn Trent Water	MICHELIN A34-CRITICAL (CSO)	T/01/35892/O	Single Discharge			19.6	24	99.98%		
Severn Trent Water	MICKLEOVER - BRIERFIELD WAY (CSO)	T/36/07474/O	Single Discharge			2.6	3	98.70%		
Severn Trent Water	MICKLEOVER - DRESDEN CLOSE 20 (CSO)	T/36/07857/O	Single Discharge			15.9	8	99.96%		
Severn Trent Water	MICKLEOVER - MELBOURNE CLOSE (SPS)	T/36/01407/B	Single Discharge			8.2	2	99.88%		2020
Severn Trent Water	MICKLEOVER - SANDOWN AVENUE (SPS)	T/36/02736/O	A1			0.0	0	100.00%		2020
Severn Trent Water	MICKLETON - COTSWOLD EDGE (CSO)	S/13/09102/O	Single Discharge			39.5	7	99.99%		
Severn Trent Water	MIDDLE ACRE ROAD/MILL LANE CSO (BARTLEY GREEN - MIDDLE ACRE RD (CSO))	T/09/36382/O	Single Discharge			0.1	1	99.72%		
Severn Trent Water	MIDDLE ACRE ROAD/MILL LANE CSO (BARTLEY GREEN - SENNELEYS PARK (CSO))	T/09/21593/O	Single Discharge			0.0	0	100.00%		
Severn Trent Water	MIDDLETON VILLAGE (STW)	T/16/35964/R	A2			78.5	26	99.98%		2020
Severn Trent Water	MILE OAK (STW)	S/01/55211/R	A2			443.7	63	100.00%		2020
Severn Trent Water	MILL LANE PUMPING STATION (HALFORD - MILL LANE (SPS))	S/14/12195/O	Single Discharge			67.8	7	99.89%		
Severn Trent Water	Milnhay Rd Langley Mill CSO	T/61/12268/O	Single Discharge			2.0	1	99.99%		2020
Severn Trent Water	MILTON - GAYTON AVENUE (CSO)	T/01/36406/O	Single Discharge			51.9	66	99.75%		
Severn Trent Water	MILTON WASTE WATER TREATMENT WORKS (MILTON (Sewage Treatment Works))	T/36/45730/R	A2			1577.9	99	90.28%		
Severn Trent Water	MINSTERLEY - THE GROVE (TPS)	S/02/50017/O	Single Discharge			180.4	16	99.15%		2020
Severn Trent Water	MINWORTH SEWAGE TREATMENT WORKS (MINWORTH (Sewage Treatment Works))	T/10/36212/R	A2			314.4	42	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MOIRA - ASHBY ROAD (CSO)	T/23/12399/O	Single Discharge			0.0	0	100.00%		
Severn Trent Water	Moira SSO	T/23/00115/O	A1			0.0	0	98.55%		2020
Severn Trent Water	MONK ST/KING ALFRED ST JCN SSO (DERBY - MONK ST/KING ALFRED ST (CSO))	T/47/22337/O	Single Discharge			2.8	4	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MONKMOOR (STW)	S/02/56373/R	A4			7.4	4	100.00%		2020
Severn Trent Water	MOORPOOL AVENUE CSO (HARBORNE - MOORPOOL AVENUE (CSO))	T/09/36431/O	Single Discharge			0.0	0	99.90%		
Severn Trent Water	MORETON PADDOX (STW)	S/13/25818/R	A2			203.4	63	100.00%		2020
Severn Trent Water	MORTON - STATION ROAD (SPS)	2419/5	A1			0.0	0	100.00%		
Severn Trent Water	MORTON - WILSONS LANE (SPS)	TSC3678	A1			0.0	0	92.33%		2020
Severn Trent Water	MUCH WENLOCK (STW)	S/02/55942/R	A2			462.7	27	100.00%		2020
Severn Trent Water	NAILSTONE (TPS)	T/20/30309/O	A1			4.4	4	91.20%		2020
Severn Trent Water	NAILSWORTH - OLD MARKET (CSO)	S/22/20943/O	Single Discharge			8.9	12	100.00%		2020
Severn Trent Water	Nailsworth Valley Sewer	S/22/05539/O	Single Discharge			22.0	23	99.83%		2020
Severn Trent Water	NARBOROUGH - BELL LANE (CSO)	DT/8041	Single Discharge			0.0	0	99.98%		
Severn Trent Water	NARBOROUGH - COV RD (MELAS) PS (CSO)	T/50/01625/O	A1			0.0	0	99.15%		
Severn Trent Water	NARBOROUGH - COVENTRY ROAD (CSO)	DT/8039	Single Discharge			0.0	0	99.71%		
Severn Trent Water	NARBOROUGH - FOREST ROAD (CSO)	T/50/40087/O	Single Discharge			130.0	47	99.97%		
Severn Trent Water	NARBOROUGH - STEWART AVENUE (CSO)	DT/8038	Single Discharge			29.9	36	90.09%		
Severn Trent Water	Narborough Park PS	T/50/07064/O	A1			530.7	73	99.85%		
Severn Trent Water	NASEBY WRW (STW)	S/10/25789/R	A2			334.7	44	100.00%		2020
Severn Trent Water	NECHELLS - ARGYLE STREET (SPS)	DT/9774	Single Discharge			0.0	0	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	NECHELLS - MOUNT ST/NEEDHAM ST (CSO)	T/09/35021/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	NECHELLS - PLUME STREET (CSO)	DT/9775	Single Discharge			0.1	1	99.88%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	NETHER BROUGHTON (STW)	T/66/45637/R	A2			679.9	58	99.83%		2020
Severn Trent Water	NETHER HEAGE - DUNGLEY HILL (CSO)	T/41/46044/O	Single Discharge			153.3	27	99.82%		2020
Severn Trent Water	NETHER LANGWITH (STW)	T/73/45847/R	A2			1112.8	95	100.00%		2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	NETHERSEAL (STW)	T/23/35565/R	A2			207.7	22	100.00%		2020
Severn Trent Water	NEW ROAD PUMPING STATION (DUDLEY - NEW ROAD PS (CSO))	S/06/50091/O	A1			1.2	3	99.72%		
Severn Trent Water	NEWARK - BEACON HILL ROAD (CSO)	T/68/20850/O	Single Discharge			12.6	10	99.99%		
Severn Trent Water	NEWARK - BOUNDARY ROAD (CSO)	T/67/45246/O	Single Discharge			23.8	20	99.81%		2020
Severn Trent Water	NEWARK - BRUNEL DRIVE (CSO)	No known permit reference	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	NEWARK - MASSEY ST (CSO)	T/68/45965/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	NEWARK - NORTH GATE WHARF (CSO)	T/67/46057/O	Single Discharge			0.0	0	99.98%		2020
Severn Trent Water	NEWBOLD - AVON LANE (HANDS INLET) (CSO)	S/10/26458/O	Single Discharge			41.2	30	99.99%		
Severn Trent Water	NEWBOLD VERDON (STW)	T/50/45372/R	A2			0.0	0	100.00%		2020
Severn Trent Water	NEWBOLD VERDON 2 (CSO)	T/50/45425/O	Single Discharge			6.7	8	100.00%		2020
Severn Trent Water	NEWBOROUGH (STW)	T/07/35744/R	A2			152.0	19	100.00%		2020
Severn Trent Water	NEWENT - THE CROFT (CSO)	S/21/26432/O	Single Discharge			1130.2	208	99.97%		2020
Severn Trent Water	NEWENT (STW)	S/21/26094/R	A2			192.7	24	99.99%		2020
Severn Trent Water	NEWTHORPE - BAKER ROAD (CSO)	T/61/12391/O	Single Discharge			0.7	2	99.98%		2020
Severn Trent Water	NEWTHORPE (STW)	T/61/45995/R	A2			260.4	29	100.00%		2020
Severn Trent Water	NEWTHORPE (STW)	T/61/45995/R	A3			20.6	6	100.00%		2020
Severn Trent Water	NEWTON REGIS (SPS)	T/21/00159/R-1	Single Discharge			163.2	40	99.89%		
Severn Trent Water	NEWTONS LANE/AWSWORTH LANE JCN SSO (AWSWORTH - THE LANE/NEWTONS LANE (CSO))	T/61/40283/O	Single Discharge			0.9	2	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	NEWTOWN - ELKINGTON ST/ASTON BROOK (CSO)	T/09/01056/O-3	Single Discharge			2.5	6	99.74%		
Severn Trent Water	NEWTOWN - LOWER TOWER ST (CSO)	T/09/35897/O	Single Discharge			0.3	4	99.99%		
Severn Trent Water	NEWTOWN - MILTON STREET (CSO)	T/09/21431/O	Single Discharge			1799.3	126	99.68%		
Severn Trent Water	NEWTOWN - SMITH ST/HOCKLEY ST (CSO)	T/09/21165/O	Single Discharge			103.6	55	99.98%		
Severn Trent Water	NEWTOWN - WALSALL ROAD/LONG LANE (CSO)	T/03/02997/O & T/03/30113/O	Single Discharge			176.2	23	99.73%		
Severn Trent Water	NEWTOWN LANE STORM OVERFLOW (CRADLEY HEATH - NEWTOWN LANE (CSO))	S/06/21041/O	Single Discharge			0.4	1	100.00%		
Severn Trent Water	NEWTOWN LINDFORD PUMPING STATION (NEWTOWN LINFORD - BRADGATE ROAD (SPS))	T/57/01286/O	A1			151.3	34	99.96%		
Severn Trent Water	Next to No.19 Retford Road	No known permit reference	Single Discharge			2.2	6	99.99%		2020
Severn Trent Water	NO.15 GREEN LANES CSO (ERDINGTON - GREEN LANES (CSO))	T/10/35737/O	Single Discharge			0.2	1	99.97%		
Severn Trent Water	NO.266 WALSALL ROAD (GREAT WYRLEY - WALSALL ROAD 266 (CSO))	T/03/21370/O	Single Discharge			44.5	39	99.99%		
Severn Trent Water	NO.36 HILTON LANE (GREAT WYRLEY - HILTON LANE 36 (CSO))	T/03/21371/O	Single Discharge			10.3	18	99.95%		
Severn Trent Water	NO.62 (NEWCASTLE - THE HIGHERLAND (NORTH) (CSO))	T/01/21605/O	Single Discharge			87.6	49	99.32%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	NORBURY (STW)	S/04/55587/R	A2			12.9	11	99.84%		2020
Severn Trent Water	NORMAN ROAD/ALEXANDER ROAD JCT SO(SMETHWICK - NORMAN RD/ALEXANDER RD (CSO))	T/08/21231/O	Single Discharge			1.2	1	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	NORMANTON ON TRENT - BROTTS ROAD (SPS)	TSC3175	A1			46.4	5	99.14%		2020
Severn Trent Water	NORMANTON-LE-HEATH - THE HOLLOW (SPS)	T/20/02775/O	A1			30.8	13	99.99%		2020
Severn Trent Water	NORTH ANSTON - RYTON ROAD PS (CSO)	T/75/12427/O	A1			25.1	18	99.98%		2020
Severn Trent Water	NORTH ASKHAM - TOWN STREET (SPS)	TSC4009	A1			5.8	5	100.00%		2020
Severn Trent Water	NORTH KILWORTH - CRANMER LANE (SPS)	TSC3277	A1			117.0	52	100.00%		2020
Severn Trent Water	North Road CSO	No known permit reference	Single Discharge			0.0	0	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	NORTH WARREN ROAD PUMPING STATION (GAINSBOROUGH - NORTH WARREN ROAD (TPS))	T/69/12378/O	Single Discharge			29.4	38	99.91%		
Severn Trent Water	NORTH WILLENHALL - BENTLEY ROAD (CSO)	T/08/36258/O	Single Discharge			11.1	4	99.98%		2020
Severn Trent Water	NORTHEND (STW)	S/13/25874/R	A2			918.2	221	100.00%		2020
Severn Trent Water	NORTHFIELD - CHURCH ROAD (CSO)	T/09/30214/O	Single Discharge			0.0	0	100.00%		
Severn Trent Water	NORTHFIELD - WEST HEATH 68 (CSO)	DT/9868	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	NORTHORPE (STW)	T/80/45645/R	A2			0.0	0	100.00%		2020
Severn Trent Water	NORTHWOOD - DALE ROAD NORTH (CSO)	817/2	Single Discharge			188.8	24	99.99%		
Severn Trent Water	NORTHWOOD - NORTHWOOD LANE (CSO)	T/40/21263/O	Single Discharge			1.4	9	83.51%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	NORTHWOOD - PRIME ST/CARDWELL ST (CSO)	T/01/36215/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	NORTHWOOD - PRIME ST/LOCKLEY ST (CSO)	T/01/36214/O	Single Discharge			0.0	0	99.99%		
Severn Trent Water	NORTHWOOD - ROSE STREET 106 (CSO)	T/01/36216/O	Single Discharge			0.1	3	99.81%		
Severn Trent Water	NORTON (STW)	T/73/45542/R	A2			411.8	83	99.93%		2020
Severn Trent Water	NORTON BRIDGE (STW)	T/02/35582/R	A2			0.0	1	99.57%		2020
Severn Trent Water	NORTON CANES PUMPING STATION (NORTON CANES - BETTYS LANE (SPS))	T/03/35596/O	A1			178.4	47	97.77%		
Severn Trent Water	NORTON GREEN - LITTLE HEAKLEY FARM (CSO)	T/01/36408/O	Single Discharge			38.4	23	99.98%		
Severn Trent Water	NORTON GREEN (STW)	T/11/35235/R	A2			507.4	48	100.00%		2020
Severn Trent Water	NORWELL - MAIN STREET (SPS)	TSC3621	A1			9.3	4	100.00%		2020
Severn Trent Water	NORWELL - SCHOOL LANE (SPS)	TSC3854	A1			0.0	0	97.49%		2020
Severn Trent Water	NOTTINGHAM - VALLEY ROAD/TENNIS COURTS (CSO)	T/63/12284/O	Single Discharge			0.7	2	100.00%		2020
Severn Trent Water	NOTTINGHAM (STOKE BARDOLPH) Sewage Treatment Works (STOKE BARDOLPH (Sewage Treatment Works))	T/64/45170/R	A2			241.9	16	98.53%		
Severn Trent Water	Nottingham Rd Southwell CSO	T/64/45275/O	Single Discharge			1.3	2	99.99%		2020
Severn Trent Water	NOTTINGHAM ROAD PUMPING STATION (OXTON - SOUTHWELL ROAD (SPS))	T/64/09313/O	A1			3.5	1	99.63%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	Nunts Lane CSO	No known permit reference	Single Discharge			0.0	0	99.98%		2020
Severn Trent Water	o/s 6 Maudslay Road, Coventry - may not be hydraulically req	No known permit reference	Single Discharge			1.0	2	99.99%		2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	o/s 6 Maudslay Road, Coventry - may not be hydraulically req	No known permit reference	Single Discharge			208.2	36	98.92%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	o/s Compound R/O Rectory Farm	T/32/36444/O	Single Discharge			54.6	18	99.63%		2020
Severn Trent Water	OAKAMOOR - CHURCH BANK (TPS)	T/30/36218/O	Single Discharge			0.5	2	100.00%		2020
Severn Trent Water	OCEAN BRIDGE STORM OVERFLOW (STONEHOUSE - OCEAN BRIDGE (CSO))	S/22/26210/O	Single Discharge			76.2	12	99.45%		
Severn Trent Water	ODSTONE (SPS)	T/20/00916/O	A1			654.2	37	100.00%		2020
Severn Trent Water	off BLURTON ROAD CSO (LONGTON - BLURTON ROAD (CSO))	T/01/35837/O	Single Discharge			12.1	30	99.82%		
Severn Trent Water	off WALKER DRIVE (A) CSO (SALTLEY - MINWORTH 14' Sewer (CSO))	TSC1716	Single Discharge			1.4	4	90.03%		
Severn Trent Water	Old Station Southwell CSO	T/64/02734/O-3	Single Discharge			42.6	15	95.58%		
Severn Trent Water	OLDBURY - CEMETERY RD/VICTORIA RD (CSO)	T/08/22245/O	Single Discharge			3.5	3	100.00%		2020
Severn Trent Water	OLDBURY - IZONS LANE (CSO)	T/08/02798/O	Single Discharge			100.6	55	99.86%		
Severn Trent Water	OLDBURY - WEST BROMWICH STREET (CSO)	T/08/02438/O	Single Discharge			0.0	0	99.63%		
Severn Trent Water	OLDCOTES - BLYTH ROAD (SPS)	TSC3125	A1			0.5	1	99.04%		2020
Severn Trent Water	OLDCROFT - OLD DAM ROAD (SPS)	S/20/25519/O	Single Discharge			291.5	13	99.97%		2020
Severn Trent Water	OLLERTON - WELLOW ROAD (CSO)	T/72/02535/O	Single Discharge			7.0	7	99.98%		
Severn Trent Water	OLTON - ULVERLEY GREEN ROAD 47 (CSO)	T/11/02240/O-3	Single Discharge			0.0	0	100.00%		
Severn Trent Water	OLTON - WAGON LANE (CSO)	DT/9735	Single Discharge			0.0	0	96.81%		
Severn Trent Water	OMBERSLEY (STW)	S/07/12734/R	A2			25.1	14	100.00%		2020
Severn Trent Water	Opp No. 777 Mansfield Road	No known permit reference	Single Discharge			0.9	1	99.81%		2020
Severn Trent Water	Orion Way/Huntington T SSO	T/03/21464/O & TSC400	Single Discharge			11.7	18	99.92%		
Severn Trent Water	ORTON-ON-THE-HILL Sewage Treatment Works (ORTON ON THE HILL (Sewage Treatment Works))	T/21/35938/R	A2			101.1	22	99.99%		
Severn Trent Water	OSBASTON HOLLOW PUMPING STATION (Osbaston Hollow PS)	T/20/02941/O	A1			0.0	0	100.00%		
Severn Trent Water	OSWESTRY - GOBOWEN RD (CSO)	S/03/21272/O	Single Discharge			1.4	4	99.97%		
Severn Trent Water	OSWESTRY - GOBOWEN RD/BEATRICE ST (CSO)	S/03/21273/O	Single Discharge			1.1	3	100.00%		2020
Severn Trent Water	OSWESTRY - SMITHFIELD MARKET CARPK (CSO)	S/01/55699/O	Single Discharge			895.5	81	100.00%		2020
Severn Trent Water	OULTON (SPS)	T/01/35124/O	A1			10.5	6	100.00%		2020
Severn Trent Water	OVERSEAL - MOIRA ROAD (SPS)	T/23/12322/O	A1			16.9	18	99.88%		2020
Severn Trent Water	OVERSEAL - SHORTHEATH (SPS)	T/23/20195/O	A1			0.0	0	100.00%		2020
Severn Trent Water	OVERSEAL (STW)	T/23/35544/R	A2			258.2	32	99.83%		2020
Severn Trent Water	OVERSEAL (STW)	T/23/35544/R	A3			2.2	6	100.00%		2020
Severn Trent Water	OVERTON HALL Sewage Treatment Works (ASHOVER - OVERTON HALL (Sewage Treatment Works))	T/41/45762/R	A2			358.9	60	100.00%		
Severn Trent Water	Oxford Street	No known permit reference	Single Discharge			801.1	38	100.00%		2020
Severn Trent Water	PACKINGTON - BABELAKE STREET (SPS)	T/23/36432/O	A1			0.0	0	93.98%		2020
Severn Trent Water	PACKINGTON (STW)	T/23/36076/R	A2			256.4	29	99.88%		2020
Severn Trent Water	PADDOCK LANE PUMPING STATION (STRATFORD - PADDOCK LANE (SPS))	S/13/08373/O-1	A1			164.2	44	95.62%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	PAINSWICK - STEPPING STONE LN (CSO)	S/22/20976/O	Single Discharge			54.4	6	99.98%		
Severn Trent Water	PANT PLAS CERRIG Sewage Treatment Works (PANT-PLAS CERRIG (Sewage Treatment Works))	S/01/56011/R	A2			1624.3	84	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	PARK LANE STORM OVERFLOW (PARK VILLAGE - PARK LANE (CSO))	S/06/20980/O	Single Discharge			10.4	3	99.92%		
Severn Trent Water	PARK PUMPING STATION (MARKET BOSWORTH - BOSWORTH PARK (SPS))	T/20/03106/O	A1			9.0	3	98.29%		
Severn Trent Water	PATTINGHAM (STW)	S/05/55412/R	A2			43.4	9	99.94%		2020
Severn Trent Water	PEBBLE CLOSE STORM OVERFLOW (STOURBRIDGE - PEBBLE CLOSE (CSO))	S/06/21182/O	Single Discharge			0.0	0	99.96%		
Severn Trent Water	PEBBLE MILL - PERSHORE ROAD (CSO)	DT/9846	Single Discharge			128.1	51	96.99%		2020
Severn Trent Water	PECKLETON (TPS)	T/50/01060/O	Single Discharge			2.6	3	99.97%		2020
Severn Trent Water	PELSALL - WOLVERHAMPTON RD (CSO)	T/08/35057/O	Single Discharge			0.5	1	94.05%		
Severn Trent Water	PENKHULL- PENKHULL NEW ROAD (CSO)	T/01/21322/O	Single Discharge			49.8	62	99.95%		
Severn Trent Water	PENKRIDGE SEWAGE TREATMENT WORKS (PENKRIDGE (Sewage Treatment Works))	T/03/35658/R	A2			1714.9	109	99.91%		
Severn Trent Water	PENN - OSBORNE ROAD 57 (CSO)	S/06/55302/O	Single Discharge			0.0	0	99.98%		
Severn Trent Water	PENN - STORM O/F VIA SURFACE WATER (BRADMORE - COALWAY RD/MYRTLE GROVE (CSO))	S/06/20319/O	Single Discharge			2.7	4	99.96%		
Severn Trent Water	PEOPLETON SEWAGE TREATMENT WORKS (PEOPLETON RBC (Sewage Treatment Works))	S/19/25426/R	A2			123.0	11	100.00%		
Severn Trent Water	PERRY BARR - PERRY PARK (CSO)	T/08/08559/O	Single Discharge			1.6	4	99.93%		2020
Severn Trent Water	PERRY CROFTS - FARM CLOSE PS (SO)	No known permit reference	A1			0.0	0	99.84%		2020
Severn Trent Water	PILHAM (STW)	T/80/45348/R	A2			19.9	11	99.99%		2020
Severn Trent Water	Pinewood Avenue #1	No known permit reference	Single Discharge			1.7	1	99.99%		2020
Severn Trent Water	PINXTON - STATION ROAD PS (CSO)	NPSWQD010460	A1			932.2	63	100.00%		2020
Severn Trent Water	PINXTON (STW)	T/61/46266/R	A2			602.8	48	100.00%		2020
Severn Trent Water	PIREHILL SEWAGE TREATMENT WORKS (PIREHILL (Sewage Treatment Works))	T/01/35916/R	A2			1408.2	90	99.99%		
Severn Trent Water	PITTS MILL (STW)	S/21/26069/R	A2			392.7	31	100.00%		2020
Severn Trent Water	PLEASLEY - JENKINS STREET (SPS)	T/71/46385/O	A1			35.6	8	100.00%		2020
Severn Trent Water	PLECK - WEDNESBURY ROAD (CSO)	T/08/35911/O	Single Discharge			15.2	5	99.89%		
Severn Trent Water	PLECK - WOLVERHAMPTON ROAD (CSO)	T/08/35135/O	Single Discharge			14.1	10	99.75%		2020
Severn Trent Water	POLESWORTH (STW)	T/21/35970/R	A3			0.0	0	100.00%		2020
Severn Trent Water	POLESWORTH SEWAGE TREATMENT WORKS (POLESWORTH (Sewage Treatment Works))	T/21/35970/R	A2			426.7	42	100.00%		
Severn Trent Water	PONTESBURY - STATION ROAD (CSO)	S/02/21987/O	Single Discharge			126.4	52	99.54%		
Severn Trent Water	PONTESBURY (STW)	S/02/56261/R	A2			508.7	44	99.99%		2020
Severn Trent Water	POPLAR CLOSE STORM OVERFLOW (BLYTHE BRIDGE - POPLAR CLOSE (CSO))	T/06/12868/O	Single Discharge			8.1	5	99.99%		
Severn Trent Water	Poplar Ln Sideway SSO	T/01/35062/O	Single Discharge			109.8	38	99.98%		
Severn Trent Water	PORT HILL INTERCEPTING Sewer (SHREWSBURY - EARLS VIEW HILL (CSO))	S/02/04974/O	Single Discharge			16.1	6	99.96%		
Severn Trent Water	PORTER ROAD AND ALMOND ROAD JCN SSO (NORMANTON - PORTER ROAD/ALMOND ST (CSO))	T/48/21200/O	Single Discharge			0.9	5	99.98%		
Severn Trent Water	PORTHILL - WATLANDS VIEW 4A (CSO)	T/01/21131/O	Single Discharge			0.6	12	99.94%		
Severn Trent Water	PORTHILL STORM SEWAGE OVERFLOW (PORTHILL - ORFORD STREET (CSO))	T/01/36418/O	Single Discharge			179.9	30	99.74%		
Severn Trent Water	PORTOBELLO - WILLENHALL ROAD (CSO)	T/08/21091/O	Single Discharge			3.2	2	100.00%		2020
Severn Trent Water	POTTERS CROSS (KINVER - MILL LANE (SPS))	S/06/07934/O-1	Single Discharge			305.0	82	99.98%		
Severn Trent Water	POTTERS LOCK PUMPING STATION (ILKESTON - POTTERS LOCK (SPS))	T/61/12364/O	A1			369.9	39	99.66%		
Severn Trent Water	POWICK Sewage Treatment Works (POWICK (Sewage Treatment Works))	S/08/25693/R	A2			908.9	69	99.89%		
Severn Trent Water	PREES - ADJ PUMPING STATION (CSO)	S/04/21583/O	Single Discharge			52.8	29	99.96%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	PRIEST BRIDGE (STW)	S/19/26264/R	A2			64.2	11	100.00%		2020
Severn Trent Water	Pump Lane CSO	No known permit reference	Single Discharge			4.0	4	100.00%		2020
Severn Trent Water	PYE BRIDGE (STW)	T/61/45143/R	A2			228.6	34	100.00%		2020
Severn Trent Water	Quakefield Road East Markham	No known permit reference	Single Discharge			6.4	7	100.00%		2020
Severn Trent Water	QUAY STREET (CSO)	RP3923KH	Single Discharge			13.3	8	100.00%		2020
Severn Trent Water	QUEDGELEY PUMPING STATION (QUEDGELEY (CRITICAL) (TPS))	S/20/26115/O	Single Discharge			662.1	35	100.00%		
Severn Trent Water	Queen Anne Street/Stoke Road	No known permit reference	Single Discharge			5.5	28	99.99%		2020
Severn Trent Water	QUORN/BARROW SPS -STORM/EMERG O/F (BARROW - PROCTORS PARK ROAD (SPS))	T/57/01373/O-3	A1			138.0	29	99.92%		
Severn Trent Water	R/O 1 Riverhead Close CSO	No known permit reference	Single Discharge			6.8	17	100.00%		2020
Severn Trent Water	RAD VALLEY Sewer AT THE ROCKS (SHREWSBURY - THE ROCKS (CSO))	S/02/04975/O	Single Discharge			84.1	20	99.75%		
Severn Trent Water	RADCLIFFE ON TRENT Sewage Treatment Works (RADCLIFFE-ON-TRENT (Sewage Treatment Works))	T/64/45783/R	A2			1299.6	101	100.00%		
Severn Trent Water	RADSTOCK AVENUE (BROMFORD - BROMFORD RD/BROMFORD LA (CSO))	T/10/09369/O	Single Discharge			106.7	10	100.00%		
Severn Trent Water	RADSTOCK AVENUE (BROMFORD - RADSTOCK AVE (CSO))	T/10/09369/O-3	Single Discharge			0.0	0	97.84%		
Severn Trent Water	RAGDALE Sewage Treatment Works (RAGDALE (Sewage Treatment Works))	T/55/45545/R	A2			801.5	61	99.97%		
Severn Trent Water	RAINWORTH (STW)	T/70/45715/R	A3			2.8	3	100.00%		2020
Severn Trent Water	RANSKILL (STW)	T/77/45889/R	A2			0.0	0	99.88%		2020
Severn Trent Water	RANTON - CHURCH CLOSE (TPS)	TSC3801	A1			119.5	20	99.84%		2020
Severn Trent Water	RATCLIFFE CULEY - MAIN ROAD (CSO)	T/20/21463/O	Single Discharge			42.1	8	99.98%		2020
Severn Trent Water	RAVENFIELD COMMON - BRAITHWELL RD (SPS)	T/76/03427/O	A1			33.8	11	100.00%		2020
Severn Trent Water	RAVENSTONE (STW)	T/20/35618/R	A2			1351.9	81	100.00%		2020
Severn Trent Water	Rear of No.27 Fairview Road	No known permit reference	Single Discharge			0.0	0	99.81%		2020
Severn Trent Water	REDDAL HILL ROAD STORM OVERFLOW (OLD HILL - REDDAL HILL ROAD (CSO))	S/06/21056/O	Single Discharge			0.0	0	99.86%		
Severn Trent Water	REDDITCH - SPERNAL (STW)	S/15/26260/R	A2			303.4	36	99.95%		2020
Severn Trent Water	REDMILE (STW)	T/66/46191/R	A2			90.4	15	99.93%		2020
Severn Trent Water	RETFORD - BOLHAM LANE PS (CSO)	T/74/02547/O	A1			27.7	9	100.00%		2020
Severn Trent Water	RETFORD - BRACKEN LANE (SPS)	T/74/02460/O-2	A1			0.0	0	99.88%		2020
Severn Trent Water	RETFORD - KINGS PARK (CSO)	T/74/02547/O	Single Discharge			5.5	5	94.32%		2020
Severn Trent Water	RETFORD (STW)	T/74/46203/R	A2			17.3	7	99.87%		2020
Severn Trent Water	RIDDINGS - GREENHILL LANE PS (CSO)	T/61/08216/O	Single Discharge			8.9	13	99.97%		
Severn Trent Water	Riddings - High Street (CSO)	No known permit reference	Single Discharge			0.0	0	98.55%		2020
Severn Trent Water	RIDGE LANE-MANCETTER (STW)	T/15/35759/R	A2			0.0	0	100.00%		2020
Severn Trent Water	RIPLEY - BROOK LANE (CSO)	DT/8271 & TSC335	Single Discharge			1.0	2	99.99%		2020
Severn Trent Water	RIPLEY - BUTTERLEY LANE (CSO)	T/41/45659/O	Single Discharge			49.8	37	99.82%		
Severn Trent Water	RIPLEY - DERBY ROAD 158 (CSO)	DT/8272 & TSC621	Single Discharge			0.0	0	99.88%		2020
Severn Trent Water	RIPLEY - DERBY ROAD 209 (CSO)	T/45/46241/O	Single Discharge			5.1	15	99.69%		
Severn Trent Water	RIPLEY - DERBY ROAD/BOWLER STREET (CSO)	T/41/45359/O	Single Discharge			0.6	2	99.99%		2020
Severn Trent Water	RIPLEY - HAMMERSMITH (PADLEY HALL) (CSO)	T/41/45400/O	Single Discharge			277.5	90	99.42%		
Severn Trent Water	RIPLEY - MOUNT PLEASANT (CSO)	T/41/21636/O	Single Discharge			0.2	2	90.10%		2020
Severn Trent Water	RIPLEY (STW)	T/41/45580/R	A1			0.0	0	100.00%		2020
Severn Trent Water	Rocester - High Street	No known permit reference	A1			0.0	0	99.99%		2020
Severn Trent Water	Rodborough Sso	S/22/20882/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	RODEN (STW)	S/04/56176/R	A2			1194.4	250	91.34%		2020
Severn Trent Water	ROSLISTON SPS	T/24/30272/O	A1			57.7	17	97.29%		
Severn Trent Water	ROSSINGTON - BANKWOOD LANE PS (CSO)	T/83/40104/O	A1			0.7	1	100.00%		2020
Severn Trent Water	ROUND ST/BAPTIST END RD JCN SSO (NETHERTON - BAPTIST END RD (CSO))	S/06/21366/O	Single Discharge			0.1	2	100.00%		
Severn Trent Water	ROUNDHILL (STW)	S/06/55232/R	A4			18.5	7	100.00%		2020
Severn Trent Water	ROUNDHILL/STATION RD/PEPPER ST SSO (Station Rd Sutton in Ashfield SSO)	T/70/07278/O-3	A1			575.8	63	99.88%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	ROUNDHILL/STATION RD/PEPPER ST SSO (SUTTON IN ASHFIELD-KIRKBY FOLLY RD (CSO))	T/70/07278/O-1	Single Discharge			1.1	6	99.60%		
Severn Trent Water	ROUS LENCH (STW)	S/17/25849/R	A2			2424.8	266	99.99%		2020
Severn Trent Water	ROWINGTON (STW)	S/15/26102/R	A2			629.0	110	92.87%		2020
Severn Trent Water	RUGBY - WOOD STREET (CSO)	S/10/04488/O	Single Discharge			0.0	0	99.99%		
Severn Trent Water	RUGBY NEWBOLD (STW)	S/10/26528/R	A2			93.5	10	100.00%		2020
Severn Trent Water	RUGBY NEWBOLD (STW)	S/10/26528/R	A3			0.0	0	100.00%		2020
Severn Trent Water	RUGELEY - SANDY LANE (CSO)	WQ/7/1345-2	Single Discharge			1.0	3	99.90%		
Severn Trent Water	RUGELEY - SLITTING MILL (SPS)	TSC3966	A1			0.5	1	100.00%		2020
Severn Trent Water	RUGELEY - SPRINGFIELD AVENUE (CSO)	T/05/20186/O	Single Discharge			3.2	19	99.10%		
Severn Trent Water	RUGELEY (STW)	T/05/36077/R	A2			402.6	56	92.12%		2020
Severn Trent Water	RUSHMOOR (STW)	S/04/55141/R	A2			332.4	31	100.00%		2020
Severn Trent Water	RUSHMOOR (STW)	S/04/55141/R	A3			27.5	12	100.00%		2020
Severn Trent Water	RYTON-ON-DUNSMORE - CHURCH ROAD (TPS)	S/10/26087/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	SALFORD CIRCUS - LICHFIELD ROAD (CSO)	T/08/35258/O	Single Discharge			77.4	43	99.87%		
Severn Trent Water	SALFORD CIRCUS - SALFORD BRIDGE (CSO)	T/08/21240/O	Single Discharge			0.5	2	99.99%		
Severn Trent Water	Saltby PS	T/54/07710/O-6	A1			0.0	0	99.94%		2020
Severn Trent Water	SALTLEY - ADDERLEY ROAD 264 (CSO)	DT/9815 & TSC54	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	SALTLEY - ALUM ROCK RD (CSO)	T/09/36399/O	Single Discharge			69.2	19	99.82%		2020
Severn Trent Water	SALTLEY - MAINSTREAM WAY (CSO)	T/09/21262/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	Saltley Road CSO	9811	Single Discharge			0.5	2	99.99%		2020
Severn Trent Water	SANDIACRE ROAD PUMPING STATION SSO (STAPLEFORD - SANDIACRE ROAD (SPS))	T/61/40323/O	Single Discharge			3.8	1	100.00%		
Severn Trent Water	SAREHOLE ROAD COMBINED STORM O'FLOW (HALL GREEN - SAREHOLE ROAD 323 (CSO))	T/12/36045/O	Single Discharge			130.3	74	99.97%		
Severn Trent Water	SAXELBY - SAXELBYE LANE (SPS)	T/55/02608/O-3	A1			2.2	1	100.00%		2020
Severn Trent Water	SCALFORD - THORPE SIDE (TPS)	T/54/07710/O-4	Single Discharge			14.1	5	100.00%		2020
Severn Trent Water	Scalpcliffe Rd Burton upon Trent CSO	T/24/30180/O	Single Discharge			0.4	4	100.00%		
Severn Trent Water	SCARCLIFFE (STW)	T/73/46169/R	A2			85.7	20	99.88%		2020
Severn Trent Water	SCOTTER (STW)	T/80/45390/R	A2			0.0	0	100.00%		2020
Severn Trent Water	SCUNTHORPE - BERKELEY STREET (CSO)	T/81/07993/O-2	Single Discharge			0.0	0	99.75%		2020
Severn Trent Water	SCUNTHORPE - BRIGG RD/STATION RD (CSO)	T/81/12308/O	Single Discharge			46.5	46	99.98%		
Severn Trent Water	SCUNTHORPE - BRIGG ROAD/HIGH STREET (CSO)	No known permit reference	Single Discharge			13.8	14	100.00%		2020
Severn Trent Water	SCUNTHORPE - BURRINGHAM ROAD (CSO)	WQ/7/1788	Single Discharge			0.0	0	99.99%		
Severn Trent Water	SCUNTHORPE - CLIFF CLOSES ROAD (CSO)	T/84/07794/O-3	Single Discharge			8.7	24	99.98%		
Severn Trent Water	SCUNTHORPE - DONCASTER RD (CSO)	T/84/07794/O-1	Single Discharge			16.9	18	100.00%		2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	SCUNTHORPE - EAST COMMON LN (CSO)	T/81/45130/O	Single Discharge			221.4	78	99.98%		
Severn Trent Water	SCUNTHORPE - GRANGE LANE NORTH (CSO)	T/81/45129/O	Single Discharge			19.0	6	99.98%		
Severn Trent Water	SCUNTHORPE - HIGH ST/FRANCES ST (CSO)	T/81/07993/O-1	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	SCUNTHORPE - QUEENSWAY (CSO)	T/81/45131/O	Single Discharge			7.8	11	100.00%		2020
Severn Trent Water	SCUNTHORPE - ROCHDALE RD (CSO)	T/81/46343/O	Single Discharge			7.2	13	99.97%		2020
Severn Trent Water	SCUNTHORPE - SPENCER AV (CSO)	T/81/07993/O-3	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	Scunthorpe O/L D SSO	T/81/07993/O-4	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	SCUNTHORPE-YADDLETHORPE (STW)	T/81/46406/R	A2			49.1	12	100.00%		2020
Severn Trent Water	SEAGRAVE - BUTCHERS LANE (CSO)	T/57/01152/O	Single Discharge			210.1	90	81.49%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	SEDGEBERROW Sewage Treatment Works (SEDGEBERROW (Sewage Treatment Works))	S/18/26164/R	A2			37.1	4	99.38%		
Severn Trent Water	SEDGLEY WATER RECLAMATION WORKS (SEDGLEY - GORGE ROAD (SST))	T/08/22103/O	Single Discharge			16.4	6	98.98%		
Severn Trent Water	Selkirk St/Lanark St CSO	No known permit reference	Single Discharge			0.7	1	97.05%		2020
Severn Trent Water	SELLY OAK - DADS LANE (S0)	T/12/36505/O	Single Discharge			3.4	3	99.99%		2020
Severn Trent Water	SELLY OAK - MOOR GREEN LANE (CSO)	T/12/36469/O	Single Discharge			28.4	31	100.00%		2020
Severn Trent Water	SELSTON GREEN - SELSTON ROAD (CSO)	T/61/03116/O-1	Single Discharge			490.2	52	99.97%		2020
Severn Trent Water	SHAWELL (STW)	S/10/26120/R	A2			146.1	59	99.91%		2020
Severn Trent Water	SHEEPY MAGNA (SPS)	T/20/00779/O	A1			3.3	2	99.45%		2020
Severn Trent Water	SHELDON - COMMON LA/BICKLEY GROVE (CSO)	T/12/36118/O	Single Discharge			543.4	74	99.92%		
Severn Trent Water	SHELDON - COVENTRY RD/ARDEN OAK RD (CSO)	T/12/36400/O	Single Discharge			2.0	5	99.99%		
Severn Trent Water	SHELDON - COVENTRY RD/BARROWS LA (CSO)	DT/9736	Single Discharge			0.9	5	99.99%		
Severn Trent Water	SHELFIELD - BROOK MEADOW ROAD (CSO)	T/08/35058/O	Single Discharge			740.3	71	99.83%		
Severn Trent Water	SHELSEY BEAUCHAMP Sewage Treatment Works (SHELSLEY BEAUCHAMP (Sewage Treatment Works))	S/09/56086/R	A2			1227.7	164	99.59%		
Severn Trent Water	SHELT HILL PUMPING STATION (WOODBOROUGH - SHELT HILL (SPS))	T/64/46349/O	Single Discharge			468.5	30	99.91%		
Severn Trent Water	SHENSTONE (STW)	T/17/35749/R	A3			208.8	35	100.00%		2020
Severn Trent Water	SHENSTONE SEWAGE TREATMENT WORKS	T/17/35749/R	A2			164.2	35	99.63%		
Severn Trent Water	SHEPSHED (STW)	T/57/45608/R	A3			0.6	3	100.00%		2020
Severn Trent Water	SHERBOURNE STORM WATER (CSO)	S/11/26637/R	Single Discharge			213.3	19	93.74%		2020
Severn Trent Water	SHERWOOD - VALLEY RD/EDWARDS LA (CSO)	T/63/08437/O	Single Discharge			8.4	6	100.00%		2020
Severn Trent Water	SHERWOOD - VALLEY ROAD (FOX HOTEL) (CSO)	T/63/07520/O	Single Discharge			0.8	5	100.00%		2020
Severn Trent Water	SHILTON - SHILTON LANE BRICKYARD (SPS)	TSC3881	A1			88.9	14	90.07%		2020
Severn Trent Water	SHIPLEY - SHIPLEY PARK (SPS)	TSC3882	A1			0.0	0	100.00%		2020
Severn Trent Water	SHIREBROOK - CARTER LANE/VICTORIA STREET	No known permit reference	Single Discharge			12.3	28	100.00%		2020
Severn Trent Water	SHIREBROOK - PORTLAND DRIVE (CSO)	T/71/03402/O	Single Discharge			7.1	9	99.99%		
Severn Trent Water	SHIREBROOK - ROWAN DR/PEAR TREE DRIVE	No known permit reference	Single Discharge			0.0	0	99.88%		2020
Severn Trent Water	SHIREBROOK - SOOKHOLME ROAD	No known permit reference	A1			0.0	0	100.00%		2020
Severn Trent Water	SHIREBROOK (STW)	T/71/45751/R	A2			102.7	14	100.00%		2020
Severn Trent Water	SHIREBROOK (STW)	T/71/45751/R	A3			0.8	1	100.00%		2020
Severn Trent Water	SHIRLAND - HALLFIELD GATE (SPS)	T/41/03811/O	A1			220.1	23	99.88%		2020
Severn Trent Water	SHIRLEY Sewage Treatment Works (SHIRLEY (Sewage Treatment Works))	T/34/35585/R	A2			25.4	15	99.98%		
Severn Trent Water	SHOBNALL - SHOBNALL ROAD (CSO)	T/33/07069/O-3	Single Discharge			13.5	14	99.98%		2020
Severn Trent Water	SHOBNALL STREET STORM OVERFLOW (SHOBNALL - SHOBNALL STREET 212 (CSO))	T/24/21521/O	Single Discharge			16.8	18	100.00%		
Severn Trent Water	SHREWSBURY - ABBEY FOREGATE (THE COLUMN) (SO)	S/02/21026/O	Single Discharge			0.1	1	99.83%		
Severn Trent Water	SHREWSBURY - ABBEY FOREGATE/BAGE WAY (CSO)	S/02/21040/O	Single Discharge			0.0	1	99.54%		
Severn Trent Water	SHREWSBURY - ABBEY FORGATE (CSO)	S/02/21036/O	Single Discharge			0.1	2	99.81%		
Severn Trent Water	SHREWSBURY - CASTLE FOREGATE (CSO)	S/02/21080/O	Single Discharge			1002.0	82	99.85%		
Severn Trent Water	SHREWSBURY - CLIVE ROAD (CSO)	S/02/21986/O	Single Discharge			47.6	39	99.99%		
Severn Trent Water	SHREWSBURY - GLENDOWER COURT (SPS)	TSC3914	Single Discharge			0.1	1	100.00%		2020
Severn Trent Water	SHREWSBURY - MILLERS GREEN (CSO)	S/02/21082/O	Single Discharge			14.2	25	99.93%		
Severn Trent Water	SHREWSBURY - OLD COLEHAM 1 (CSO)	S/02/21027/O	Single Discharge			516.1	57	99.69%		
Severn Trent Water	SHREWSBURY - OLD COLEHAM 2 (CSO)	S/02/21108/O	Single Discharge			497.9	49	99.83%		
Severn Trent Water	SHREWSBURY - SMITHFIELD RD/MARDOL (CSO)	S/02/21045/O	Single Discharge			134.6	12	96.36%		
Severn Trent Water	SHREWSBURY - SPRING GDNS/SULTAN RD (CSO)	S/02/21025/O	Single Discharge			1097.0	69	99.49%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	SHREWSBURY - SUTTON ROAD 10 (CSO)	S/02/21081/O	Single Discharge			327.1	122	92.95%		
Severn Trent Water	SHREWSBURY - VICTORIA AVE/CRES LA (CSO)	S/02/21017/O	Single Discharge			1673.9	92	99.98%		
Severn Trent Water	SHURDINGTON - STORM TANK (CSO)	S/20/12258/O	Single Discharge			4.0	3	99.99%		
Severn Trent Water	SIBTHORPE (STW)	T/69/45943/R	A2			493.5	80	99.93%		2020
Severn Trent Water	SIR JOHN'S ROAD CSO (CANNON HILL PARK- off PERSHORE RD (CSO))	T/09/36130/O	Single Discharge			29.5	6	99.80%		
Severn Trent Water	SKEGBY - COLLIERY VALLEY (CSO)	T/61/03264/O-1	Single Discharge			13.7	14	99.94%		
Severn Trent Water	SKEGBY - MANSFIELD ROAD (CSO)	T/71/07325/O	Single Discharge			2.9	7	99.97%		2020
Severn Trent Water	SKEGBY (STW)	T/71/45942/R	A2			2692.6	262	100.00%		2020
Severn Trent Water	SKEGBY (STW)	T/71/45942/R	A3			46.6	18	100.00%		2020
Severn Trent Water	SLAD ROAD CSO	No known permit reference	Single Discharge			0.1	2	99.99%		2020
Severn Trent Water	SLADE HOOTON (STW)	T/76/45411/R	A3			8.3	5	100.00%		2020
Severn Trent Water	SLADE HOOTON SEWAGE TREATMENT WORKS (SLADE HOOTON (Sewage Treatment Works))	T/76/45411/R	A2			686.5	64	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	SMALL HEATH - DORA ROAD (CSO)	T/12/36401/O	Single Discharge			0.2	2	100.00%		2020
Severn Trent Water	SMALL HEATH - GLOVERS RD (CSO)	T/09/21164/O	Single Discharge			69.5	5	100.00%		2020
Severn Trent Water	SMALL HEATH - GLOVERS RD/OAKLEY RD (CSO)	T/09/21545/O	Single Discharge			0.0	0	99.83%		2020
Severn Trent Water	SMALL HEATH - HOB MOOR ROAD (CSO)	T/12/02961/O-3	Single Discharge			0.1	1	99.93%		
Severn Trent Water	SMALL HEATH - MUNTZ STREET (CSO)	T/12/21539/O	Single Discharge			0.8	2	99.49%		2020
Severn Trent Water	SMALL HEATH - SOMERVILLE ROAD (CSO)	T/12/22673/O	Single Discharge			1.9	5	99.97%		
Severn Trent Water	SMALLEY - MAIN ROAD (CSO)	T/45/02651/O	Single Discharge			0.9	4	99.84%		2020
Severn Trent Water	SMALLEY- SMALLEY MILL ROAD (CSO)	T/45/03036/O	Single Discharge			0.0	0	99.99%		2020
Severn Trent Water	SMETHWICK - BOOTH ST/DOWNING ST (CSO)	T/08/35699/O	Single Discharge			23.5	7	100.00%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	SMETHWICK - BRASSHOUSE LANE (CSO)	T/08/30068/O	Single Discharge			1259.6	80	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	SMETHWICK - CAPE HILL (CSO)	T/09/35700/O	Single Discharge			5.1	14	99.99%		
Severn Trent Water	SMETHWICK - CORNWALL ROAD (CSO)	T/08/35701/O	Single Discharge			0.9	2	99.99%		
Severn Trent Water	SMETHWICK - DORSET RD/WILSON RD (CSO)	T/08/21123/O	Single Discharge			0.0	0	97.71%		2020
Severn Trent Water	SMETHWICK - GROVE STREET (CSO)	T/09/35703/O	Single Discharge			5.4	6	99.99%		
Severn Trent Water	SMETHWICK - HIGH ST/WATERY LA (CSO)	T/08/35704/O	Single Discharge			358.4	22	99.95%		2020
Severn Trent Water	SMETHWICK - LONDONDERRY LANE (CSO)	T/09/30212/O	Single Discharge			43.9	31	99.99%		
Severn Trent Water	SMETHWICK - RABONE LANE 2 (CSO)	T/08/35706/O	Single Discharge			3.7	7	99.99%		
Severn Trent Water	SMETHWICK - SOHO WAY/BALDWIN ST (CSO)	T/08/35698/O	Single Discharge			0.0	0	99.39%		
Severn Trent Water	SMITHFIELD RD STORM O/F (SHREWSBURY - SMITHFIELD ROAD (CSO))	S/02/21024/O	Single Discharge			362.7	53	94.00%		
Severn Trent Water	SNARESTONE (STW)	T/23/35619/R	A2			1550.0	81	99.78%		2020
Severn Trent Water	SNARESTONE ROAD PUMPING STATION (NEWTON BURGOLAND - SNARESTON ROAD (SPS))	T/23/30145/O	A1			19.8	3	100.00%		
Severn Trent Water	SNARROWS (STW)	T/57/46075/R	A2			823.2	67	99.98%		2020
Severn Trent Water	SNIBSTON - ST MARYS LANE (LAND SOUTH OF) (CSO)	T/20/30034/O	Single Discharge			0.4	1	100.00%		2020
Severn Trent Water	SNITTERFIELD Sewage Treatment Works (SNITTERFIELD (Sewage Treatment Works))	S/13/25980/R	A2			25.5	12	100.00%		
Severn Trent Water	SNOWSHILL (SPS)	S/18/26411/O	Single Discharge			52.4	4	100.00%		2020
Severn Trent Water	SOLIHULL - BRENTFORD ROAD (CSO)	T/11/36449/O	Single Discharge			1.3	1	81.80%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	SOMERCOTES - BIRCHWOOD LN (SPS)	T/61/45731/O	A1			10.0	8	99.88%		2020
Severn Trent Water	SOMERCOTES - LOWER BIRCHWOOD (SPS)	T/61/40153/O	A1			143.0	24	99.88%		2020
Severn Trent Water	SOMERCOTES - SOMERCOTES HILL (CSO)	T/61/45739/O	Single Discharge			26.5	7	99.87%		
Severn Trent Water	SOUDLEY - NR TRAMWAY ROAD (SPS)	S/20/25506/O	A1			345.2	20	98.75%		
Severn Trent Water	SOUTH ASKHAM - ASKHAM ROAD (SPS)	TSC3997	A1			0.0	0	99.99%		2020
Severn Trent Water	SOUTH CROXTON - SCHOOL LANE PS (CSO)	T/55/45236/O	A1			46.1	6	94.37%		
Severn Trent Water	SOUTH MUSKHAM - MAIN STREET (SPS)	TSC3625	A1			0.0	0	100.00%		2020
Severn Trent Water	SOUTH NORMANTON - BIRCHWOOD LANE (CSO)	T/61/03163/O	Single Discharge			10.5	7	99.88%		2020
Severn Trent Water	SOUTH NORMANTON - CARNFIELD (SPS)	T/41/40185/O	A1			0.0	0	99.25%		2020
Severn Trent Water	SOUTH NORMANTON - HILL FIELDS (CSO)	T/61/21877/O	Single Discharge			2.7	5	99.81%		
Severn Trent Water	SOUTH NORMANTON (STW)	T/41/46401/R	A2			727.6	43	99.98%		2020
Severn Trent Water	SOUTH NORMANTON (STW)	T/41/46401/R	A3			0.0	0	100.00%		2020
Severn Trent Water	SOUTH WINGFIELD - HOLM LANE (SPS)	T/41/07222/R-1	A1			53.9	5	99.95%		2020
Severn Trent Water	SOUTH WINGFIELD (STW)	T/41/45538/R	A2			179.3	55	93.50%		2020
Severn Trent Water	SOUTHAM - BANBURY ROAD (CSO)	S/12/07887/O-1	Single Discharge			8.1	3	100.00%		2020
Severn Trent Water	SOUTHWELL - CHURCH STREET (CSO)	T/64/45856/O	Single Discharge			11.1	10	99.99%		
Severn Trent Water	SOUTHWELL - NEWARK ROAD (CSO)	T/64/45855/O	Single Discharge			33.9	17	99.99%		2020
Severn Trent Water	SOUTHWELL (STW)	WQD008782	A2			591.6	48	99.94%		2020
Severn Trent Water	SOWE STORM WATER (CSO)	S/11/26637/R	Single Discharge			341.9	66	100.00%		2020
Severn Trent Water	Spath Uttoxeter PS	T/32/07881/O	A1			6.6	6	100.00%		2020
Severn Trent Water	SPITFIRE ROAD CSO (BROMFORD - SPITFIRE ROAD (CSO))	T/10/22100/O	Single Discharge			0.8	3	99.98%		
Severn Trent Water	SPONDON - NOTTINGHAM ROAD (CSO)	T/48/20341/O	Single Discharge			0.0	0	99.91%		
Severn Trent Water	SPRINGFIELDS - NEWCASTLE ROAD (CSO)	T/01/35716/O	Single Discharge			6.1	11	99.99%		
Severn Trent Water	SPROXTON - COSTON ROAD (SPS)	T/54/07710/O-3	A1			0.0	0	100.00%		2020
Severn Trent Water	SSO AT BOWERS HALL, BAKEWELL (STANTON IN PEAK - BOWERS HALL (CSO))	T/39/45884/O	Single Discharge			772.4	56	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	SSO AT SOUTH CHURCH STREET (BAKEWELL - SOUTH CHURCH STREET (CSO))	T/38/45886/O	Single Discharge			510.5	40	94.20%		
Severn Trent Water	ST JAMES HOUSE SSO (EDGBASTON - FREDERICK RD 1 (CSO))	T/09/30215/O	Single Discharge			0.4	2	99.73%		
Severn Trent Water	ST JAMES ROAD SSO (EDGBASTON - ST JAMES RD (CSO))	T/09/30217/O	Single Discharge			0.2	2	99.99%		
Severn Trent Water	St Lukes Road CSO	No known permit reference	Single Discharge			0.0	1	99.65%		2020
Severn Trent Water	St Marys Rd Nuneaton PS	T/19/08001/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	St Marys Rd Nuneaton PS	T/19/08001/O	Single Discharge			20.7	7	99.93%		2020
Severn Trent Water	ST MICHAELS ROAD (CROSS HEATH - ST MICHAELS ROAD (CSO))	T/01/30008/O	Single Discharge			56.1	54	100.00%		
Severn Trent Water	STAFFORD - BROAD EYE (SPS)	TSC3157	A1			11.8	7	99.88%		2020
Severn Trent Water	STAFFORD - SILKMORE LANE (SPS)	TSC3888	A1			13.0	4	100.00%		2020
Severn Trent Water	STAFFORD AVENUE CSO (NEWCASTLE UNDER LYME - STAFFORD AV (CSO))	NPSWQD002018	Single Discharge			24.6	12	99.95%		
Severn Trent Water	STAFFORD LANE (Cannock Rd Sso)	T/03/03105/O-1	Single Discharge			107.8	11	99.94%		
Severn Trent Water	STAFFORD LANE (HEDNESFORD - CHEVIOT RISE (CSO))	TSC1834	Single Discharge			16.6	15	99.83%		
Severn Trent Water	STAFFORD ROAD CSO (PENKRIDGE - STAFFORD ROAD (SPS))	T/03/36185/O	A1			22.1	4	99.91%		
Severn Trent Water	STALLINGTON LANE (BLYTHE BRIDGE - STALLINGTON LANE (CSO))	T/06/30271/O	Single Discharge			0.5	2	99.98%		
Severn Trent Water	STANHOPE ROAD/DAVISON ROAD JCT SO (SMETHWICK - STANHOPE RD/DAVISON RD (CSO))	T/08/35707/O	Single Discharge			4.7	7	100.00%		
Severn Trent Water	STANLEY COMMON - COMMON LANE (CSO)	T/61/45470/O	Single Discharge			0.9	4	99.88%		2020
Severn Trent Water	STANLEY DOWNTON WWTW (STANLEY DOWNTON (Sewage Treatment Works))	S/22/26240/R	A2			720.6	64	99.93%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	STANLEY LANE STW SITE (BRIDGNORTH - STANLEY LANE (CSO))	S/02/08954/O	Single Discharge			27.4	20	99.91%		
Severn Trent Water	STANLEY ROAD STORM OVERFLOW (OLDBURY - STANLEY RD - OPPOSITE 27 (CSO))	T/09/36170/O	Single Discharge			7.1	15	95.36%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	STANTON UNDER BARDON SPS (STANTON UNDER BARDON (SPS))	T/56/40256/O	A1			456.7	85	93.74%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	STAPLEFORD-BESSELL LANE WWTW (STAPLEFORD-BESSEL LANE (Sewage Treatment Works))	T/61/45964/R	A2			62.0	9	99.39%		
Severn Trent Water	STAPLETON LANE SEWAGE PUMPING ST. (BARWELL - STAPLETON LANE (SPS))	T/20/35907/O	A1			184.4	35	99.31%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	STAPLETON PUMPING STATION SSO (STAPLETON - DADLINGTON LANE (SPS))	T/20/30311/O	A1			0.8	3	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	STARCH LANE STORM OVERFLOW (SANDIACRE - STARCH LANE (CSO))	T/61/21280/O	Single Discharge			0.0	0	98.68%		
Severn Trent Water	STATHERN - HARBY LANE (CSO)	T/66/09254/O-2	Single Discharge			27.0	13	99.89%		
Severn Trent Water	Station Rd Cheddleton SSO	T/30/35159/O	Single Discharge			2.8	1	93.36%		
Severn Trent Water	STATION ROAD P.S CODSALL (CODSALL - STATION ROAD (SPS))	T/03/30099/O	A1			3.7	6	99.97%		
Severn Trent Water	STATION ROAD STORM OVERFLOW (BEESTON - STATION ROAD (CSO))	T/64/40177/O	Single Discharge			12.7	5	99.89%		
Severn Trent Water	STAVERTON BRIDGE (SPS)	S/20/25539/O	Single Discharge			90.9	10	100.00%		2020
Severn Trent Water	STECHFORD - EASTFIELD ROAD (CSO)	T/12/36497/O	Single Discharge			8.7	11	96.78%		2020
Severn Trent Water	STECHFORD - STECHFORD LN OPP 99 (CSO)	T/12/36261/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	STETCHFORD - FLAXLEY ROAD (CSO)	T/12/36066/O	Single Discharge			21.9	14	99.99%		
Severn Trent Water	STOKE GOLDING - THE ROSEWAY (CSO)	T/20/03817/O	Single Discharge			48.6	37	99.99%		
Severn Trent Water	Stoke Golding PS	T/20/03180/O	A1			368.7	48	99.97%		
Severn Trent Water	STOKE ORCHARD (STW)	S/17/26029/R	A2			660.3	61	100.00%		2020
Severn Trent Water	STOKE PRIOR Sewage Treatment Works (STOKE PRIOR (Sewage Treatment Works))	S/07/56078/R	A2			93.3	14	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	STOKE SAINT MILBOROUGH (STW)	S/09/56129/R	A2			0.0	0	100.00%		2020
Severn Trent Water	STOKE-ON-TRENT - BEECHS GARAGE (CSO)	T/01/30305/O	Single Discharge			43.6	24	99.74%		
Severn Trent Water	STOKE-ON-TRENT - QUEENSWAY (SPS)	T/01/30157/O	A1			1.7	1	97.91%		
Severn Trent Water	STONE - CROWN STREET 2 (CSO)	DT/2540	Single Discharge			0.0	0	99.98%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	Stonebridge Lane Long Itchington PS	S/12/25044/O	Single Discharge			131.5	13	93.84%		2020
Severn Trent Water	Stonebridge Ln/Rd (Vale Av PS) CSO	T/71/08687/O-4	Single Discharge			3.8	6	99.98%		2020
Severn Trent Water	STONEBROOM INDUSTRIAL ESTATE (CSO)	T/41/45148/O	Single Discharge			0.3	2	99.99%		
Severn Trent Water	STONEFIELD SQUARE OVERFLOW (STONE - STONEFIELD SQUARE (CSO))	T/01/30076/O	Single Discharge			0.0	0	99.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	STONESBY - KING STREET LANE (SPS)	T/54/07710/O-2	A1			3.3	1	99.80%		2020
Severn Trent Water	STONEY STANTON - HINCKLEY ROAD (CSO)	T/50/07734/O-3	Single Discharge			0.0	0	98.41%		
Severn Trent Water	STONEY STANTON - MANOR BROOK CLOSE (CSO)	T/50/07734/O-1	Single Discharge			0.9	1	99.99%		
Severn Trent Water	STONEY STANTON (STW)	T/50/46146/R	A2			525.0	33	100.00%		2020
Severn Trent Water	STOTTESDON (STW)	S/09/12624/R	A2			0.0	0	99.98%		2020
Severn Trent Water	Stourport Rd Syphon Kidderminster CSO	TSC3952	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	STRAITS ROAD STORM OVERFLOW (STRAITS GREEN - STRAITS ROAD (CSO))	S/06/21305/O	Single Discharge			89.6	57	100.00%		
Severn Trent Water	STRATFORD(MILCOTE) Sewage Treatment Works (STRATFORD-MILCOTE (Sewage Treatment Works))	S/13/25718/R	A2			583.4	49	99.99%		
Severn Trent Water	STREETLY - CHESTER ROAD (CSO)	T/17/00893/O	Single Discharge			0.0	0	98.77%		2020
Severn Trent Water	STRETTON - DERBY ROAD (CSO)	CSO/T/59	Single Discharge			1.7	1	100.00%		2020
Severn Trent Water	STRONGFORD SEWAGE TREATMENT WORKS (STRONGFORD (Sewage Treatment Works))	T/01/36052/R	A2			1044.0	96	99.78%		
Severn Trent Water	STROUD - BEARDS LANE (CSO)	S/22/04828/O	Single Discharge			0.4	1	99.97%		
Severn Trent Water	STROUD - WALLBRIDGE (SPS)	S/22/26219/O	Single Discharge			1878.9	98	100.00%		
Severn Trent Water	STUDLEY - CASTLE ROAD (CSO)	S/15/23166/O	Single Discharge			3.9	2	99.98%		
Severn Trent Water	SUTTON BONNINGTON (STW)	T/57/46002/R	A2			242.3	38	100.00%		2020
Severn Trent Water	SUTTON IN ASHFIELD - COMMON ROAD (CSO)	T/41/07908/O-2	Single Discharge			1.0	3	99.97%		
Severn Trent Water	SUTTON IN ASHFIELD - COXMOOR ROAD (CSO)	T/61/03264/O-7	Single Discharge			9.3	35	99.56%		
Severn Trent Water	SUTTON IN ASHFIELD - CROSS LANE (CSO)	T/41/07908/O	Single Discharge			1.7	7	99.99%		
Severn Trent Water	SUTTON IN ASHFIELD - FACKLEY ROAD (CSO)	T/71/07259/O	Single Discharge			18.2	8	99.80%		
Severn Trent Water	SUTTON IN ASHFIELD - MEDEN BANK (CSO)	T/71/07259/O	Single Discharge			0.9	1	99.99%		2020
Severn Trent Water	SUTTON IN ASHFIELD - SPRINGWELL STREET (CSO)	T/41/07908/O-3	Single Discharge			0.2	2	99.98%		
Severn Trent Water	SUTTON IN ASHFIELD WWTW (SUTTON IN ASHFIELD (Sewage Treatment Works))	T/70/45949/R	A2			0.0	0	99.91%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	SUTTON ON TRENT - CROMWELL (STW)	T/69/46017/R	A2			461.9	48	99.94%		2020
Severn Trent Water	SUTTON ON TRENT - MAIN STREET (SPS)	TSC3626	A1			0.0	0	97.64%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	Sutton Rd Walsall SWS	T/08/00563/O	Single Discharge			0.2	1	99.90%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	SUTTON VILLAGE - SUTTON LANE (STW)	T/66/45287/R	A2			10.8	4	99.93%		2020
Severn Trent Water	Swadlincote - Alma Road (CSO)	No known permit reference	Single Discharge			0.5	9	99.88%		2020
Severn Trent Water	Swadlincote - Belmont Street (CSO)	No known permit reference	Single Discharge			0.0	1	98.99%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	Swadlincote - Coppice Side (CSO)	No known permit reference	Single Discharge			0.4	1	99.97%		2020
Severn Trent Water	Swadlincote - High Street (CSO)	No known permit reference	Single Discharge			0.0	0	99.99%		2020
Severn Trent Water	SWAN VILLAGE - DUDLEY STREET (CSO)	T/08/08407/O	Single Discharge			0.0	0	97.75%		
Severn Trent Water	SWANINGTON PUMPING STATION (SWANNINGTON - JEFFCOATS LANE (SPS))	T/57/01188/O	A1			747.1	32	99.99%		
Severn Trent Water	SWANWICK - HICKTON ROAD (SPS)	T/41/40340/O	A1			38.2	28	99.77%		2020
Severn Trent Water	SWANWICK - THE DELVES (FARM LAYBY) (CSO)	T/41/45456/O	Single Discharge			63.4	58	99.99%		
Severn Trent Water	SWANWICK (STW)	T/41/45656/R	A2			1222.8	86	99.98%		2020
Severn Trent Water	SWEPSTONE - MAIN STREET (SPS)	T/23/01208/O-1	A1			0.0	0	100.00%		2020
Severn Trent Water	SYPHON Z (SILVERDALE - ELLAMS PLACE (CSO))	T/01/03101/O-2	Single Discharge			0.0	0	100.00%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	SYPHON Z (SILVERDALE - NEWCASTLE ST/MILL ST (CSO))	T/01/03101/O-3	Single Discharge			2.5	7	99.98%		
Severn Trent Water	SYSTON - CLUMBER CLOSE (CSO)	T/55/21953/O	Single Discharge			0.0	0	86.24%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	TALBOT LANE PS - EMERG/STORM O/F (THRINGSTONE - TALBOT LANE (SPS))	T/57/03208/O	A1			0.0	0	99.58%		
Severn Trent Water	TAMWORTH - LICHFIELD ROAD (TPS)	T/22/02643/O	Single Discharge			192.1	33	99.99%		
Severn Trent Water	TANSLEY - OLD COACH RD (POND) CSO	T/40/21109/O	Single Discharge			66.0	18	99.96%		
Severn Trent Water	TANWORTH-IN-ARDEN - DANZEY GRN LA (SPS)	S/15/12208/O	Single Discharge			85.4	27	100.00%		2020
Severn Trent Water	TEDDINGTON - A435 (SPS)	S/17/25464/O	Single Discharge			413.9	55	100.00%		2020
Severn Trent Water	TELFORD - FURNACE LANE TRENCH (CSO)	S/04/12251/O-1	Single Discharge			0.8	3	99.99%		
Severn Trent Water	TENBURY - CRALVES MEAD (SPS)	TSC3190	A1			0.0	0	99.91%		2020
Severn Trent Water	TENBURY WELLS SEWAGE WORKS (TENBURY (Sewage Treatment Works))	S/09/55831/R	A2			1018.2	107	99.99%		
Severn Trent Water	TETHERINGRASS LANE PUMPING STATION (BECKINGHAM - TETHERING GRASS LANE (SPS))	T/69/40259/O	A1			33.2	14	99.98%		
Severn Trent Water	TETTENHALL - BRIDGNORTH RD (CSO)	S/06/20944/O	Single Discharge			329.3	83	99.99%		
Severn Trent Water	TETTENHALL - MEADOW VIEW TERRACE (CSO)	S/06/09091/O-2	Single Discharge			36.1	17	99.98%		
Severn Trent Water	TETTENHALL - WOOD ROAD (CSO)	T/03/12429/O-1	Single Discharge			0.5	1	97.44%		
Severn Trent Water	TEWKESBURY - RED LANE (CSO)	S/17/20917/O	Single Discharge			65.5	9	99.97%		
Severn Trent Water	TEWKESBURY - TOLSEY LANE (CSO)	S/17/20915/O	Single Discharge			97.6	11	99.94%		
Severn Trent Water	TEWKESBURY Sewage Treatment Works (TEWKESBURY (Sewage Treatment Works))	S/17/26480/R	A2			1137.0	56	98.68%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	THE BUILDING SOCIETY (BELPER - BRIDGEFOOT (CSO))	T/42/21277/O	Single Discharge			1025.8	61	99.90%		
Severn Trent Water	THE CROSS PS (CSO)	No known permit reference	Single Discharge			105.7	8	95.17%		2020
Severn Trent Water	THE GEORGE HOTEL (LICHFIELD - MARKET STREET (CSO))	T/07/22061/O	Single Discharge			0.0	0	99.98%		
Severn Trent Water	THE HAYES STORM OVERFLOW (LYE - THE HAYES (CSO))	S/06/21904/O	Single Discharge			178.0	13	99.63%		
Severn Trent Water	THE HOLLOWAY STORM OVERFLOW (COMPTON - BRIDGNORTH RD (CSO))	S/06/20949/O	Single Discharge			0.0	0	90.85%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	THE MILL WALK STORM SEWAGE OVERFLOW (NORTHFIELD - THE MILL WALK (CSO))	T/09/36047/O	Single Discharge			2.2	2	98.46%		
Severn Trent Water	THE OVAL PUMPING STATION (SPS) (BICTON - THE OVAL (SPS))	S/02/55422/O	A1			214.2	34	99.60%		
Severn Trent Water	THORPE SATCHVILLE (STW)	T/55/45647/R	A2			123.7	21	100.00%		2020
Severn Trent Water	THRUMPTON SEWAGE TREATMENT WORKS (THRUMPTON (Sewage Treatment Works))	T/49/45285/R	A2			175.4	46	100.00%		
Severn Trent Water	TIBBERTON - GREENHOUSES (SPS)	S/04/55250/O	Single Discharge			201.7	41	99.99%		2020
Severn Trent Water	TIBBERTON PUMPING STATION (TIBBERTON - PLOUGH ROAD (STW) (SPS))	S/19/21927/R	Single Discharge			1.7	1	98.90%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	TIBSHELF - CHESTERFIELD ROAD (SPS)	T/41/03048/O	A1			62.2	18	99.88%		2020
Severn Trent Water	TIBSHELF - DOE HILL LANE/SPA CROFT (CSO)	T/41/03162/O-3	Single Discharge			0.6	1	100.00%		2020
Severn Trent Water	TIBSHELF - HIGH ST/BROOKE ST (CSO)	No known permit reference	Single Discharge			0.3	2	99.92%		2020
Severn Trent Water	TICKHILL (STW)	T/83/45915/R	A3			0.4	1	100.00%		2020
Severn Trent Water	TICKNALL (Sewage Treatment Works)	T/36/45812/R	A2			432.9	21	99.92%		
Severn Trent Water	TICKNALL SPS (TICKNALL - MAIN STREET (SPS))	T/36/21920/O	A1			105.9	35	99.73%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	TIDESWELL (STW)	T/39/45417/R	A2			848.6	68	99.88%		2020
Severn Trent Water	TILE CROSS - ALCOTT GROVE (CSO)	T/12/36417/O	Single Discharge			9.0	17	99.99%		
Severn Trent Water	TIPTON - ALEXANDRA ROAD (CSO)	T/08/36337/O	Single Discharge			71.5	30	99.99%		
Severn Trent Water	TIPTON - BEAN ROAD (CSO)	T/08/22104/O	Single Discharge			0.0	0	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	TIPTON - BIRMINGHAM NEW RD/BAKER ST (CSO)	T/08/21536/O	Single Discharge			2.9	3	99.98%		
Severn Trent Water	TIPTON - DENBIGH ROAD (SPS)	DT/2357	Single Discharge			4.2	3	99.92%		
Severn Trent Water	TIPTON - TOLL END (SO)	T/08/12150/O	A1			0.0	0	99.57%		2020
Severn Trent Water	TIPTON - WOOD STREET 26 (CSO)	T/08/36061/O	Single Discharge			2.0	4	99.99%		
Severn Trent Water	TITHBY (STW)	T/66/45337/R	A2			258.2	30	100.00%		2020
Severn Trent Water	TITTENSOR (CSO)	T/01/00122/O	Single Discharge			8.9	27	81.18%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	TITTESWORTH (SPS)	TSC4004	A1			0.0	0	99.88%		2020
Severn Trent Water	TODDINGTON Sewage Treatment Works (TODDINGTON (Sewage Treatment Works))	S/18/25752/R	A2			546.0	66	99.91%		
Severn Trent Water	TONG-NEWPORT ROAD (SPS)	EPRCP3623XS	Single Discharge			0.0	0	99.99%		2020
Severn Trent Water	TOWNSEND - WOOLISCROFT ROAD (CSO)	T/01/22768/O	Single Discharge			4.1	9	99.99%		
Severn Trent Water	TRENT VALE - HARPFIELD ROAD (CSO)	T/01/30092/O	Single Discharge			4.6	13	99.99%		
Severn Trent Water	TRENT VALE PS (CSO)	T/01/36007/O	A1			965.0	81	99.99%		
Severn Trent Water	TRENTHAM - GOODWOOD PLACE (CSO)	T/01/35956/O	Single Discharge			8.4	9	99.90%		
Severn Trent Water	TRENTHAM - STONE ROAD 1 (CSO)	T/01/35954/O	Single Discharge			30.4	25	99.54%		
Severn Trent Water	TRENTHAM - WERBURGH DRIVE (CSO)	T/01/35955/O	Single Discharge			5.5	6	99.99%		
Severn Trent Water	TRESCOTT - FURNACE GRANGE ROAD (SPS)	S/06/55188/S	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	TRESCOTT (STW)	S/06/55363/R	A3			0.0	0	100.00%		2020
Severn Trent Water	TRINITY RD / LODGE RD	No known permit reference	Single Discharge			74.9	69	100.00%		2020
Severn Trent Water	TRINITY STREET STORM OVERFLOW (OLD HILL - TRINITY STREET (CSO))	S/06/21057/O	Single Discharge			1038.7	44	99.99%		
Severn Trent Water	TRYSULL ROAD STORM OVERFLOW (BRADMORE - TRYSULL ROAD (CSO))	S/06/50124/O	Single Discharge			83.5	7	99.71%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	TUFFLEY - STROUD ROAD 389 (CSO)	S/20/23155/O	Single Discharge			11.7	16	99.90%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	TURNDITCH - COWERS LANE (SPS)	T/43/40155/O	A1			3.7	5	100.00%		2020
Severn Trent Water	TUTBURY - DUKE STREET (CSO)	T/33/35123/O	Single Discharge			36.0	21	99.98%		
Severn Trent Water	TUTBURY SEWAGE PUMPING STATION (Tutbury PS)	T/33/35095/O	A1			185.6	35	100.00%		
Severn Trent Water	TWO DALE-CHESTERFLD RD (THE CROFT) (CSO)	817-8	Single Discharge			50.3	11	93.01%		
Severn Trent Water	TWO DALES - GREENWAY LN/ODDFORD LN (CSO)	817-6	Single Discharge			10.5	7	99.73%		
Severn Trent Water	TWO GATES - MOUNT PLEASANT 8 (CSO)	454-3	Single Discharge			21.2	17	99.90%		
Severn Trent Water	TWYNING Sewage Treatment Works (TWYNING (Sewage Treatment Works))	S/17/25353/R	A2			1452.6	88	99.79%		
Severn Trent Water	TYBURN - HANSONS BRIDGE ROAD 120 (CSO)	T/10/00883/O	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	TYSELEY - HAY HALL ROAD (CSO)	T/12/21954/O	Single Discharge			0.0	0	0.00%	As previously indicated - installation not feasible at this location. Capital project promoted to facilitate asset improvements for future installation.	
Severn Trent Water	TYSELEY - SPEEDWELL RD/REDHILL RD (CSO)	T/12/30296/O	Single Discharge			1.1	3	99.98%		
Severn Trent Water	ULLESTHORPE - CLAYBROOKE ROAD (CSO)	T/50/08859/O	Single Discharge			47.9	34	99.96%		
Severn Trent Water	UNDER M6 (CSO) (Gavelly Hill - off Walker Drive CSO)	TSC2009 & TSC2012	Single Discharge			0.3	8	100.00%		
Severn Trent Water	UPPER GORNAL - GREEN LANE (CSO)	T/08/22102/O	Single Discharge			19.0	9	99.95%		
Severn Trent Water	UPPER MIDWAY - POPLAR AVENUE (SO)	No known permit reference	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	UPPER SAPEY (STW)	S/09/55357/R	A2			110.2	27	99.99%		2020
Severn Trent Water	UPPER TEAN - CHEADLE ROAD (CSO)	T/32/21253/O	Single Discharge			13.5	6	99.94%		
Severn Trent Water	UPPER TYSOE - SMARTS LANE (SPS)	S/14/09028/O	A1			2.8	5	100.00%		2020
Severn Trent Water	UPTON SNODSBURY (STW)	S/17/25981/R	A2			4.6	1	100.00%		2020
Severn Trent Water	Upton upon Severn TPS	S/08/09361/O	A1			251.5	13	99.95%		2020
Severn Trent Water	UPTON-ON-SEVERN WKS (STW)	S/08/25699/R	A2			406.5	21	100.00%		2020
Severn Trent Water	Urban Rd/Lindleys Ln Mh 1201 SSO	T/61/03524/O-1	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	UTTOXETER - DOVE BANK ROAD (CSO)	T/33/21089/O	Single Discharge			2.9	5	99.98%		2020
Severn Trent Water	UTTOXETER SEWAGE TREATMENT WORKS (UTTOXETER (Sewage Treatment Works))	T/33/36107/R	A2			270.9	43	99.98%		
Severn Trent Water	VALLEY PARKWAY CSO (BOURNVILLE - WOODBROOKE ROAD (CSO))	T/09/36498/O	Single Discharge			28.7	9	99.30%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	VALLEY ROAD STORM OVERFLOW (LYE - VALLEY ROAD (CSO))	S/06/21177/O	Single Discharge			0.3	2	99.98%		
Severn Trent Water	Victoria St Ironville PS	T/61/08887/O	Single Discharge			44.5	20	100.00%		2020
Severn Trent Water	W BROMWICH ROAD(PLAYING FIELDS) CSO (THE DELVES - WEST BROMWICH ROAD (CSO))	T/08/35624/O	Single Discharge			0.7	1	99.97%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	W/FLD-MERRILLS HALL LN-W/FIELD WY (SO)	T/08/21171/O	Single Discharge			219.8	13	99.98%		
Severn Trent Water	WADWORTH - DAW LANE (TPS)	T/83/46097/O	A1			0.2	1	100.00%		2020
Severn Trent Water	WAKE GREEN RD/YARDLEY WOOD RD SSO (WAKE GREEN - WAKE GREEN RD (CSO))	T/12/30218/O	Single Discharge			0.3	6	100.00%		
Severn Trent Water	WALKERINGHAM Sewage Treatment Works (WALKERINGHAM (Sewage Treatment Works))	T/69/45814/R	A2			161.7	36	100.00%		
Severn Trent Water	WALL - WATLING STREET (SPS)	T/17/08977/O	A1			12.1	8	99.52%		2020
Severn Trent Water	WALL HEATH - BROOK ST/CROSS ST (CSO)	S/06/07949/O-1	Single Discharge			15.6	10	99.99%		
Severn Trent Water	WALSALL - BESCOT CRES (CSO)	T/08/12317/O	Single Discharge			11.6	14	98.93%		
Severn Trent Water	WALSALL - BESCOT CRESCENT (CSO)	T/08/35325/O	Single Discharge			727.3	94	99.95%		
Severn Trent Water	WALSALL - BIRMINGHAM ROAD (CSO)	T/08/20376/O	Single Discharge			43.8	41	99.95%		
Severn Trent Water	WALSALL - BODMIN RISE/HELSTON ROAD (SO)	No known permit reference	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	WALSALL - BRIDGEMAN STREET (CSO)	T/08/21227/O	Single Discharge			2.0	3	98.78%		2020
Severn Trent Water	WALSALL - BROADWAY (CSO)	T/08/03680/O-7	Single Discharge			0.0	0	99.97%		
Severn Trent Water	WALSALL - CORPORATION STREET WEST (CSO)	T/08/35073/O	Single Discharge			15.6	6	90.64%		
Severn Trent Water	WALSALL - FERNLEIGH/GOSCOTE LANE (CSO)	T/08/36453/O	Single Discharge			19.7	17	99.99%		
Severn Trent Water	WALSALL - GOSCOTE LANE - OPP 72 (CSO)	T/08/36217/O	Single Discharge			0.7	1	99.97%		
Severn Trent Water	WALSALL - JESSON RD (CSO)	T/08/12316/O	A1			0.2	1	99.74%		
Severn Trent Water	WALSALL - LORD ST/QUEEN MARY ST (CSO)	T/08/35910/O	Single Discharge			1.3	3	99.93%		
Severn Trent Water	WALSALL - MILTON ST/ROSAMOND ST (CSO)	T/08/21440/O	Single Discharge			0.3	1	99.31%		2020
Severn Trent Water	WALSALL - PLECK ROAD (SO)	T/08/36234/O	Single Discharge			3.0	7	99.77%		
Severn Trent Water	WALSALL - PORTLAND STREET (CSO)	T/08/09218A/O	Single Discharge			8.1	10	99.98%		
Severn Trent Water	WALSALL WOOD - HALL LANE (CSO)	T/08/35821/O	Single Discharge			19.9	14	99.95%		
Severn Trent Water	WALSALL WOOD (STW)	T/08/36224/R	A2			123.2	18	100.00%		2020
Severn Trent Water	WALTHAM (STW)	T/54/46202/R	A2			22.0	7	100.00%		2020
Severn Trent Water	WALTON ON TRENT_MAINT ST & STATION LN_WALTON SPS	T/24/35152/O	A1			1.3	7	94.16%		
Severn Trent Water	WANLIP SEWAGE TREATMENT WORKS (WANLIP (Sewage Treatment Works))	T/53/46354/R	A5			0.0	0	100.00%	Monitor installed after reporting period but data will be available for next year's submission.	2020
Severn Trent Water	WANLIP SEWAGE TREATMENT WORKS (WANLIP (Sewage Treatment Works))	T/53/46354/R	A3			968.0	129	99.88%		
Severn Trent Water	WARMSWORTH - COMMON LANE (CSO)	T/83/40281/O	Single Discharge			9.4	10	100.00%		2020
Severn Trent Water	WARMSWORTH (STW)	T/83/45838/R	A2			0.7	3	99.87%		2020
Severn Trent Water	WARMSWORTH (STW)	T/83/45838/R	A3			39.2	13	100.00%		2020
Severn Trent Water	WARSOP - BURNS LANE (SSO)	T/71/40114/O	A1			31.2	9	97.94%		2020
Severn Trent Water	WARSOP - STONEBRIDGE LANE (SPS)	T/71/08687/O-2	A1			0.2	1	100.00%		2020
Severn Trent Water	WARSTONES RD/WARSTONES CRESCENT SSO (PENN - WARSTONES RD/WARSTONES CRES (CSO))	S/06/22071/O	Single Discharge			3.0	3	96.02%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	WARTNABY - SPRING LANE (SPS)	T/55/02608/O-2	A1			0.0	0	100.00%		2020
Severn Trent Water	WARTON - ORTON ROAD (SPS)	TSC3577	A1			132.8	38	100.00%		2020
Severn Trent Water	WARWICK - LONGBRIDGE (STW)	S/13/26328/R	A2			559.5	51	100.00%		2020
Severn Trent Water	WASHWOOD HEATH - ASTON CHURCH ROAD (CSO)	DT/9807 & TSC124	Single Discharge			15.5	16	98.05%		2020
Severn Trent Water	WASHWOOD HEATH - WASHWOOD HEATH RD (CSO)	T/10/36412/O	Single Discharge			113.6	14	98.97%		
Severn Trent Water	WASHWOOD HEATH - WATSON ROAD (CSO)	T/10/35023/O	Single Discharge			21.2	8	100.00%		2020
Severn Trent Water	WATERHOUSES (STW)	EPRWB3499NQ	A2			461.4	29	90.37%		2020
Severn Trent Water	WEBHEATH - CHURCH ROAD PS (CSO)	S/19/25363/O	A1			4.3	3	99.85%		2020
Severn Trent Water	WEDDINGTON - CHURCH LANE (CSO)	T/19/00771/O	Single Discharge			47.4	10	99.97%		
Severn Trent Water	WEDDINGTON - WEDDINGTON ROAD (SPS)	T/19/02830/O	A1			1065.5	57	99.84%		2020
Severn Trent Water	WEDNESFIELD - AMOS LA/BELLAMY LA (CSO)	T/08/22021/O	Single Discharge			0.9	2	100.00%		2020
Severn Trent Water	WEDNESFIELD - WATERY LANE (CSO)	T/08/35944/O	Single Discharge			12.7	54	93.32%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	WEDNESFIELD ROAD/WOLVERHAMPTON (SPRINGFIELD - WEDNESFIELD ROAD (CSO))	S/06/08749/O	Single Discharge			1.3	1	99.57%		
Severn Trent Water	WELFORD (STW)	S/10/26433/R	A2			22.3	8	99.40%		2020
Severn Trent Water	WELLESBOURNE (STW)	S/13/26721/R	A2			679.2	62	99.98%		2020
Severn Trent Water	WELLESBOURNE (STW)	S/13/26721/R	A3			0.0	0	100.00%		2020
Severn Trent Water	WELLINGTON - BUCKS HEAD (CSO)	S/04/50087/O	Single Discharge			56.5	42	99.99%		
Severn Trent Water	WELLINGTON - GAS WORKS (SST)	S/04/50010/O	Single Discharge			0.0	0	96.49%		2020
Severn Trent Water	WELLINGTON - MORRISONS (SST)	S/04/50009/O	Single Discharge			2.8	3	99.97%		2020
Severn Trent Water	WEM - ASTON ROAD (STW)	S/04/55285/R	A2			629.0	53	99.98%		2020
Severn Trent Water	WEM - DRAWELL LANE (SPS)	S/04/05896/O	Single Discharge			0.0	0	99.94%		2020
Severn Trent Water	WEM - THE GROVE 36 (REAR GARDEN) (CSO)	S/04/21012/O	Single Discharge			9.1	11	99.97%		
Severn Trent Water	WEM - WELLGATE (CSO)	S/04/21013/O	Single Discharge			57.3	45	99.99%		
Severn Trent Water	WERRINGTON - CLOUGH LANE (CSO)	T/01/36468/O	Single Discharge			0.2	4	100.00%		2020
Severn Trent Water	WESSINGTON - BACK LANE (SPS)	T/41/40327/O	A1			844.5	53	99.88%		2020
Severn Trent Water	WESSINGTON - MATLOCK ROAD (CSO)	T/41/22277/O	Single Discharge			0.0	0	98.94%		2020
Severn Trent Water	WEST BROMWICH - CHARLEMONT ROAD (CSO)	T/08/22796/O	Single Discharge			0.1	1	98.26%		
Severn Trent Water	WEST BROMWICH - LYNDON/GRAFTON RD (CSO)	T/08/21443/O	Single Discharge			1.0	3	100.00%		2020
Severn Trent Water	WEST BROMWICH - SUSSEX AVENUE (CSO)	T/08/35029/O	Single Discharge			0.4	1	99.87%		
Severn Trent Water	WEST FELTON (STW)	S/01/56178/R	A2			31.3	6	99.98%		2020
Severn Trent Water	WESTACRE CRESCENT SSO (COMPTON - WESTACRE CRES (CSO))	S/06/55744/O	Single Discharge			447.5	21	93.43%		
Severn Trent Water	WESTGATE STORM OVERFLOW (BRIDGNORTH - WESTGATE/VICTORIA RD (CSO))	S/02/20966/O	Single Discharge			13.4	20	99.99%		
Severn Trent Water	WESTLANDS - PRIORY ROAD (CSO)	T/01/21284/O	Single Discharge			11.6	26	99.91%		
Severn Trent Water	WESTON - MEADOW LANE (SPS)	TSC3645	A1			8.1	2	100.00%		2020
Severn Trent Water	WESTON-UNDER-LIZARD - WESTON HALL (SPS)	S/05/06051/O	A1			9.6	8	100.00%		2020
Severn Trent Water	WESTON-UNDER-WETHERLEY Sewage Treatment Works (WESTON-UNDER-WETHERLEY (Sewage Treatment Works))	S/12/26152/R	A2			438.4	34	96.17%		
Severn Trent Water	WESTRAY DRIVE STORM OVERFLOW (HINCKLEY - WESTRAY DRIVE (CSO))	T/19/20313/O	Single Discharge			0.5	2	99.99%		
Severn Trent Water	WESTWOOD BROOK (STW)	T/41/45991/R	A2			846.7	75	99.86%		2020
Severn Trent Water	Wharf Rd PS Ellesmere CSO	S/03/09296/O	Single Discharge			52.9	41	99.34%		
Severn Trent Water	WHATCOTE - CHURCH LANE (SPS)	S/14/09243/O	A1			679.2	41	100.00%		2020
Severn Trent Water	WHATSTANDWELL (STW)	T/40/45704/R	A2			0.0	0	100.00%		2020
Severn Trent Water	WHEATON ASTON (STW)	T/03/35649/R	A2			930.5	63	100.00%		2020
Severn Trent Water	WHEELERS LANE,KINGS HEATH (KINGS HEATH - ARDENCOTE ROAD 24 (CSO))	T/12/35459/O	Single Discharge			0.5	2	100.00%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	WHEELEYS RD SSO (EDGBASTON - WHEELEYS RD (CSO))	T/09/30216/O	Single Discharge			0.5	3	99.77%		
Severn Trent Water	WHEELWRIGHT RD/ALLEYNE RD (BROMFORD - WHEELWRIGHT ROAD (CSO))	T/10/22777/O	Single Discharge			0.3	4	100.00%		
Severn Trent Water	WHETSTONE (STW)	T/50/45829/R	A2			316.9	32	99.99%		2020
Severn Trent Water	Whissendine PS	T/54/45935/O	Single Discharge			239.3	41	100.00%		2020
Severn Trent Water	WHITBOURNE WORKS (STW)	S/09/55935/R	A2			276.0	58	99.94%		2020
Severn Trent Water	WHITMINSTER - ATTWOOLS (SPS)	S/20/25534/O	Single Discharge			433.3	36	99.98%		
Severn Trent Water	WHITTINGTON - BABBINSWOOD (TPS)	S/03/05852/O	Single Discharge			934.1	63	100.00%		2020
Severn Trent Water	WHITTINGTON - CHURCH LANE (WORCS) (SPS)	S/19/25475/O	Single Discharge			95.9	11	99.99%		2020
Severn Trent Water	WHITWELL (STW)	T/73/46317/R	A3			1.5	3	100.00%		2020
Severn Trent Water	WHITWELL WASTEWATER TREATMENT WORKS (WHITWELL (Sewage Treatment Works))	T/73/46317/R	A2			8.8	27	100.00%		
Severn Trent Water	WHITWICK - PARSONWOOD HILL (CSO)	T/57/46238/O	Single Discharge			223.5	48	100.00%		2020
Severn Trent Water	WICKERSLEY - SECOND LANE (SPS)	T/76/09342/O	A1			11.7	8	97.98%		2020
Severn Trent Water	WICKHAMFORD - GOLDEN LANE (SPS)	S/16/26141/O	Single Discharge			51.9	4	100.00%		2020
Severn Trent Water	WIGHTWICK - SABRINA ROAD	No known permit reference	Single Discharge			2.4	2	99.70%		2020
Severn Trent Water	WIGSTON - BLABY RD (CSO)	T/83/02690/O-1	Single Discharge			35.7	31	100.00%		2020
Severn Trent Water	WIGSTON - COUNTESTHORPE ROAD (CSO)	T/83/02690/O-2	Single Discharge			34.2	4	100.00%		2020
Severn Trent Water	WIGSTON - CROW MILLS PS (CSO)	T/51/12328/R	A1			37.0	12	99.79%		
Severn Trent Water	WIGSTON - PARK ROAD/ORANGE STREET (CSO)	T/83/02690/O-3	Single Discharge			12.5	20	98.04%		
Severn Trent Water	WIGSTON PARVA STW SSO	T/50/45544/R	A2			0.0	0	100.00%		2020
Severn Trent Water	WIGSTON URBAN DISTRICT COUNCIL (WIGSTON - GAS LANE (CSO))	T/83/01666/O-2	Single Discharge			1385.1	85	95.96%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	WIGSTON URBAN DISTRICT COUNCIL (WIGSTON - MOAT STREET (CSO))	T/83/01666/O-3	Single Discharge			0.6	1	100.00%		
Severn Trent Water	WILLENHALL - WALSALL RD/ACORN ST (CSO)	T/08/21113/O	Single Discharge			1.6	1	99.98%		2020
Severn Trent Water	WILLENHALL (CSO)	EPRVP3222XF	Single Discharge			20.8	5	100.00%		2020
Severn Trent Water	WILLOUGHYBY CLOSE CSO (MELTON - WILLOUGHBY CLOSE (R;NO.17) (CSO))	TSC2141	Single Discharge			6.5	2	100.00%		
Severn Trent Water	WILNECOTE - WATLING STREET (CSO)	454-4	Single Discharge			2.2	8	91.71%		
Severn Trent Water	WINCHCOMBE - VINEYARD STREET (CSO)	S/18/20336/O	Single Discharge			37.3	12	99.96%		
Severn Trent Water	WINCHCOMBE SEWAGE TREATMENT WORKS (WINCHCOMBE (Sewage Treatment Works))	S/18/26092/R	A2			675.3	68	100.00%		
Severn Trent Water	WINKHILL PUMPING STATION (CSO)	T/14/35329/O	Single Discharge			132.3	9	99.97%		2020
Severn Trent Water	WINSON GREEN - ALL SAINTS HOSPTL 2 (CSO)	T/09/22246/O	Single Discharge			0.7	2	99.95%		
Severn Trent Water	WINSON GREEN - PERROTT STREET (CSO)	TSC1455	Single Discharge			0.2	1	96.19%		
Severn Trent Water	WINSON GREEN - WELLINGTON ST (CSO)	T/09/21430/O	Single Discharge			3.6	9	99.96%		
Severn Trent Water	WINSON GREEN - WINSON GREEN RD (CSO)	T/08/22704/O	Single Discharge			22.6	46	99.98%		
Severn Trent Water	WIRKSWORTH (STW)	T/43/45907/R	A2			1191.9	68	100.00%		2020
Severn Trent Water	WITTON - GEC GROUNDS (CSO)	T/09/03339/O-28	Single Discharge			23.0	23	100.00%		2020
Severn Trent Water	WITTON - WITTON ROAD (CSO)	DT/9760	Single Discharge			0.0	0	100.00%		2020
Severn Trent Water	WITTON LANE ASTON LANE JUNCTION	T/09/03339/O-25	Single Discharge			59.3	50	100.00%		2020
Severn Trent Water	Witton Lane, Witton, Birmingham - replacement for -17	TSC2147	Single Discharge			2.4	4	100.00%		2020
Severn Trent Water	Woden Road West CSO	No known permit reference	Single Discharge			17.6	6	100.00%		2020
Severn Trent Water	WOLLATON ROAD STORM OVERFLOW (BEESTON - WOLLATON ROAD (CSO))	T/62/22083/O	Single Discharge			6.5	20	99.54%		
Severn Trent Water	Wolseley Rd Rugeley PS	T/05/35781/O	A1			16.3	10	91.46%		2020
Severn Trent Water	WOLSEY ROAD (OAK HILL - WOLSELEY ROAD (CSO))	T/01/30156/O	Single Discharge			2.6	1	94.82%		
Severn Trent Water	WOLVERHAMPTON - GREAT HAMPTON ST (CSO)	S/06/55301/O	Single Discharge			3.3	7	99.92%		
Severn Trent Water	WOLVERHAMPTON - POND LA/KENT RD (CSO)	T/08/36056/O	Single Discharge			2.1	2	99.86%		2020
Severn Trent Water	WOLVERHAMPTON - VIADUCT DRIVE (CSO)	S/06/56044/O	Single Discharge			0.0	0	99.90%		
Severn Trent Water	WOLVERLEY - NEWTOWN (CSO)	TSC3701	Single Discharge			0.0	0	99.80%		2020
Severn Trent Water	WOLVERTON SPS - STORM OVERFLOW (WOLVERTON VILLAGE PS (CSO))	S/13/09366/O	A1			3.6	1	100.00%		

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	WOMBOURNE - GIGGETTY LANE (CSO)	S/06/07340/O-2	Single Discharge			36.0	25	99.98%		
Severn Trent Water	WOMBOURNE SEWAGE TREATMENT WORKS (WOMBOURNE (STW))	S/06/56197/R	Single Discharge			218.3	29	100.00%		
Severn Trent Water	WOOD END SSO (WOOD END - WOOD STREET (CSO))	T/14/35328/O	Single Discharge			38.5	36	99.95%		
Severn Trent Water	WOOD GREEN - MYVOD ROAD (CSO)	T/08/30064/O	Single Discharge			0.0	0	99.99%		
Severn Trent Water	WOOD GREEN - POPLAR ROAD (CSO)	T/08/30065/O	Single Discharge			24.4	9	99.97%		
Severn Trent Water	WOODCHESTER - BATH RD/STATION RD (CSO)	S/22/20979/O	Single Discharge			0.8	1	100.00%		2020
Severn Trent Water	WOODHOUSE - SCHOOL LANE (CSO)	T/57/45736/O	Single Discharge			23.1	26	96.99%		
Severn Trent Water	WOODHOUSE - VICARY LANE (CSO)	T/57/45737/O	Single Discharge			66.3	37	97.27%		
Severn Trent Water	WOODHOUSE EAVES - BRAND LANE (CSO)	T/57/45738/O	Single Discharge			0.0	0	93.96%		
Severn Trent Water	WOODS LANE STORM OVERFLOW (DERBY - WOODS LANE 74 (CSO))	T/47/22321/O	Single Discharge			0.1	1	89.35%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	WOODS LANE/STOCKBROOK ST JCN SSO (DERBY - WOODS LA/STOCKBROOK ST (CSO))	T/47/22322/O	Single Discharge			0.3	2	99.98%		
Severn Trent Water	WOODSEAVES (STW)	S/04/56177/R	A2			71.7	44	99.88%		2020
Severn Trent Water	WOODSETTS (STW)	T/76/45627/R	A2			69.4	15	100.00%		2020
Severn Trent Water	WOODSIDE - HOLLY HALL ROAD (CSO)	S/06/22535/O	Single Discharge			2.0	3	93.73%		2020
Severn Trent Water	WOODTHORPE - CONINGSBY GDNS EAST (CSO)	T/63/08750/O	Single Discharge			0.4	1	90.92%		2020
Severn Trent Water	WOODVILLE - BROOMY FURLONG (CSO)	T/36/09236/O-1	Single Discharge			9.1	10	99.93%		2020
Severn Trent Water	Woodyard Lane 20 Whetstone CSO	T/51/21105/O	Single Discharge			15.4	8	100.00%		2020
Severn Trent Water	WOOLSTHORPE (STW)	T/65/45569/R	A2			174.4	31	100.00%		2020
Severn Trent Water	WOOLSTONE (STW)	S/17/26098/R	A2			478.3	85	92.13%		2020
Severn Trent Water	WOOTTON WAWEN (STW)	S/15/26259/R	A2			141.1	18	99.87%		2020
Severn Trent Water	WORCESTER - BATH ROAD (CSO)	S/08/26842/O	Single Discharge			6.3	3	99.94%		
Severn Trent Water	WORCESTER - BATTENHALL ROAD (CSO)	S/08/56222/O	Single Discharge			4.2	31	84.97%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	WORCESTER - OMBERSLEY RD (CSO)	S/08/21010/O	Single Discharge			7.9	20	91.27%	For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	Worcester Rd Malvern SSO	S/08/20941/O	A1			28.1	10	99.82%		2020
Severn Trent Water	WORCESTER Sewage Treatment Works (WORCESTER - BROMWICH ROAD (Sewage Treatment Works))	S/07/55380/R	A2			1464.9	93	100.00%		
Severn Trent Water	WORKSOP - EASTGATE (CSO)	T/75/01386/O	Single Discharge			8.5	9	99.99%		
Severn Trent Water	WORKSOP - KILTON HILL (CSO)	T/75/01386/O-2	Single Discharge			2.0	4	99.79%		
Severn Trent Water	WORKSOP-MANTON (STW)	T/75/45222/R	A2			225.2	29	100.00%		2020
Severn Trent Water	WORKSOP-MANTON (STW)	T/75/45222/R	A3			16.1	4	100.00%		2020
Severn Trent Water	WORMINGTON SEWAGE TREATMENT WORKS (WORMINGTON (Sewage Treatment Works))	S/18/25840/R	A2			222.4	45	100.00%		
Severn Trent Water	WORTHEN (STW)	S/02/55952/R	A2			157.2	28	93.18%		2020
Severn Trent Water	WORTHINGTON (STW)	T/36/45905/R	A2			242.0	21	100.00%		2020
Severn Trent Water	WYCHBOLD - CROWN LANE (CSO)	S/07/26835/O	Single Discharge			109.6	39	99.99%		
Severn Trent Water	WYCHBOLD (STW)	S/07/56286/R	A2			415.5	33	99.99%		2020
Severn Trent Water	WYCOMB - MIAN ROAD (TPS)	T/54/07710/O-1	Single Discharge			497.5	35	99.82%		2020
Severn Trent Water	WYMONDHAM (STW)	T/54/45839/R	A2			131.7	14	99.99%		2020
Severn Trent Water	YARDLEY - BLAKESLEY ROAD (CSO)	T/12/21541/O	Single Discharge			78.4	26	99.97%		2020
Severn Trent Water	YARDLEY - NEWBRIDGE ROAD (CSO)	T/12/21252/O	Single Discharge			15.4	18	99.97%		2020
Severn Trent Water	YARDLEY WOOD RD/HAUNCH LANE JCN CSO (YARDLEY WOOD - FIRTH DRIVE 9 (SST))	T/12/36479/O	Single Discharge			49.6	27	99.69%		
Severn Trent Water	YEAVELEY (STW)	T/34/35885/R	A3			99.8	26	100.00%		2020
Severn Trent Water	YEAVELEY Sewage Treatment Works (YEAVELEY (Sewage Treatment Works))	T/34/35885/R	A2			63.5	38	99.90%		
Severn Trent Water	YELVERTOFT (STW)	S/10/26054/R	A2			87.7	15	100.00%		2020
Severn Trent Water	YEW TREE - 27 PLANE TREE ROAD (CSO)	TSC691	Single Discharge			2.7	10	99.84%		
Severn Trent Water	YEW TREE - BRACKENDALE DRIVE (CSO)	CP3826XC	Single Discharge			13.4	17	92.48%		
Severn Trent Water	Yoxall Combined Sewer	T/07/30300/O	A1			4.4	16	94.25%		2020

Table 2: EDM Monitored Sites with Additional Data Addendums - SEE APPENDIX 1

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	EDWARD STREET STORM OVERFLOW (BALSALL HEATH - EDWARD ROAD (CSO))	T/09/21428/O	Single Discharge			0.2	1	93.38%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	EVESHAM - BURFORD ROAD 8&9 (CSO)	S/17/05968/O	Single Discharge			0.9	8	87.40%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	Floyer Road Bordesley Green	No known permit reference	Single Discharge			0.0	0	11.08%	An addendum of data will be submitted for this site as per the covering email on submission.	2020
Severn Trent Water	HOLLOWAY SCHOOL ROAD (TETTENHALL - SCHOOL ROAD/WOOD ROAD (CSO))	T/03/12429/O-2	Single Discharge			0.0	0	8.03%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	HUNCOTE - FOREST RD/EUNICE AVE (CSO)	DT/8047 & TSC707	Single Discharge			0.0	0	79.64%	An addendum of data will be submitted for this site as per the covering email on submission.	2020
Severn Trent Water	KEGWORTH - WHATTON ROAD (CSO)	T/57/08994/O-2	Single Discharge			0.0	1	64.97%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	MORDA - WESTON ROAD (CSO)	S/01/22537/O	Single Discharge			8.8	6	94.18%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	OPPOSITE NO.155 THE AVENUE CSO (HARPFIELDS - THE AVENUE 155 (CSO))	T/01/35717/O	Single Discharge			0.1	1	98.64%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	QUARNDON - CHURCH ROAD 114 (CSO)	T/47/21116/O	Single Discharge			1.6	3	65.48%	An addendum of data will be submitted for this site as per the covering email on submission.	2020
Severn Trent Water	ROCESTER - ASHBOURNE ROAD (CSO)	T/30/30181/O	Single Discharge			0.0	0	0.00%	An addendum of data will be submitted for this site as per the covering email on submission.	2020
Severn Trent Water	SHUTTINGTON (SPS)	T/21/00159/R-3	Single Discharge			0.0	0	0.00%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	SMETHWICK - DOWNING STREET (CSO)	T/08/35702/O	Single Discharge			1.1	3	94.10%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	SMETHWICK - RABONE LANE (CSO)	T/08/35705/O	Single Discharge			115.8	8	92.43%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	SS FROM QUARRY LANE CSO NORTHFIELD (NORTHFIELD - QUARRY LANE (CSO))	T/09/36175/O	Single Discharge			0.8	5	99.74%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	SSO SERVING NORTH CHURCH STREET (BAKEWELL - NORTH CHURCH STREET (CSO))	T/38/45892/O	Single Discharge			4.2	16	98.86%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	THE WHARFAGE PUMPING STATION (IRONBRIDGE - WHARFAGE (SPS))	S/02/07445/O	A1			363.2	40	99.68%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	TRENTHAM - STONE RD/BANKHOUSE RD (CSO)	T/01/35786/O	Single Discharge			4.3	14	59.08%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	VENTNOR AVENUE (LOZELLS - VENTNOR AVENUE (CSO))	T/08/22031/O	Single Discharge			0.2	2	93.21%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	VICARAGE ROAD COMBINED STORM O'FLOW (HARBORNE - VICARAGE ROAD O/S 91 (CSO))	T/09/36306/O	Single Discharge			8.4	19	98.64%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	WEST BROMWICH - LAMBERT END (CSO)	T/08/36060/O	Single Discharge			3.3	9	54.23%	An addendum of data will be submitted for this site as per the covering email on submission.	2020
Severn Trent Water	WINSON GREEN - LODGE ROAD (CSO)	T/09/35898/O	Single Discharge			29.3	27	65.08%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	WINSON GREEN - WELLINGTON RD (CSO)	T/09/21429/O	Single Discharge			2.4	6	87.77%	An addendum of data will be submitted for this site as per the covering email on submission.	
Severn Trent Water	WOLVERHAMPTON - BILSTON RD 1 (CSO)	T/08/20244/O	Single Discharge			2.0	2	97.92%	An addendum of data will be submitted for this site as per the covering email on submission.	2020

Table 3: EDM Monitored Sites with Installation, Maintenance or River Ingress issues

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	5 Severn Terrace	No known permit reference	Single Discharge			664.3	58	81.61%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	ABBERLEY (COMMON RD) Sewage Treatment Works STORM SEW (ABBERLEY - THE COMMON (Sewage Treatment Works))	S/08/55842/O	A2			2252.0	119	99.88%	Maintenance issues have been identified which affect the number of reported spills - these issues have been resolved.	
Severn Trent Water	ABBEY HULTON - BIRCHES HEAD ROAD (SST)	T/01/35770/O	Single Discharge			292.7	95	86.17%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	ABBEY HULTON - GREASLEY ROAD 1 (CSO)	T/01/35800/O	Single Discharge			303.6	34	69.41%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	ALFRETON (STW)	T/41/45824/R	A2			5.3	6	75.83%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	ALLESTREE - KEDLESTON RD/MARKEATON LN (SO)	T/46/12418/O	Single Discharge			8.8	2	30.75%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	ALVASTON - RAYNESWAY PARK DRIVE (CSO)	T/48/45201/O	Single Discharge			190.4	37	79.70%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	ALVERTON (STW)	T/65/45944/R	A2			5429.2	230	99.99%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	AREAS MILFORD & BELPER/SM & EM O/F (The Meadows Ps)	T/42/03392/O-3	Single Discharge			85.7	15	87.00%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	ARELEY KINGS PUMPING STATION (Areley Kings Stourport on Severn PS)	S/08/55511/O	A1			1835.1	112	99.91%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	Arkwright Walk / Radcliffe Street	No known permit reference	Single Discharge			45.5	28	76.72%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	ARMTHORPE (STW)	T/83/45356/R	A2			1913.2	111	100.00%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	ARNESBY (STW)	T/51/45648/R	A2			492.1	122	78.58%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	ASFORDBY,KIRBY BELLARS,ROTHERBY PSS (ROTHERBY - MAIN STREET (SPS))	T/55/02241/O-3	A1			5769.0	286	99.35%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	Ash Green Close CSO	No known permit reference	Single Discharge			0.1	2	45.73%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	ASHTON UNDER HILL - CORNFIELD WAY (CSO)	S/17/26431/O	Single Discharge			16.1	2	70.95%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	ASPLEY - HARWILL CRESCENT (CSO)	T/64/21889/O	Single Discharge			23.9	62	85.99%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	ASTON - HOLTE ROAD (CSO)	NPSWQD010065	Single Discharge			3.4	1	46.16%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	ASTON SEWAGE PUMPING STATION (ASTON-BY-STONE (SPS))	T/01/30173/O	A1			15.8	3	87.27%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	ATHERSTONE (STW)	T/19/35541/R	A2			4731.7	229	99.97%	Maintenance issues have been identified which affect the number of reported spills - these issues have been resolved.	2020
Severn Trent Water	AVENING (STW)	S/22/26628/R	A2			283.0	90	74.32%	River ingress affecting number of spills being reported at this location. Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	AYLESTONE - MARSDEN LANE (CSO)	T/52/12345/O	Single Discharge			24.9	3	83.21%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BADSEY - HIGH STREET (CSO)	S/16/25516/O	Single Discharge			470.6	42	78.00%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	BAGWORTH - OFF HAWTHORN ROAD (SPS)	WQD006539	A1			0.0	0	78.54%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	BALSALL COMMON (STW)	T/11/35953/R	A2			776.1	54	86.37%	Maintenance issues have been identified and resolved at this site.	2020
Severn Trent Water	BAMFORD - ROSE GARDEN (CSO)	T/38/21466/O	Single Discharge			481.9	83	84.21%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BAMFORD - THE HOLLOW (CSO)	T/38/21621/O	Single Discharge			60.6	25	83.32%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BARKBY - FIELD 3234 (CSO)	T/55/21460/O	Single Discharge			0.9	3	89.69%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	BARLASTON COMBINED Sewer OVERFLOW (BARLASTON - OLD ROAD (CSO))	T/01/12326/O	Single Discharge			4.9	6	51.67%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BARLASTOON (BARLASTON - FIELD EAST of RAILWAY (CSO))	T/01/20998/O	Single Discharge			392.2	22	77.04%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	BARROW - BREACHFIELD ROAD (CSO)	T/57/03655/O	Single Discharge			6.5	8	89.66%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BARROW & QUORN Sewage Treatment Works (BARROW & QUORN (Sewage Treatment Works))	T/57/45505/R	A2			2029.6	104	94.26%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	BARSTON (STW)	T/11/35994/R	A2			714.4	44	82.73%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	BASLOW - CHURCH LANE (CAR PARK) (SPS)	T/38/40243/O	A1			0.0	0	49.73%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	Bath Lane Mansfield STW PS	T/70/45038/O	A2			131.2	17	8.94%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	BECKFORD (STW)	S/17/25751/R	A2			2061.3	107	100.00%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	BEDWORTH - NUNEATON ROAD (CSO)	T/19/02814/O	Single Discharge			2.6	14	85.01%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission.	
Severn Trent Water	BEESTON - WOLLATON RD/HIGH RD (CSO)	T/62/21329/O	Single Discharge			17.8	21	78.53%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BEESTON (LILAC GROVE) Sewage Treatment Works (BEESTON -LILAC GROVE (Sewage Treatment Works))	T/62/45769/R	A2			2625.5	176	100.00%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BELPER - BRIDGE HILL/BELPER LANE (CSO)	T/42/45740/O	Single Discharge			47.1	13	86.85%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BELPER - DERBY ROAD (CSO)	T/42/45740/O-1	Single Discharge			8.1	15	83.29%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	BILLESDON (STW)	T/51/45517/R	A2			596.5	132	100.00%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	BILSTONE - CONGERSTONE (SPS)	T/20/30033/O	Single Discharge			19.3	6	85.08%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	BIRCH DRIVE STORM OVERFLOW (STOURBRIDGE - BIRCH DRIVE (CSO))	S/06/21183/O	Single Discharge			0.0	0	43.90%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	BIRSTALL - WORCESTER AVENUE (CSO)	T/53/01523/O-3	Single Discharge			0.0	0	84.71%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	BISHOPS CASTLE - UNION STREET (CSO)	S/09/21721/O	A1			362.6	70	86.13%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	BLACKFRIARS - WESTGATE (SPS)	TSC4079	A1			73.8	4	68.86%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	BLAKENEY (STW)	S/20/26262/R	A3			41.8	8	59.16%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	BOATHORSE ROAD CSO (TUNSTALL - BOATHORSE ROAD (CSO))	T/01/35893/O	Single Discharge			745.5	47	86.07%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	BOLEHALL - GLASCOTE ROAD (CSO)	T/21/35998/O	Single Discharge			35.4	54	81.45%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BORDESLEY - LIVERPOOL STREET (CSO)	DT/9820	Single Discharge			0.0	0	28.53%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	BORROWASH - NEWBOLD AVENUE (CSO)	T/48/45655/O	Single Discharge			206.4	42	80.74%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	BOWEN COOKE AVE SEWAGE PUMPING STA (PERTON - BOWEN-COOKE AVENUE (SPS))	T/03/35273/O	A1			3.5	1	86.78%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	BRACKENDALE WAY STORM OVERFLOW (PEDMORE - BRACKENDALE WAY (CSO))	S/06/21176/O	Single Discharge			92.0	44	84.60%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	Bradbury Lane Cannock - Ops emergency code of sov-999-99-23	No known permit reference	Single Discharge			0.0	0	48.87%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission.	2020
Severn Trent Water	BRAILSFORD SEWAGE TREATMENT WORKS (BRAILSFORD (Sewage Treatment Works))	T/34/36002/R	A2			340.4	66	89.67%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BRAUNSTONE - AMY STREET 14 (CSO)	T/52/01648/O	Single Discharge			5.3	1	89.16%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BRAUNSTONE - WESTOVER ROAD 66 (CSO)	T/52/00990/O	Single Discharge			82.1	42	69.98%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	BREEDON (STW)	T/36/45725/R	A2			1038.0	224	90.37%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	Bretby Park area (CSO)	No known permit reference	Single Discharge			0.0	0	89.86%	Maintenance issues have been identified and resolved at this site.	2020
Severn Trent Water	BRIDGE STREET (BELPER - BRIDGE STREET 122/130 (CSO))	T/42/20903/O	Single Discharge			209.8	115	99.87%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BRIDGNORTH - HOLLYBUSH ROAD (CSO)	S/02/12217/O	Single Discharge			0.0	0	84.83%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BRIERLEY HILL ROAD STORM OVERFLOW (BRIERLEY HILL - BRIERLEY HILL ROAD (CSO))	S/06/55761/O	Single Discharge			0.0	0	85.73%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	BRINDLEY FORD - PECK MILL LANE (CSO)	T/01/36405/O	Single Discharge			24.3	33	76.59%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	BRINSLEY - CORDY LANE 2 (CSO)	T/61/21122/O	Single Discharge			0.6	2	89.57%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	BROADHEATH - OLD SD WORKS (SPS)	S/09/55763/O	A1			28.6	5	73.15%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	BROADOAK (SPS)	S/20/25720/O	Single Discharge			5.0	1	16.56%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	BROOKHOUSES - BROOKHOUSE WAY (CSO)	T/32/35163/O	Single Discharge			37.1	16	80.94%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	BROOKS LANE - STORM/EMERGENCY O/F (Brooks Ln MH13 Whitwick SSO)	T/57/08799/O-2	Single Discharge			226.5	22	74.34%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	Brookside Hinckley CSO	T/19/09205/O	Single Discharge			486.1	28	84.06%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	BROSELEY - COCKSHUTT LANE (CSO)	S/02/21005/O	Single Discharge			307.7	81	82.99%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	BROUGHTON ASTLEY - BROUGHTON WAY (CSO)	T/50/07567/O	Single Discharge			85.5	15	84.22%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	BRYANS LANE (RUGELEY - BRYANS LANE (CSO))	T/05/08345/O	Single Discharge			275.7	54	63.92%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	BUCKNALL - WERRINGTON ROAD (CSO)	T/01/35719/O	Single Discharge			3748.0	195	99.90%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	Buck's Head Football Ground	No known permit reference	Single Discharge			0.0	0	0.00%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	BULKINGTON WWTW (BULKINGTON (Sewage Treatment Works))	T/19/35774/R	A2			1957.6	164	92.87%	Maintenance issues have been identified which affect the number of reported spills - these issues have been resolved.	
Severn Trent Water	BULWELL - HUCKNALL LA/LAWTON DR (CSO)	T/63/40226/O	Single Discharge			3.6	1	24.06%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	BULWELL - VERNON ROAD 129 (CSO)	T/64/21890/O	Single Discharge			0.0	0	0.00%	Reporting impacted by installation issues - action taken to resolve for next year's submission.	2020
Severn Trent Water	BURSLEM STW OVERFLOW (CSO)	T/01/35900/O	Single Discharge			37.1	7	84.73%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	BURTON UPON TRENT - FERRY ST/HEATH RD (CSO)	No known permit reference	Single Discharge			9.8	10	78.37%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	BUXTON (STW)	T/39/45680/R	A2			1542.3	161	81.97%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	C.L.HICKS LTD (COMPTON - OPP 14 BRIDGNORTH RD (CSO))	S42/3	Single Discharge			25.6	74	48.10%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	CALLOW BROOK (RUBERY - WINDMILL AVENUE (CSO))	T/09/00786/O	Single Discharge			0.0	0	82.18%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	CANNOCK - CANNOCK RD/CEMETERY RD (CSO)	TSC399	Single Discharge			8.7	8	77.21%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	CANNOCK - CANNOCK ROAD/SANKEY ROAD (CSO)	T/03/12430/O	Single Discharge			0.1	1	81.69%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	CANNOCK - CEMETERY RD (CENTRAL PH) (CSO)	TSC432	Single Discharge			85.5	58	81.89%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	CAPPY FARM PUMPING STATION (CASTLE GRESLEY - CASTLE ROAD (SPS))	T/24/30147/O	A1			2162.1	167	85.89%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	CARLTON - BURTON AVENUE / FOXHILL ROAD CSO	T/64/45354/O	Single Discharge			0.0	0	83.04%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	CARLTON - CAVENDISH ROAD (CSO)	WQ/7/1881-7	Single Discharge			32.9	30	86.30%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	CARLTON - FOXHILL RD/BELL STREET (CSO)	T/64/08304/O-5	Single Discharge			80.9	41	81.91%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	CARSINGTON - B5035 (SPS)	CSO/T/413	A1			0.9	2	74.22%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	CASTLE GRESLEY - BURTON ROAD (CSO)	T/24/21126/O	Single Discharge			280.7	56	83.29%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	CASTLE ORCHARD - STORM OVERFLOW (DUFFIELD - MILFORD ROAD (CSO))	T/42/07163/O	Single Discharge			373.6	156	99.87%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	CASTLEFIELDS - BURTON STREET (CSO)	S/02/21039/O	Single Discharge			1390.2	125	99.76%	River ingress affecting number of spills being reported at this location.	
Severn Trent Water	CASTLEFIELDS - DANA STEPS (CSO)	S/02/21486/O	Single Discharge			1599.6	108	99.86%	River ingress affecting number of spills being reported at this location.	
Severn Trent Water	CASTLEFIELDS - VICTORIA ST (CSO)	S/02/21365/O	Single Discharge			2089.6	158	99.71%	River ingress affecting number of spills being reported at this location.	
Severn Trent Water	CHADDESDEN - JOHN BERRYSFORD CLOSE (CSO)	T/48/22376/O	Single Discharge			185.2	59	86.96%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	CHADDESDEN - NOTTINGHAM RD (CSO)	T/48/22430/O	Single Discharge			0.0	0	88.68%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	CHAMBERLAIN AVENUE (BOOTHEN - CHAMBERLAIN AVENUE (CSO))	T/01/30171/O	Single Discharge			21.6	29	28.52%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	CHARLES ROAD STORM Sewer OVERFLOW (STOURBRIDGE - CHARLES ROAD (CSO))	S/06/55455/O	Single Discharge			10.2	1	71.27%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	CHEADLE - QUEEN ST/OAKAMOOR RD (CSO)	T/32/22503/O	Single Discharge			101.3	73	64.31%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	CHELLASTON - STATION ROAD 83 (CSO)	NPSWQD000198	Single Discharge			206.3	142	99.74%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	Chelmsford Drive	No known permit reference	A1			1572.4	67	87.42%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	CHESLYN HAY - LITTLEWOOD (SPS)	T/03/20196/O	A1			32.4	4	75.86%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	CHILWELL - HIGHROAD/HEATHFIELD (CSO)	T/62/07974/O	Single Discharge			7.2	7	70.83%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	CHURCH LANE PUMPING STATION (THORPE (SPS))	T/29/30278/O	Single Discharge			5329.7	248	89.16%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	CHURCH WARSOP - MANOR ROAD (CSO)	T/71/40116/O	Single Discharge			0.0	0	86.16%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission.	
Severn Trent Water	CHURCHAM - LAKE LANE (SPS)	TSC3241	Single Discharge			383.5	34	82.11%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	CINDERFORD - LORRY PARK (CSO)	S/20/21136/O	Single Discharge			264.4	31	43.06%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	CLAYMILLS (STW)	T/24/36133/R	A2			4773.4	218	100.00%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	CLEE HILL - TENBURY ROAD (CSO)	S/09/50069/O	Single Discharge			0.0	0	77.94%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	COALPORT Sewage Treatment Works (COALPORT (Sewage Treatment Works))	S/02/56070/R	A2			465.5	128	81.84%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	COCKS MOOR WOODS GOLF COURSE CSO (BRANDWD END-COCKS MOOR WD GLF CRSE (CSO))	T/12/36474/O	Single Discharge			471.1	47	80.03%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	COLD OVERTON (STW)	T/54/45654/R	A2			3309.2	191	100.00%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	COLWALL (STW)	S/09/55757/R	A2			1482.4	104	100.00%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	COMPTON - BRIDGNORTH ROAD	No known permit reference	Single Discharge			0.0	0	89.91%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	CORELEY - CLEE HILL (STW)	S/09/55836/O	Single Discharge			763.5	168	99.91%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	COSSINGTON - MAIN STREET (SPS)	T/56/02858/O-1	A1			0.0	0	81.63%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	Cotes Rd Barrow Cso	T/57/40133/O	Single Discharge			2.6	5	81.41%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	COTHAM (STW)	NPSWQD002550	A2			0.3	1	74.11%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	COTTAGE LANE STORM SEWAGE OVERFLOW (SHOTTERY - COTTAGE LANE (SO))	S/13/21484/O	Single Discharge			15.6	21	78.13%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	COUNTESTHORPE - ROSEBANK ROAD 50 (CSO)	T/51/02170/O	Single Discharge			3.2	2	66.60%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	COUNTESTHORPE (STW)	T/51/45760/R	A2			559.5	109	100.00%	Maintenance issues have been identified and resolved at this site.	2020
Severn Trent Water	CRICK - MAIN ROAD (SPS)	S/10/25236/O	Single Discharge			1012.3	53	87.23%	Maintenance issues have been identified and resolved at this site.	2020
Severn Trent Water	CROFT - ARBOR ROAD (CSO)	T/50/12388/O	Single Discharge			113.1	55	88.66%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	CROMFORD - VIA GELLIA (CSO)	DT/2188	Single Discharge			81.8	25	91.64%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	CROMFORD MEADOWS - PIPE BRIDGE (CSO)	DT/2184	Single Discharge			0.0	0	76.55%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	CROPTHORNE PUMPING STATION (CROPTHORNE - MAIN STREET (SPS))	S/17/25066/O	A1			27.5	2	85.14%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	CROWN HOUSE STORM OVERFLOW (BURTON UPON TRENT - NEW ST (CSO))	T/24/21517/O	Single Discharge			3.2	2	58.44%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	CSO HARBOURNE LANE/LEASOW DRIVE (SELLY OAK - HARBORNE LANE (CSO))	T/09/36440/O	Single Discharge			0.3	2	69.03%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	CUBBINGTON - OFFCHURCH ROAD (SPS)	S/12/23084/O	A1			114.1	23	88.86%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	CURBAR - RIDDINGS LANE (CSO)	671/2	Single Discharge			2341.6	202	81.71%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	Curdworth Pumping Station	No known permit reference	Single Discharge			0.0	0	45.36%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	DANIEL PLATTS TILE WORKS (TUNSTALL - CANAL LN (CSO))	T/01/30158/O	Single Discharge			2.7	4	60.74%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	DARLEY DALE - DARLEY BRIDGE PS (CSO)	817-4	Single Discharge			340.7	49	51.09%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	DARLEY DALE_DALE ROAD SOUTH (DARLEY LODGE)_OFF OLD HACKNEY LANE CSO	T/40/12431/O	Single Discharge			7.8	15	55.16%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	Dean's Farm Storage Tank	S/20/05468/R	A1			2979.8	187	100.00%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	DENSTONE - DENSTONE HALL (CSO)	T/30/21772/O	Single Discharge			9.9	5	60.35%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	DERBY - EASTGATE/PENTAGON ISLAND (CSO)	C758-2	Single Discharge			96.4	15	87.78%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DERBY - HARROW STREET (CSO)	T/48/21453/O	Single Discharge			23.4	16	73.33%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	DERBY - KEDLESTON RD (CSO)	T/47/21613/O	Single Discharge			440.8	63	83.36%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DERBY - MARKEATON ST/MERCHANT ST (CSO)	T/47/21114/O	Single Discharge			70.2	25	83.50%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	DERBY - PARCEL TERRACE (CSO)	T/47/21119/O	Single Discharge			0.1	1	82.19%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	DERBY - SHAWS GREEN (CSO)	T/17/21249/B	Single Discharge			14.8	191	82.84%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	DERBY - ST ANNES CLOSE (CSO)	T/47/00978/O	Single Discharge			8.1	9	83.29%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DERBY - STATION APP/PRIDE PARKWAY (CSO)	T/48/21470/O	Single Discharge			195.0	69	82.94%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DERBY - UTTOXETER NEW RD 2 (CSO)	T/47/20999/O	Single Discharge			9.9	11	89.61%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	DERBY - WAYZGOOSE DRIVE (CSO)	C758	Single Discharge			25.7	7	87.56%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DERBY SEWAGE TREATMENT WORKS (DERBY (Sewage Treatment Works))	T/48/45678/R	A2			0.7	2	88.60%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	Desford - Leicester Lane	No known permit reference	A1			2966.8	191	91.01%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	DIGBETH - BRADFORD STREET (CSO)	T/09/36135/O	Single Discharge			0.0	0	86.76%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	DROITWICH - STATION ROAD (CSO)	S/07/21157/O	Single Discharge			0.0	0	0.00%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	DROITWICH-LADYWOOD (STW)	S/07/55591/R	A2			1782.0	109	99.83%	Maintenance issues have been identified which affect the number of reported spills - these issues have been resolved.	2020
Severn Trent Water	Drybrook SPS (CSO)	No known permit reference	A1			0.0	0	0.00%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	DUFFIELD Sewage Treatment Works (DUFFIELD (Sewage Treatment Works))	T/44/08090/R	A2			8085.3	360	99.95%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	EAST BRIDGFORD Sewage Treatment Works (EAST BRIDGFORD (Sewage Treatment Works))	T/64/45552/R	A2			2774.5	254	99.96%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	ENDERBY - FOXHUNTER JUBILEE PARK (TPS)	T/50/07645/O-2	A1			7.6	3	81.41%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	ENDSOR SEWAGE P S (EDENSOR (SPS))	T/38/40241/O	A1			298.3	31	69.80%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	ETRURIA VALE 1 (CSO)	T/01/01822/O	Single Discharge			0.2	1	25.63%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	EVESHAM - HAMPTON SYPHON 19 (CSO)	S/17/21990/O	A1			160.1	17	73.54%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	FARNSFIELD (STW)	T/64/45766/R	A2			51.8	10	64.91%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	FINCHFIELD HILL/WHITE OAK DRIVE SSO (COMPTON - FINCHFIELD HILL (CSO))	S/06/20898/O	Single Discharge			0.1	1	43.40%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	FOLEY ROAD (LONGTON - FOLEY ROAD (CSO))	T/01/21117/O	Single Discharge			0.3	3	63.75%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	FOXHILL ROAD CSO (CARLTON - WORTH ST/FOXHILL RD (CSO))	TSC2178	Single Discharge			5276.7	261	99.88%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	GANNICOX ROAD STORM OVERFLOW (STROUD - GANNICOX ROAD 2 (CSO))	S/22/21189/O	Single Discharge			1393.1	59	86.21%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	GLASCOTE - NEW STREET (CSO)	T/21/03151/O	Single Discharge			19.3	9	79.51%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	Glebe Farm PS	S/17/23088/O	A1			0.0	0	69.00%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	GLEN PARVA - SOUTHFIELD CLOSE (SPS)	T/52/03045/O-1	A1			112.0	16	81.60%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	GLENFIELD - STAMFORD ST (CSO)	T/56/02605/O-5	Single Discharge			106.4	53	73.37%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	GLENFIELD - STAMFORD STREET (CSO)	T/56/02605/O-9	Single Discharge			1307.3	137	65.17%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	GLOUCESTER NETHERIDGE Sewage Treatment Works (NETHERIDGE (Sewage Treatment Works))	S/20/26440/R	A3			0.0	0	0.00%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	GREAT BRIDGE - WHITEHALL ROAD (CSO)	T/08/21264/O	Single Discharge			662.6	35	73.53%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	GREAT DALBY - MAIN STREET (SPS)	T/55/40329/O	A1			29.3	8	84.22%	Maintenance issues have been identified and resolved at this site.	2020
Severn Trent Water	GREAT GLEN - THE NOOK (TPS)	T/51/01368/O	A1			6347.7	275	100.00%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	GROBY - BRANTING HILL (CSO)	T/56/45416/O	Single Discharge			3.8	12	87.77%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	GROSVENOR RD SSO (BIRCHFIELD - GROSVENOR ROAD (CSO))	T/08/36173/O	Single Discharge			11.6	17	83.93%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	HADDON ROAD PPG STN - STM/EMEG O.F (BAKEWELL - HADDON ROAD (TPS))	T/38/02091/O	A1			1838.2	117	99.97%	River ingress affecting number of spills being reported at this location.	
Severn Trent Water	HAMPTON IN ARDEN - OLD STATION RD (SPS)	T/11/02379/O	A1			62.5	5	48.29%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	Hands Rd (No143) Heanor CSO	T/61/45630/O	Single Discharge			0.5	1	89.42%	Maintenance issues have been identified and resolved at this site.	2020
Severn Trent Water	HANDSWORTH - BACCHUS ROAD OPP 102 (CSO)	T/09/09232/O	Single Discharge			6.2	10	59.92%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	HANLEY - CAULDON ROAD (CSO)	T/01/21319/O	Single Discharge			56.0	48	84.00%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HANLEY - LEEK ROAD (CSO)	T/01/36022/O	Single Discharge			1324.4	135	94.29%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	HARBORNE ROAD STORM OVERFLOW (EDGBASTON - HARBORNE RD (CSO))	T/09/35290/O	Single Discharge			4.0	15	81.68%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HARBURY - MILL STREET (SPS)	TSC3453	A1			361.1	28	88.49%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	HARBY - WATSONS LANE (CSO)	T/66/09254/O-1	Single Discharge			16.0	8	84.28%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	HARRINGTON ST/HOLCOMBE ST JCN SSO (PEAR TREE - HARRINGTON ST (CSO))	T/48/21251/O	Single Discharge			2942.3	126	99.73%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	HARTHILL - FIELD OFF HARD LANE (CSO)	T/75/07062/O-2	Single Discharge			0.0	0	34.69%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	HARTLEBURY - PARK FARM (CSO)	S/08/21572/O	Single Discharge			1.2	3	76.03%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HARTPURY - WATERSMEET (CSO)	S/21/08947/O	A1			423.0	70	56.87%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	HASELOR - WALCOTE ROAD (SPS)	TSC3461	A1			2000.9	106	80.13%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	HASSELL STREET STORM S/O (NEWCASTLE - GEORGE ST/HASSELL ST (CSO))	T/01/20993/O	Single Discharge			614.1	106	99.22%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HATHERN - CROSS STREET (CSO)	T/57/02032/O-1	Single Discharge			22.2	12	82.13%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HATHERN - THE GREEN FIELD 4604 (CSO)	T/57/21093/O	Single Discharge			49.9	13	40.52%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HATTON - CHURCH AVENUE(SPS)	T/33/36343/O	A1			338.5	30	83.51%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	HELLIDON - STOCKWELL LANE (SPS)	S/12/26612/O	Single Discharge			21.3	3	31.83%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	HIGH STREET(OPPOSITE BULL ST) (HARBORNE - HIGH STREET/BULL STREET (CSO))	T/09/36419/O	Single Discharge			0.0	0	84.55%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HILTON - EGGINGTON ROAD (SPS)	T/33/30011/O	Single Discharge			6600.0	276	100.00%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	HINCKLEY - ASHBY ROAD (CSO)	T/20/02145/O	Single Discharge			6.6	13	79.92%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HINCKLEY - COVENTRY RD/NUTTS LA (CSO)	T/19/35416/O	Single Discharge			30.1	33	79.18%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HINCKLEY - FOREST ROAD (CSO)	T/19/30143/O	Single Discharge			93.4	60	80.05%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HINCKLEY - LANGDALE ROAD (CSO)	T/19/30299/O	Single Discharge			30.6	24	56.01%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HINCKLEY WASTEWATER TREATMENT WORKS (HINCKLEY (STW))	T/19/36495/R	A2			652.5	51	56.36%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	HINTON ON THE GREEN Sewage Treatment Works (HINTON-ON-THE-GREEN (Sewage Treatment Works))	S/18/25984/R	A2			392.5	114	100.00%	River ingress affecting number of spills being reported at this location. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HODSOCK (STW)	T/76/45601/R	A2			6599.1	276	99.99%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	HOLLOWAY SCHOOL ROAD (TETTENHALL - SCH RD/WOODLAND AVE (CSO))	T/03/12429/O-3	Single Discharge			8.8	16	80.10%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	Hollycroft Crescent CSO	No known permit reference	Single Discharge			0.2	1	84.82%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	HOLT HEATH Sewage Treatment Works (HOLT HEATH (Sewage Treatment Works))	S/08/56181/R	A2			60.9	34	68.85%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HONEYBOURNE (STW)	S/16/26289/R	A2			964.3	42	34.87%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	Hope PS	T/38/45982/O	Single Discharge			17.2	2	55.24%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	HOUGHTON ON THE HILL (STW)	T/53/12089/R	A2			540.7	36	41.86%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	HUNCOTE - MAIN STREET (SPS)	T/50/03632/O-3	A1			87.2	11	89.61%	Maintenance issues have been identified and resolved at this site.	2020
Severn Trent Water	HUNGARTON Sewage Treatment Works (HUNGARTON (Sewage Treatment Works))	T/55/45462/R	A2			1026.6	106	84.25%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	HUNNINGTON - BROMSGROVE ROAD (CSO)	S/06/21059/O	Single Discharge			31.7	22	83.30%	Maintenance issues have been identified and resolved at this site.	2020
Severn Trent Water	ILKESTON - RUTLAND STREET (CSO)	T/61/45159/O	Single Discharge			43.2	26	86.23%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	ILKESTON - SPRINGFIELD GARDEN B (CSO)	T/61/01787/O-6	Single Discharge			12.5	22	84.44%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	IRONBRIDGE - DALE END (SPS)	S/02/55807/O	A1			79.7	22	81.90%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	IRONBRIDGE - IRONBRIDGE RD (CSO)	S/02/21267/O	Single Discharge			1.1	3	79.00%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	IRONBRIDGE, ST. LUKES ROAD	No known permit reference	Single Discharge			0.1	1	83.61%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	JAMES SCOTT ROAD STORM OVERFLOW (LYE - JAMES SCOTT ROAD (CSO))	S/06/21175/O	Single Discharge			0.0	0	73.90%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	JUNCTION GIBFIELD LANE/DERBY ROAD (BELPER - DERBY ROAD/GIBFIELD LANE (CSO))	T/42/20904/O	Single Discharge			2.3	8	45.51%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	JUNCTION of WIGMORE LANE/ (WEST BROMWICH - WATER LANE (CSO))	T/08/02374/O	Single Discharge			0.0	0	81.24%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	KEYWORTH - DEBDALE LANE (SPS)	T/62/45893/O	A1			52.4	13	74.22%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	KEYWORTH - WYNBRECK DRIVE (CSO)	No known permit reference	Single Discharge			0.0	0	0.00%	Reporting impacted by installation issues - action taken to resolve for next year's submission.	2020
Severn Trent Water	KEYWORTH - WYNBRECK DRIVE (CSO)	T/62/40036/O	Single Discharge			0.0	0	0.00%	Reporting impacted by installation issues - action taken to resolve for next year's submission.	2020
Severn Trent Water	KEYWORTH SEWAGE TREATMENT WORKS (KEYWORTH (Sewage Treatment Works))	T/62/45371/R	A2			1424.1	87	83.85%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	KIDDERMINSTER - BLACKWELL ST ISLND (CSO)	S/06/12240/O	Single Discharge			0.0	1	76.67%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	KIDDERMINSTER - BLACKWELL STREET (CSO)	S/06/12241/O-1	Single Discharge			2.7	10	71.85%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	KIDDERMINSTER - MILL STREET (CSO)	S/06/12243/O	Single Discharge			7.0	7	41.34%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	KIMCOTE (STW)	S/10/26413/R	A2			1682.4	174	99.99%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	KINETON - CASTLE CRESCENT (CSO)	S/13/20328/O	Single Discharge			0.0	0	73.48%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	KINGS NORTON - PERSHORE RD SOUTH (CSO)	DT/9864	Single Discharge			0.0	0	0.00%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	KINGS NORTON - WYCHALL LANE (CSO)	DT/9865	Single Discharge			37.8	29	81.99%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	KINGSBURY - COVENTRY ROAD (SPS)	2112	A1			69.0	16	81.83%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	KINVER - POTTERS CROSS (CSO)	S/06/07934/O-2	Single Discharge			0.1	1	47.84%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	KIRBY MUXLOE - COURT CLOSE (SPS)	T/56/03828/O	Single Discharge			38.3	4	83.26%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	KIRBY MUXLOE - RATBY LANE (CSO)	T/56/02605/O-7	Single Discharge			19.8	14	87.05%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	KIRK LANGLEY (STW)	T/47/46016/R	A2			2642.0	140	99.98%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	KIRKBY IN ASHFIELD (STW)	T/61/45171/R	A2			4628.2	220	99.97%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	KNEESALL - A616 (CSO)	T/69/22279/O	Single Discharge			11.7	10	87.58%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	KNIGHTON FIELDS - WELFORD RD (CSO)	T/52/40069/O	Single Discharge			4.9	15	88.92%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	KNOWLE - WARWICK ROAD (CSO)	T/11/01965/O	Single Discharge			19.4	17	75.06%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	LADYWOOD - FRANCIS ROAD (CSO)	T/08/21310/O	Single Discharge			7.1	4	67.74%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	LANGFIELD ROAD STORM OVERFLOW (KNOWLE - LANGFIELD ROAD (CSO))	T/11/20992/O	Single Discharge			7.2	5	88.64%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	LEAMINGTON - PRINCES DR (REF 19A) (CSO)	S/12/20263/O	Single Discharge			142.3	30	88.28%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	LEAMINGTON - PRINCES DR (REF 19B) (CSO)	S/12/20264/O	Single Discharge			9.6	7	88.28%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	LEAMINGTON - PRIORY TERRACE (CSO)	S/12/20258/B	Single Discharge			0.0	0	27.72%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	LEAMINGTON - STAMFORD GARDENS (CSO)	S/12/21859/O	Single Discharge			0.3	1	74.34%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	LEEK - JUNCTION ROAD (CSO)	T/30/03561/O-1	Single Discharge			43.7	35	31.52%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	LEICESTER - BEATRICE RD/RUBY ST (CSO)	T/53/21282/O	Single Discharge			99.4	69	88.96%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	LEICESTER - NARBOROUGH RD/ WESTCOTE RD (CSO)	T/53/21535/O	Single Discharge			0.0	0	79.29%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	LEICESTER - ST MARGARETS WAY (CSO)	T/53/21471/O	Single Discharge			0.0	0	81.25%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	LEICESTER - THE NEWARKE (CSO)	T/53/21452/O	Single Discharge			0.9	4	86.37%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	LEICESTER - TUDOR ROAD/PAGET ROAD (CSO)	T/53/03685/O	Single Discharge			7.9	10	23.07%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	Leicester Bridge O/L D SSO	T/55/03724/O-3	A1			420.7	19	81.83%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	Leicester Bridge O/L E SSO	T/55/03724/O-4	Single Discharge			0.0	0	89.02%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	LEICESTER FOREST-BULLS HEAD PS (CSO)	T/56/02605/O-10	A1			539.6	24	74.54%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	LEINTWARDINE - HIGH STREET 1 CSO)	S/09/21067/O	Single Discharge			30.1	5	79.17%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	LEINTWARDINE - WATLING STREET 1 (CSO)	S/09/21088/O	Single Discharge			32.8	6	54.72%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	LENTON - GREGORY STREET 45 (CSO)	T/62/21952/O	Single Discharge			40.9	20	88.00%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	LENTON - SHERWIN RD/HUNGERTON ST (CSO)	T/63/22400/O	A1			1.2	2	86.81%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	LONGPORT STATION (LONGPORT - STATION STREET (CSO))	T/01/21669/O	Single Discharge			0.9	2	76.74%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	LOUGHBOROUGH - JUBILEE DRIVE (CSO)	T/57/02034/O-2	Single Discharge			99.5	25	40.89%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission.	
Severn Trent Water	LOUGHBOROUGH - MORLEY STREET (CSO)	T/57/08828/O	Single Discharge			36.2	16	87.80%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	LOUGHBOROUGH - PARK ROAD (SST)	T/57/00418/O	Single Discharge			527.0	78	81.57%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	Lowesmoor Bridge	No known permit reference	Single Discharge			19.7	17	85.63%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	LUTTERWORTH - FOX INN (CSO)	S/10/26166/O	Single Discharge			31.0	21	86.20%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	LYDBURY NORTH (STW)	S/09/50131/R	A2			1547.3	107	99.99%	River ingress affecting number of spills being reported at this location.	2020
Severn Trent Water	MAISEMORE - GLOUCESTER ROAD (CSO)	S/20/20191/O	Single Discharge			0.8	3	64.18%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	MANHOLE NO.1 NR THE PUMPING STATION (GREAT HAYWOOD - MANHOLE 1 (CSO))	T/01/00104/O	Single Discharge			35.9	14	75.06%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	MANOR ROAD - STORM OVERFLOW (Manor Rd Wolverhampton Sso)	S/06/12285/O	Single Discharge			57.6	11	50.11%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	MANOR WAY STORM OVERFLOW (HALESOWEN - MANOR WAY (CSO))	S/06/21174/O	Single Discharge			1906.5	101	85.30%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	MANSF. WOODHOUSE - KINGSLEY AVE PS (CSO)	T/71/07573/O	A1			5414.1	227	100.00%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	MANSFIELD WOODHOUSE - PARK HALL RD (CSO)	T/71/09179/O-3	Single Discharge			0.4	1	61.77%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	MARKFIELD - CROFTWAY (CSO)	T/56/45446/O	Single Discharge			55.3	114	61.38%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	MATLOCK - BANK ROAD CSO	T/40/12290/O	Single Discharge			1.0	6	83.75%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MATLOCK BATH - MASSON MILL (CSO)	DT/2181	Single Discharge			104.3	19	88.45%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MATLOCK_178 Bth-DALE RD_(COAL MERCHANTS) ARTISTS CORNER CSO	DT/2179	Single Discharge			602.0	101	83.97%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MATLOCK_LIME GROVE WALK/BANK RD PO CSO	DT/2170	Single Discharge			94.3	106	83.43%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MATLOCK_RAILWAY BRIDGE_DALE RD CSO	DT/2178	Single Discharge			35.5	32	64.49%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	MEADOWS - EASTCROFT DEPOT CSO	T/64/45210/O	Single Discharge			2.8	5	75.22%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	Meadows Way / Ainsworth Drive	No known permit reference	Single Discharge			0.0	0	86.37%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	MELBOURNE - CASTLE LANE (CSO)	T/36/40279/O	Single Discharge			9.3	16	69.05%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	MIDDLETON - CHURCH LANE (CSO)	T/16/02646/O	Single Discharge			1.0	3	44.53%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	MIDDLETON (STW)	S/09/56165/R	A2			0.2	1	69.06%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	MILDRED ROAD STORM OVERFLOW (CRADLEY HEATH - MILDRED ROAD (CSO))	S/06/21058/O	Single Discharge			0.2	1	64.22%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	Mill House PS	S/14/09258/O	A1			75.5	18	88.25%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	MILL LANE COMBINED EWAGE OVERFLOW (NORTHFIELD - MILL LANE (CSO))	T/09/36174/O	Single Discharge			32.2	3	80.80%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	MOIRA - MEASHAM ROAD (SPS)	T/23/02557/O	A1			2.6	4	74.56%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	MORETON MORRELL WWTW (MORETON MORRELL (Sewage Treatment Works))	S/13/26230/R	A2			1041.1	119	99.84%	River ingress affecting number of spills being reported at this location.	
Severn Trent Water	MOUNTSORREL - BETTY HENSERS LANE (SPS)	T/56/02858/O-3	A1			78.9	15	48.09%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission.	
Severn Trent Water	MOUNTSORREL - LOUGHBOROUGH ROAD (CSO)	T/57/22145/O	Single Discharge			51.7	31	84.70%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	MUCH WENLOCK - PRIORY (CSO)	S/02/55370/O	Single Discharge			147.8	45	76.31%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	NANSEN ROAD CSO (WASHWOOD HEATH - NANSEN ROAD 52 (CSO))	T/10/36322/O	Single Discharge			10.8	20	37.04%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	NAPTON (STW)	S/12/25765/R	A2			3958.8	175	99.92%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	NARBOROUGH - JUBILEE CROFT (CSO)	DT/8043	Single Discharge			0.0	0	57.66%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	NECHELLS - LONG ACRE 1 (CSO)	T/09/21102/O	Single Discharge			2.6	3	78.84%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	NEDHAM ROAD STORM WATER OVERFLOW (LEICESTER - NEDHAM STREET (CSO))	T/53/20332/O	Single Discharge			0.1	2	82.53%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	NEW BASFORD - RADFORD RD/NORTHGATE (CSO)	T/63/07899/O	Single Discharge			249.7	52	88.95%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	New Hampton Road West (Gibbs St)	No known permit reference	Single Discharge			0.0	0	62.51%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	NEW ROAD COMBINED SEWAGE OVERFLOW (SOUTH RUBERY - NEW ROAD (CSO))	T/09/36126/O	Single Discharge			2401.6	130	99.85%	Maintenance issues have been identified and resolved at this site.	

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	NEW ROAD STORM OVERFLOW (DUDLEY - NEW ROAD (CSO))	S/06/21844/O	Single Discharge			1.9	5	84.21%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	NEWENT - CLEEVE MILL LANE (CSO)	TSC517	Single Discharge			207.7	41	89.56%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	NEWPORT - BRIDGE TERRACE (CSO)	No known permit reference	Single Discharge			9.1	7	79.87%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	NEWPORT - LOWER BAR (CSO)	No known permit reference	Single Discharge			0.0	0	62.50%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	NEWPORT - WATER LANE (CSO)	S/04/20900/O	Single Discharge			0.0	0	28.44%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	NEWPORT - WATERS LANE COMMUNITY CENTRE (CSO)	No known permit reference	Single Discharge			254.3	40	33.68%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	NEWPORT (STW)	S/04/09049/R	A2			794.3	90	78.04%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	NEWQUAY AV/CHURCHFIELD LANE JCN SSO (RADFORD - NEWQUAY AVENUE (CSO))	T/64/21887/O	Single Discharge			562.0	72	50.40%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	NEWTON SOLNEY - NEWTON PARK (WEST) (SPS)	T/24/12287/O	A1			92.1	11	86.50%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	NEWTOWN - SMITH ST/WELL ST (CSO)	T/09/30264/O	Single Discharge			0.1	1	35.69%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	NORMANTON - CUTTLEBROOK CLOSE (CSO)	T/36/46093/O	Single Discharge			1667.3	92	88.59%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	NORTHWOOD - DALE RD NORTH (RLWY) (CSO)	817/14	Single Discharge			163.8	97	89.90%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	OADBY Sewage Treatment Works (OADBY (Sewage Treatment Works))	T/52/45772/R	A2			1749.9	111	100.00%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	OFF CHURCH HILL - STORM & EMERG (STRETTON-ON-DUNSMORE (TPS))	S/12/07742/O	A1			1815.7	129	85.90%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	off WALKER DRIVE (B) CSO (GRAVELLY HILL - off WALKER DR B (SO))	TSC2055	Single Discharge			25.0	9	84.07%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	OGSTON TREATMENT WORKS (CSO)	T/41/07443/O	Single Discharge			526.9	35	86.93%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	OKER_SNITTERTON_SNITTETON RD SPS	T/40/01181/O	Single Discharge			1006.8	114	100.00%	Monitor calibration issues alongside river ingress affecting number of reported spills - site under review to improve data for next year.	
Severn Trent Water	OLDBURY - BROMFORD LANE (CSO)	T/08/03038/O	Single Discharge			3693.3	167	99.18%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	OSMASTON PUMPING STATION (OSMASTON - CHURCH LANE (SPS))	T/34/30188/O	A1			17.4	7	76.36%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	Outside East Wall of Prison CSO	No known permit reference	Single Discharge			155.0	14	79.36%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	PEARTREE BITHELL'S (GREAT BARR - RAY HALL LANE 13 (SO))	T/08/02635/O	A1			101.0	27	73.10%	Reporting impacted by installation issues - action taken to resolve for next year's submission.	
Severn Trent Water	PEDMORE ROAD STORM OVERFLOW (BRIERLEY HILL - PEDMORE ROAD (CSO))	S/06/55805/O	Single Discharge			0.0	0	75.75%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	PERLETHORPE (TPS)	T/71/03544/T	Single Discharge			0.0	0	88.98%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	PLEASLEY - WILKINSONS CLOSE 6 (CSO)	T/71/21095/O	Single Discharge			0.0	0	77.62%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	PORTOBELLO - DILLOWAYS LA/WAITE RD (CSO)	TSC631	Single Discharge			0.6	1	86.53%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	PRESTBURY - LINDEN CLOSE (CSO)	S/17/08870/O	Single Discharge			246.8	95	64.65%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	QUARRY BANK - COPPICE LANE (CSO)	S/06/21725/O	Single Discharge			63.1	15	86.82%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission.	
Severn Trent Water	QUAY LANE (STW)	S/08/26508/R	A2			292.5	182	99.96%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	QUORN - SOAR ROAD (CSO)	T/57/01373/O-1	Single Discharge			241.8	29	82.26%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	QUORN/BARROW SPS -STORM/EMERG O/F (Sileby Rd Barrow SSO)	T/57/01373/O-2	Single Discharge			7.3	5	87.83%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	RAD BROOK STORM Sewer OVERFLOW (SHREWSBURY - KINGSLAND ROAD (CSO))	S/02/21033/O	Single Discharge			3446.3	173	99.95%	River ingress affecting number of spills being reported at this location.	
Severn Trent Water	RADCLIFFE ON TRENT - BINGHAM RD (CSO)	T/64/40360/O	Single Discharge			324.4	129	78.71%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	RAINWORTH (STW)	T/70/45715/R	A2			1822.9	116	99.81%	Maintenance issues have been identified and resolved at this site.	2020
Severn Trent Water	RATBY PS & VILLAGE/STM/EMG/SWS (Ratby PS)	T/56/02657/O-3	A1			0.0	0	80.31%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	REARSBY - MILL ROAD PS (CSO)	T/55/40129/O	A1			79.9	16	69.76%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	RETFORD - LONDON RD (CSO)	T/74/21615/O	Single Discharge			557.3	40	85.17%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	ROLLESTON - SOUTH HILL (CSO)	T/33/08436/O	Single Discharge			3.1	1	68.39%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	ROTHLEY - TOWN GREEN STREET (CSO)	T/56/08751/O	Single Discharge			407.7	46	73.35%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	ROTHLEY (SPS)	T/57/45485/O	A1			1790.0	179	99.99%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	ROUNDHILL WASTEWATER TREATMENT WRKS (ROUNDHILL (Sewage Treatment Works))	S/06/55232/R	A3			1453.7	164	93.84%	Maintenance issues have been identified and resolved at this site.	Maintenance issues have been identified which affect the number of reported spills - these issues have been resolved.
Severn Trent Water	ROWNEY GREEN (MINI) (SPS)	S/15/23073/O	A1			286.3	25	61.27%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	ROWSLEY - SCHOOL LANE (TPS)	T2386-3	A1			0.0	0	14.70%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	RUSHBURY (STW)	S/09/55814/O	A2			355.9	184	67.88%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	RUSPIDGE - RAILWAY ROAD (CSO)	S/20/22172/O	Single Discharge			41.7	8	73.21%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	SALFORD PRIORS - STATION ROAD (CSO)	S/17/21775/O	Single Discharge			13.4	11	71.33%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	SANDIACRE PASTURE LOCK CSO (SANDIACRE - PASTURE LOCK (CSO))	EPRAP3421GQ	Single Discharge			356.6	61	86.31%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	SAPCOTE - ASTON FIRS (SPS)	T/50/40071/O	A1			11.9	4	57.77%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	SCHOOL LANE STORM OVERFLOW (SUDBURY - SCHOOL LANE (CSO))	T/33/21297/O	Single Discharge			0.0	0	81.63%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	Scott Street	No known permit reference	Single Discharge			1.8	6	79.88%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	SCREVETON - KNIGHTS CLOSE (SPS)	T/67/45396/O	Single Discharge			0.0	0	58.52%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	SCUNTHORPE - EAST COMMON LANE 122 (CSO)	T/81/45036/O	Single Discharge			27.3	15	87.45%	Maintenance issues have been identified and resolved at this site.	2020
Severn Trent Water	SCUNTHORPE - SCOTTER RD (CSO)	635	Single Discharge			189.8	39	26.74%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	SCUNTHORPE - SOUTH GRANGE (CSO)	T/81/12307/O	Single Discharge			279.8	101	48.98%	Maintenance issues have been identified and resolved at this site.	2020
Severn Trent Water	SHARDLOW (STW)	T/36/45805/R	A2			2743.0	224	99.77%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	SHARNFORD - THE GREEN (SPS)	T/50/03632/O-5	A1			59.8	8	79.44%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	SHEAFHOUSE FARM (CSO)	S/14/25382/O	Single Discharge			38.7	10	88.92%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	Shelton New Rd Cliff Vale SSO	T/01/21508/O	Single Discharge			0.1	1	31.54%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	SHENTON WEST (TPS)	T/20/02399/O-1	Single Discharge			260.4	24	87.37%	Maintenance issues have been identified and resolved at this site.	2020
Severn Trent Water	SHEPSHED WASTEWATER TREATMENT WKS (SHEPSHED (Sewage Treatment Works))	T/57/45608/R	A2			68.4	19	39.99%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	SHOWELL ROAD	No known permit reference	Single Discharge			0.7	3	69.49%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	SHREWSBURY - BRIDGE ST/HILLS LA (CSO)	S/02/21107/O	Single Discharge			234.7	48	84.59%	River ingress affecting number of spills being reported at this location. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	SHREWSBURY - CLAREMONT BANK (CSO)	S/02/21037/O	Single Discharge			2848.0	189	86.32%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	SHREWSBURY - DITHERINGTON RD (CSO)	S/02/21038/O	Single Discharge			7.7	10	74.27%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	SHREWSBURY - MANOR WAY (BELVIDERE) (SPS)	TSC3095	A1			0.0	0	86.16%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	SHREWSBURY - UNDERDALE ROAD 2 (CSO)	S/02/21020/O	Single Discharge			4.5	3	36.72%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission.	
Severn Trent Water	SHREWSBURY - VICTORIA AV (CSO)	S/02/21032/O	Single Discharge			2584.7	159	99.76%	River ingress affecting number of spills being reported at this location.	
Severn Trent Water	SHREWSBURY - WHITE HART ROAD (SPS)	TSC4101	A1			0.0	0	34.36%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	SHREWSBURY MONKMOOR Sewage Treatment Works (MONKMOOR (Sewage Treatment Works))	S/02/56373/R	A3			3842.9	187	100.00%	Monitor calibration issues alongside river ingress affecting number of reported spills - site under review to improve data for next year.	
Severn Trent Water	SIBSON (TPS)	T/20/02399/O-2	Single Discharge			146.0	18	89.44%	Maintenance issues have been identified and resolved at this site.	2020
Severn Trent Water	SILEBY - COSSINGTON ROAD (SPS)	T/56/02858/O-4	Single Discharge			50.3	11	79.50%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	SILVERDALE SEWAGE PUMPING STATION (SILVERDALE - SILVERDALE ROAD (SPS))	T/01/30327/O	A1			2503.0	106	38.68%	River ingress affecting number of spills being reported at this location. Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	SINFIN - WILMORE ROAD (CSO)	T/36/46026/O	Single Discharge			0.0	0	77.74%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	SMALL HEATH - HEYBARNES RD (CSO)	T/12/02961/O-2	Single Discharge			0.0	0	71.69%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	SMETHWICK - STONEY LANE (CSO)	T/09/35149/O	Single Discharge			179.3	9	85.51%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	SNEINTON - 264 SNEINTON DALE CSO	T/64/40038/O	Single Discharge			0.3	3	82.32%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	SNEINTON - 331 SNEINTON DALE CSO	T/64/21892/O	Single Discharge			43.7	51	82.09%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	SNEINTON - MEADOW LANE / DALESIDE RD JCN CSO	T/64/21888/O	Single Discharge			107.3	20	82.38%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	SNEINTON _10 ST ANNE'S WELL RD / RANSOM RD CSO	T/64/07994/O-2	Single Discharge			6.0	9	85.62%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission.	
Severn Trent Water	Sneinton PS	T/64/45209/O	A1			541.0	43	84.93%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	SNEINTON_SNEINTON DALE_EDALE RD CSO	T/64/45267/O	Single Discharge			9.2	18	81.84%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	SNEINTON_SNEINTON DALE_WATSON ST CSO	T/64/21891/O	Single Discharge			209.9	87	64.99%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	SNITTERFIELD - LODGE FARM DRIVE (CSO)	S/13/23221/O	Single Discharge			36.3	9	88.27%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	SO HIGH ST AND SO PLECK (High St Bidford-on-Avon SSO)	S/13/07378/O-3	Single Discharge			15.3	22	63.08%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	SO HIGH ST AND SO PLECK (The Pleck (Upstream of PS) Bidford CSO)	S/13/07378/O-4	Single Discharge			719.7	34	49.69%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	SOMERBY (STW)	T/54/45992/R	A2			482.2	50	89.49%	Maintenance issues have been identified and resolved at this site.	2020
Severn Trent Water	SOUTH NORMANTON - WATER LANE (CSO)	T/41/03160/O	Single Discharge			27.5	17	84.81%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	SOUTHFIELD ROAD STORM OVERFLOW (HINCKLEY - SOUTHFIELD ROAD (CSO))	T/19/22033/O	Single Discharge			48.2	42	66.64%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	SPONDON - ANGLERS LANE 39/41 (CSO)	T/48/21193/O	Single Discharge			36.8	7	82.98%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	SPONDON - DALE RD/SANDRINGHAM DR (CSO)	T/48/20202/O	Single Discharge			23.4	20	78.38%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	ST ANNE'S - CURZON GARDENS CSO	T/64/21894/O	Single Discharge			10.4	23	81.88%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	STANLEY - GLEBE CRESCENT (CSO)	T/61/01094/O	Single Discharge			8.5	2	85.84%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	STANTON (DERBYSHIRE) STW (Discharges to River Trent)	WB3535AJ	A2			1193.7	79	86.58%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission.	
Severn Trent Water	STAPLEFORD - NEW ROAD (CSO)	T/61/12357/O	Single Discharge			11.2	4	81.25%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	STATION ROAD (CSO)	No known permit reference	Single Discharge			5.7	6	69.03%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	Station Road/ Eastern Road CSO	No known permit reference	Single Discharge			0.0	0	0.00%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	STOCKTON-NEW ZEALAND FM-NAPTON RD (SPS)	S/12/25046/O	Single Discharge			212.3	25	82.10%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	STONE - CROWN STREET 3 (CSO)	T/01/30015/O	Single Discharge			33.9	17	85.30%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	STONE - NEWCASTLE ROAD (CSO)	T/01/35277/O	Single Discharge			311.0	63	36.40%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	STONEHOUSE - REGENT STREET (CSO)	S/22/06022/O	Single Discharge			58.5	33	87.01%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	STONEY STANTON - SAPCOTE ROAD (CSO)	T/50/07734/O	Single Discharge			145.5	34	83.56%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	STORM OVERFLOW/SWS/SUTTON-IN-ASHFLD (SUTTON IN ASHFIELD - SHEEPWASH LA (CSO))	T/70/03659/O-2	Single Discharge			4.0	12	88.41%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	STOUR VALE RD STORM SEWAGE O/F (LYE - STOUR VALE ROAD (CSO))	S/08/55810/O	Single Discharge			66.8	18	77.64%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	STOURPORT ON SEVERN - VALE RD (CSO)	S/06/12236/O	Single Discharge			28.6	5	87.05%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	STOURPORT ROAD PUMPING STATION (BEWDLEY - STOURPORT ROAD (SPS))	S/08/50205/O	A1			1869.7	99	62.90%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	STRATFORD - ALCESTER RD/CHURCH LA (CSO)	S/13/23220/O	Single Discharge			68.2	41	81.22%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	STRATFORD - BANBURY RD/DALE AV (CSO)	S/13/09259/O	Single Discharge			3.7	2	67.73%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	STRATFORD - BRIDGEWAY (CSO)	S/13/26430/O	Single Discharge			23.7	11	81.39%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	STRATFORD - SHIPSTON ROAD (CSO)	S/13/21639/O	Single Discharge			0.0	0	29.99%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	STRATFORD - TIDDINGTON ROAD (CSO)	S/13/09259/O-2	Single Discharge			7.5	5	85.87%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	STREETLY - BRIDLE LANE 80 (CSO)	T/10/35327/O	Single Discharge			80.2	58	81.28%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	STREETLY - WHITE FARM ROAD (CSO)	T/17/21266/O	Single Discharge			0.0	0	74.64%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	STRETTON-ON-FOSSE Sewage Treatment Works (STRETTON-ON-FOSSE (Sewage Treatment Works))	S/14/26229/R	A2			109.2	167	99.62%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	SUDBURY SEWAGE TREATMENT WORKS (SUDBURY (Sewage Treatment Works))	T/33/35620/R	A2			3694.5	209	99.91%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	SUGARBROOK (BPS)	S/07/55347/T	A1			524.1	50	50.69%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	SUTTON IN ASHFIELD - LUCKNOW DRIVE (CSO)	T/70/03659/O-1	Single Discharge			316.2	27	85.41%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	SUTTON IN ASHFIELD - PEEL STREET (CSO)	T/70/45413/O	Single Discharge			92.6	26	85.47%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	SUTTON IN ASHFIELD - PEPPER STREET (CSO)	T/70/07278/O-2	Single Discharge			1.3	7	80.59%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	Sutton In Ashfield Inlet PS No2	T/70/45397/O	A1			6.3	4	84.46%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission.	
Severn Trent Water	SWADLINCOTE_BOARDMAN IND EST/HOSPITAL LANE CSO	T/24/30139/O	Single Discharge			19.0	8	64.33%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	SWANFIELD ROAD STORM OVERFLOW (BRIERLEY HILL - SWANFIELD ROAD (CSO))	S/06/21850/O	Single Discharge			0.0	0	47.67%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	SYDNEY GROVE SEWAGE PUMPING STATION (RADCLIFFE ON TRENT - SYDNEY GRV (TPS))	T/64/46094/O	A1			5229.6	241	75.12%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	SYSTON - TURN STREET (SPS)	T/55/40150/O	A1			2.6	24	76.50%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	TANSLEY OLD COACH RD CSO	T/40/21451/O	Single Discharge			11.1	5	75.44%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	TELFORD - FURNACE LA TRENCH (R EX) (CSO)	S/04/12251/O-2	Single Discharge			2.3	7	79.34%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	TEMESIDE PUMPING STATION (LUDLOW - TEMESIDE (TPS))	S/09/21650/O	A1			233.8	65	84.24%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	THE DELVES - WALSTEAD RD/BELL LA (CSO)	T/08/35632/O	Single Discharge			118.4	61	89.00%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	The Delves (Goodwin) Swanwick CSO	T/41/21715/O	Single Discharge			1596.4	176	99.98%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	THE FLASH STORM O/F (SHREWSBURY - COTON HILL (CSO))	S/02/21023/O	Single Discharge			770.7	75	45.13%	River ingress affecting number of spills being reported at this location. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	THIMBLEMILL ROAD STORM OVERFLOW (SMETHWICK - THIMBLEMILL ROAD (CSO))	T/08/35227/O	Single Discharge			0.0	0	8.95%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	THORNEY - ROADWOOD ROAD (SPS)	TSC3824	A1			0.0	0	75.53%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	THORNHILL RD STORM O/F (SHREWSBURY - THE MOUNT (CSO))	S/02/21009/O	Single Discharge			163.4	86	69.40%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	THRUSSINGTON - REARSBY ROAD (SPS)	T/55/40151/O	A1			185.5	45	76.06%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	THURCASTON - MILL ROAD (SPS)	T/56/01285/O-4	A1			271.3	27	40.85%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	THURMASTON - CANAL STREET (SPS)	T/53/01523/O-1	A1			0.0	0	81.65%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	TIBSHELF - HIGH ST/FIVE PITS TRAIL (SO)	T/41/03162/O-1	Single Discharge			0.0	0	50.91%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	TICKHILL (STW)	T/83/45915/R	A2			4977.5	220	99.92%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	TIDDINGTON - MAIN STREET (CSO)	S/13/08803/O	Single Discharge			15.9	20	81.37%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	TILE CROSS - SHELDON HALL AVENUE (CSO)	T/12/22015/O	Single Discharge			1.4	3	84.67%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	TITFORD PUMPING STATION (WHITEHEATH - TITFORD LANE (CSO))	T/08/36285/O	Single Discharge			35.0	19	77.43%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	TOLLERTON - HOE HILL (SPS)	T/64/40294/O	A1			81.5	17	89.03%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	TOLLERTON - LOTHIAN RD SPS	T/64/40321/O	A1			488.5	68	84.93%	Longer term investment in improvements for the site has caused a period of non-reporting. Benefits will be seen during next year's submission.	
Severn Trent Water	TOTON - WOODSTOCK ROAD (CSO)	T/62/21206/O	Single Discharge			2.5	7	82.24%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	TRESCOTT (STW)	S/06/55363/R	A2			6544.7	276	100.00%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020
Severn Trent Water	TUFFLEY - GRANGE ROAD (CSO)	S/20/12253/R	Single Discharge			40.2	7	78.48%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	TWO DALES - CHESTERFIELD RD (CSO)	817-15	Single Discharge			0.4	1	58.49%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	TWO DALES GARAGE DALE RD SOUTH CSO	T/40/45742/O	Single Discharge			107.3	36	83.48%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	UPPER STRENSHAM PUMPING STATION (Upper Strensham PS)	S/17/22197/O	A1			24.3	3	89.93%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	UTTOXETER - HIGH STREET/MANOR ROAD (CSO)	T/32/20997/O	Single Discharge			45.4	26	88.85%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	UTTOXETER ROAD (LONGTON - UTTOXETER RD/CHADWICK ST (CSO))	T/01/30153/O	Single Discharge			0.1	1	69.29%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	WALSALL - BIRMINGHAM RD (THE BELL) (CSO)	T/08/03428/O	Single Discharge			0.5	2	71.38%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	WANLIP SEWAGE TREATMENT WORKS (WANLIP (Sewage Treatment Works))	T/53/46354/R	A4			172.9	22	82.68%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	WARSLOW (STW)	T/26/35919/R	A2			1376.2	106	61.69%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	WATERHEAD DRIVE (WESTCROFT - WATERHEAD DRIVE (CSO))	T/03/07865/O	Single Discharge			25.2	17	81.76%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	WATERHOUSES - A523 (SPS)	T/27/30247/O	A1			0.0	0	81.54%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020
Severn Trent Water	WELFORD-ON-AVON - BARTON ROAD (CSO)	S/13/08946/O	Single Discharge			16.8	6	67.04%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	WELFORD-ON-AVON - BOAT LANE (SPS)	TSC4064	Single Discharge			134.6	34	85.95%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	WERGS - WROTTERSELY RD (SPS)	TSC4072	Single Discharge			105.9	28	65.39%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	2020
Severn Trent Water	WEST HALLAM - ST WILFRIDS ROAD (CSO)	T/61/45469/O	Single Discharge			107.1	49	57.27%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	WESTMINSTER ROAD CSO (BIRCHFIELD - WESTMINSTER ROAD (CSO))	T/08/36132/O	Single Discharge			0.6	2	84.49%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	WESTON UNDERWOOD (STW)	T/47/45561/R	A2			225.7	142	100.00%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	2020

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	WHITNASH - SOUTH FARM (SPS)	TSC4102	A1			7.3	2	51.11%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	WIGSTON - MIDLAND COTTAGES (CSO)	T/51/40058/O	Single Discharge			0.1	2	81.40%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	WILMCOTE - CHURCH ROAD (CSO)	S/13/26500/O	Single Discharge			1.6	3	74.94%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	WINDSOR GROVE - STORM OVERFLOW (WORDSLEY - WINDSOR GROVE (CSO))	S/06/08130/O	Single Discharge			4.0	4	23.88%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	WINSON GREEN - ALL SAINTS HOSPTL 1 (CSO)	T/09/30275/O	Single Discharge			0.0	0	36.51%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	WIRKSWORTH - WARMBROOK/DERBY ROAD (SO)	T/43/21425/O	Single Discharge			1.0	2	51.36%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	WOLVERHAMPTON - PARK CRESCENT (CSO)	S/06/50097/O	Single Discharge			1.5	24	72.83%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	WOODHOUSE - RUSHEY MANOR	No known permit reference	Single Discharge			18.0	20	86.65%	Maintenance issues have been identified and resolved at this site.	2020
Severn Trent Water	WOODHOUSE EAVES - MEADOW LANE (CSO)	T/57/45735/O	Single Discharge			3.1	13	77.93%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	WORCESTER - DIGLIS AVENUE SYPHON (CSO)	S/08/55356/O	Single Discharge			398.4	42	86.19%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	WORCESTER - GRANDSTAND ROAD (CSO)	S/08/56332/O	Single Discharge			205.3	10	18.99%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	
Severn Trent Water	WORCESTER - HYLTON ROAD/HENWICK RD (CSO)	S/08/50127/O	Single Discharge			496.1	212	97.50%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	WORCESTER - ORCHARD ST (CSO)	S/08/21015/O	Single Discharge			70.8	30	85.02%	Maintenance issues have been identified and resolved at this site. For a proportion of the submission period this monitor has been reporting at a lower than required timestep which affects the data provided. Process improvements have been put in place to resolve this issue for next year's submission.	
Severn Trent Water	WWOLVERHAMPTON - BILSTON RD 2 (CSO)	T/08/20244/O	Single Discharge			2.9	2	88.96%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	WYASTON SEWAGE TREATMENT WORKS (WYASTON (Sewage Treatment Works))	T/34/35859/R	A2			2694.1	155	99.93%	Maintenance issues have been identified at this site and maintenance tasks are scheduled to improve data quality for next year's return.	
Severn Trent Water	WYRE ROAD SEWAGE PUMPING STATION (PERSHORE - WYRE ROAD (SPS))	S/17/26005/O	A1			2446.9	119	100.00%	Maintenance issues have been identified which affect the number of reported spills - these issues have been resolved.	
Severn Trent Water	YARDLEY - YARDLEY GREEN ROAD (CSO)	DT9714	Single Discharge			22.6	10	74.66%	Further investigation to be undertaken and maintenance to be scheduled accordingly.	2020

APPENDIX 1: EDM ADDENDUM DATA

Where sites are labelled in red, this indicates the data is likely to be inaccurate due to issues with maintenance, installation or river ingress.

Water Company Name	Site Name	Permit No.	Activity Reference (if more than one discharge) on permit	Shellfishery (Only populate for storm overflows that have Shellfish water EDM requirements)	Bathing Beach (Only populate for storm overflows that have bathing water EDM requirements)	Total Duration (hours) of all spills prior to processing through 12-24 hour counting method	Counted spills using 12-24hr counting method	% of reporting period EDM operational	Comments	First Reporting Year
Severn Trent Water	EDWARD STREET STORM OVERFLOW (BALSALL HEATH - EDWARD ROAD (CSO))	T/09/21428/O	Single Discharge			0.2	1	93.38%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	EVESHAM - BURFORD ROAD 8&9 (CSO)	S/17/05968/O	Single Discharge			2.6	10	97.72%		
Severn Trent Water	Floyer Road Bordesley Green	No known permit reference	Single Discharge			0.0	0	61.38%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	HOLLOWAY SCHOOL ROAD (TETTENHALL - SCHOOL ROAD/WOOD ROAD (CSO))	T/03/12429/O-2	Single Discharge			0.0	0	89.06%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	HUNCOTE - FOREST RD/EUNICE AVE (CSO)	DT/8047 & TSC707	Single Discharge			0.0	0	79.64%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	KEGWORTH - WHATTON ROAD (CSO)	T/57/08994/O-2	Single Discharge			0.0	1	66.20%	Maintenance issues have been identified and resolved at this site.	
Severn Trent Water	MORDA - WESTON ROAD (CSO)	S/01/22537/O	Single Discharge			15.5	10	99.98%		
Severn Trent Water	OPPOSITE NO.155 THE AVENUE CSO (HARPFIELDS - THE AVENUE 155 (CSO))	T/01/35717/O	Single Discharge			0.1	1	100.00%		
Severn Trent Water	QUARNDON - CHURCH ROAD 114 (CSO)	T/47/21116/O	Single Discharge			1.6	3	65.48%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	ROCESTER - ASHBOURNE ROAD (CSO)	T/30/30181/O	Single Discharge			0.0	0	0.00%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	2020
Severn Trent Water	SHUTTINGTON (SPS)	T/21/00159/R-3	Single Discharge			0.0	0	0.00%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	SMETHWICK - DOWNING STREET (CSO)	T/08/35702/O	Single Discharge			1.1	3	94.10%	Maintenance process issues have affected the amount of data available. Process improvements have been put in place to resolve for next year's submission.	
Severn Trent Water	SMETHWICK - RABONE LANE (CSO)	T/08/35705/O	Single Discharge			3.0	5	99.99%		
Severn Trent Water	SS FROM QUARRY LANE CSO NORTHFIELD (NORTHFIELD - QUARRY LANE (CSO))	T/09/36175/O	Single Discharge			0.8	5	99.74%		